

ECM 2a – Water Conservation Measures with Waterless Urinals

Arapahoe County Domestic Water
Administration Building

Assumptions	
Staff Population	358.00
Pop Ratio Female	50.00%
Visitor Population	1000
Pop Ratio Female	0.5
Length of Stay (hrs)	0.50
Inmate Population	0
Pop Ratio Female	0.7
Length of Stay (hrs)	4.00
Staff Absentee rate	10.00%
Days/year	236
Site Type (Res Comm)	comm
Laundry Population	0

Water Temperature	
Street	54
DHW supply	130
Boiler Efficiency	100%
Laundry	
Cycle/person/day	0
Gallons/load Pre	37.5
Gallons/load Post	25

Ice Machine Calc.	
Lbs/Day	0 lbs
Lbs/Year	0 lbs
Gallons / year	0 gal
Gallons of water/100 lbs of ice	16 gal
Process waste	0 gal
Est. Storage Waste	0 gal
Number of Ice Machines	1 gal
Total Storage Waste	24 gal
Total Ice Machine Usage (Gallons)	0 gal

Energy Inputs	
DHW heating source	NG
Fuel conversion source	GC
Nat. Gas System Efficiency	100.00%

Lbs/Year	5200
Gallons / year	624
Gallons of water/100 lbs of ice	16
Process waste	208
Est. Storage Waste	8000
Number of Ice Machines	8000
Total Ice Machine Usage (Gallons)	8832


Arapahoe County Domestic Water Administration Building

2.4 gallons/minute/100 tons of cooling	3 Rule of thumb CFM/SF
748 Chiller size	0.075 lb/cf density of air
Number of Chillers	122,833 SF of conditioned space
Design Load	368,499 CFM total
50% turn down	
24 minimum load	

http://qweather.com/ccd/nrmccdd.htm


Month	CCD	% of CCD in this Month	Gallons / month
Jan	0	0%	0
Feb	0	0%	0
Mar	0	0%	0
Apr	2	0%	3,795
May	23	3%	43,638
Jun	135	19%	256,137
Jul	281	38%	495,199
Aug	217	31%	411,717
Sep	57	8%	108,147
Oct	0	0%	0
Nov	0	0%	0
Dec	0	0%	0
	695	1	1,318,634

Month	DENVER Wet Bulb	DENVER RH	DENVER Mean Dry Bulb	DENVER High Temp Dry Bulb	Average High and mean	Psychrometric Chart Humidity Ratio (#moisture / # of dry air)	Gallons / month
Jan	24	49	36.4	43.2	39.8		
Feb	27	44	36.5	47.2	41.9		
Mar	31	40	43.1	53.7	48.4		
Apr	38	35	50.9	60.9	55.9		
May	46	38	61.0	70.5	65.8		
Jun	54	35	69.2	82.1	75.7	0.002000	286,659
Jul	58	34	78.2	88.0	83.1	0.003200	458,655
Aug	57	35	74.8	86.0	80.4	0.003000	429,989
Sep	50	34	65.9	77.4	71.7	0.001000	143,330
Oct	41	36	53.2	66.0	59.6		
Nov	31	49	41.0	51.5	46.3		
Dec	25	52	35.2	44.1	39.7		
	40	50	53.8	64.2	59.0		1,318,634



[illegible][illegible]

Coal Analysis	No. Sectors Type	Non Sector Use (M)	Co. sector Use (M)	Export Co. sector	Location	Market	Total traded non-sector use
Jan	41	0	0	0	0	0	0
Feb	41	0	0	0	0	0	0
Mar	41	0	0	0	0	0	0
Apr	41	0	0	0	0	0	0
May	41	0	0	0	0	0	0
June	41	0	0	0	0	0	0
July	41	0	0	0	0	0	0
Aug	41	0	0	0	0	0	0
Sept	41	0	0	0	0	0	0
Oct	41	0	0	0	0	0	0
Nov	41	0	0	0	0	0	0
Dec	41	0	0	0	0	0	0
Total	41	0	0	0	0	0	0



Arapahoe County Domestic Water
Administration Building

Code	Units
1	Gal
2	Kgal
3	Cf
4	Ccf
5	Mcf
2	<<< enter unit code

Summer rate \$3.000000 per
Winter rate \$0.000000 per
Water Rate \$2.570000 per
Sewer Rate \$0.000000 per
Service Charge \$85.20 bi monthly
Storm water fee \$2.460.00 annual
Fireline Charge \$15.03 bi monthly

Read Date	Month	Kgal/day	Usage	Gallons	Billing days	Water Charges	Sewer Charges	Total Watered Charges	Total Water Charges	Total Charges
5/27/2004	May	21	699	699,324	31	\$1,737	\$1,668	\$3,405	\$1,737	\$3,405
6/30/2004	Jun	26	790	789,762	30	\$2,036	\$1,968	\$3,968	\$2,036	\$3,968
7/30/2004	Jul	28	878	878,157	31	\$2,257	\$2,188	\$4,445	\$2,257	\$4,445
8/30/2004	Aug	31	955	954,706	31	\$2,454	\$2,385	\$4,839	\$2,454	\$4,839
9/30/2004	Sep	23	655	655,211	28	\$1,684	\$1,615	\$3,299	\$1,684	\$3,299
10/28/2004	Oct	16	505	504,794	33	\$1,349	\$1,280	\$2,629	\$1,349	\$2,629
11/30/2004	Nov	14	428	427,553	30	\$1,058	\$1,000	\$2,058	\$1,058	\$2,058
12/31/2004	Dec	4	121	120,761	30	\$258	\$258	\$516	\$258	\$516
1/30/2005	Jan									
						141,378,470.3		17,199,222.03		216,193,780.3

\$/gal Water charge	\$/gal Sewer charge	\$/gallon Total
\$0.0021	\$0.0028	\$0.0050
\$0.0021	\$0.0032	\$0.0053
\$0.0021	\$0.0044	\$0.0065
\$0.0021	\$0.0010	\$0.0032
\$0.0026	\$0.0065	\$0.0091
\$0.0026	\$0.0003	\$0.0030
\$0.0026	\$0.0004	\$0.0030
\$0.0026	\$0.0004	\$0.0030
\$0.0026	\$0.0005	\$0.0031
\$0.0026	\$0.0007	\$0.0033
\$0.0021	\$0.0017	\$0.0039
\$0.0021	\$0.0031	\$0.0052

129,964	130
115,828	116
266,561	267
352,443	352
699,329	699
789,762	790
878,157	878
954,706	955
655,211	655
524,794	525
214,553	215
120,761	121

Arapahoe County Domestic Water
Arapahoe Plaza East

Assumptions	
Staff Population	60.00
Pop Ratio Female	50.00%
Visitor Population	200
Pop Ratio Female	0.5
Length of Stay (hrs)	1.00
Inmate Population	0
Pop Ratio Female	0.7
Length of Stay (hrs)	4.00
Staff Absentee rate	0.00%
Days/year	236
Site Type (Res Comm)	comm
Laundry Population	0

Water Temperature	
Street	54
DHW supply	130
Boiler Efficiency	100%
Laundry	
Cycle/person/day	0
Gallons/load Pre	37.5
Gallons/load Post	25

Ice Machine Calc.	
Lbs/Day	0 lbs
Lbs/Year	0 lbs
Gallons / year	0 gal
Gallons of water/100 lbs of ice	16 gal
Process waste	0 gal
Est. Storage Waste	0 gal
Number of Ice Machines	1 gal
Total Storage Waste	24 gal
Total Ice Machine Usage (Gallons)	0 gal

Energy Inputs	
DHW heating source	NG
Fuel conversion source	GG
Not. Gas System Efficiency	100.00%

Lbs/Year	5200
Gallons / year	624
Gallons of water/100 lbs of ice	16
Process waste	832
Est. Storage Waste	8000
Number of Ice Machines	8000
Total Ice Machine Usage (Gallons)	8832

Use only the following

WYJG/PZCN[illegible][illegible][illegible]

Year	Day	Month	Year
1997	10	10	1997

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----

YHMA 200

235	235	235
236	236	236

Year	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067	2068	2069	2070	2071	2072	2073	2074	2075	2076	2077	2078	2079	2080	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093	2094	2095	2096	2097	2098	2099	2100																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																			
Population (millions)	5.3	5.5	5.7	5.9	6.1	6.3	6.5	6.7	6.9	7.1	7.3	7.5	7.7	7.9	8.1	8.3	8.5	8.7	8.9	9.1	9.3	9.5	9.7	9.9	10.1	10.3	10.5	10.7	10.9	11.1	11.3	11.5	11.7	11.9	12.1	12.3	12.5	12.7	12.9	13.1	13.3	13.5	13.7	13.9	14.1	14.3	14.5	14.7	14.9	15.1	15.3	15.5	15.7	15.9	16.1	16.3	16.5	16.7	16.9	17.1	17.3	17.5	17.7	17.9	18.1	18.3	18.5	18.7	18.9	19.1	19.3	19.5	19.7	19.9	20.1	20.3	20.5	20.7	20.9	21.1	21.3	21.5	21.7	21.9	22.1	22.3	22.5	22.7	22.9	23.1	23.3	23.5	23.7	23.9	24.1	24.3	24.5	24.7	24.9	25.1	25.3	25.5	25.7	25.9	26.1	26.3	26.5	26.7	26.9	27.1	27.3	27.5	27.7	27.9	28.1	28.3	28.5	28.7	28.9	29.1	29.3	29.5	29.7	29.9	30.1	30.3	30.5	30.7	30.9	31.1	31.3	31.5	31.7	31.9	32.1	32.3	32.5	32.7	32.9	33.1	33.3	33.5	33.7	33.9	34.1	34.3	34.5	34.7	34.9	35.1	35.3	35.5	35.7	35.9	36.1	36.3	36.5	36.7	36.9	37.1	37.3	37.5	37.7	37.9	38.1	38.3	38.5	38.7	38.9	39.1	39.3	39.5	39.7	39.9	40.1	40.3	40.5	40.7	40.9	41.1	41.3	41.5	41.7	41.9	42.1	42.3	42.5	42.7	42.9	43.1	43.3	43.5	43.7	43.9	44.1	44.3	44.5	44.7	44.9	45.1	45.3	45.5	45.7	45.9	46.1	46.3	46.5	46.7	46.9	47.1	47.3	47.5	47.7	47.9	48.1	48.3	48.5	48.7	48.9	49.1	49.3	49.5	49.7	49.9	50.1	50.3	50.5	50.7	50.9	51.1	51.3	51.5	51.7	51.9	52.1	52.3	52.5	52.7	52.9	53.1	53.3	53.5	53.7	53.9	54.1	54.3	54.5	54.7	54.9	55.1	55.3	55.5	55.7	55.9	56.1	56.3	56.5	56.7	56.9	57.1	57.3	57.5	57.7	57.9	58.1	58.3	58.5	58.7	58.9	59.1	59.3	59.5	59.7	59.9	60.1	60.3	60.5	60.7	60.9	61.1	61.3	61.5	61.7	61.9	62.1	62.3	62.5	62.7	62.9	63.1	63.3	63.5	63.7	63.9	64.1	64.3	64.5	64.7	64.9	65.1	65.3	65.5	65.7	65.9	66.1	66.3	66.5	66.7	66.9	67.1	67.3	67.5	67.7	67.9	68.1	68.3	68.5	68.7	68.9	69.1	69.3	69.5	69.7	69.9	70.1	70.3	70.5	70.7	70.9	71.1	71.3	71.5	71.7	71.9	72.1	72.3	72.5	72.7	72.9	73.1	73.3	73.5	73.7	73.9	74.1	74.3	74.5	74.7	74.9	75.1	75.3	75.5	75.7	75.9	76.1	76.3	76.5	76.7	76.9	77.1	77.3	77.5	77.7	77.9	78.1	78.3	78.5	78.7	78.9	79.1	79.3	79.5	79.7	79.9	80.1	80.3	80.5	80.7	80.9	81.1	81.3	81.5	81.7	81.9	82.1	82.3	82.5	82.7	82.9	83.1	83.3	83.5	83.7	83.9	84.1	84.3	84.5	84.7	84.9	85.1	85.3	85.5	85.7	85.9	86.1	86.3	86.5	86.7	86.9	87.1	87.3	87.5	87.7	87.9	88.1	88.3	88.5	88.7	88.9	89.1	89.3	89.5	89.7	89.9	90.1	90.3	90.5	90.7	90.9	91.1	91.3	91.5	91.7	91.9	92.1	92.3	92.5	92.7	92.9	93.1	93.3	93.5	93.7	93.9	94.1	94.3	94.5	94.7	94.9	95.1	95.3	95.5	95.7	95.9	96.1	96.3	96.5	96.7	96.9	97.1	97.3	97.5	97.7	97.9	98.1	98.3	98.5	98.7	98.9	99.1	99.3	99.5	99.7	99.9	100.1	100.3	100.5	100.7	100.9	101.1	101.3	101.5	101.7	101.9	102.1	102.3	102.5	102.7	102.9	103.1	103.3	103.5	103.7	103.9	104.1	104.3	104.5	104.7	104.9	105.1	105.3	105.5	105.7	105.9	106.1	106.3	106.5	106.7	106.9	107.1	107.3	107.5	107.7	107.9	108.1	108.3	108.5	108.7	108.9	109.1	109.3	109.5	109.7	109.9	110.1	110.3	110.5	110.7	110.9	111.1	111.3	111.5	111.7	111.9	112.1	112.3	112.5	112.7	112.9	113.1	113.3	113.5	113.7	113.9	114.1	114.3	114.5	114.7	114.9	115.1	115.3	115.5	115.7	115.9	116.1	116.3	116.5	116.7	116.9	117.1	117.3	117.5	117.7	117.9	118.1	118.3	118.5	118.7	118.9	119.1	119.3	119.5	119.7	119.9	120.1	120.3	120.5	120.7	120.9	121.1	121.3	121.5	121.7	121.9	122.1	122.3	122.5	122.7	122.9	123.1	123.3	123.5	123.7	123.9	124.1	124.3	124.5	124.7	124.9	125.1	125.3	125.5	125.7	125.9	126.1	126.3	126.5	126.7	126.9	127.1	127.3	127.5	127.7	127.9	128.1	128.3	128.5	128.7	128.9	129.1	129.3	129.5	129.7	129.9	130.1	130.3	130.5	130.7	130.9	131.1	131.3	131.5	131.7	131.9	132.1	132.3	132.5	132.7	132.9	133.1	133.3	133.5	133.7	133.9	134.1	134.3	134.5	134.7	134.9	135.1	135.3	135.5	135.7	135.9	136.1	136.3	136.5	136.7	136.9	137.1	137.3	137.5	137.7	137.9	138.1	138.3	138.5	138.7	138.9	139.1	139.3	139.5	139.7	139.9	140.1	140.3	140.5	140.7	140.9	141.1	141.3	141.5	141.7	141.9	142.1	142.3	142.5	142.7	142.9	143.1	143.3	143.5	143.7	143.9	144.1	144.3	144.5	144.7	144.9	145.1	145.3	145.5	145.7	145.9	146.1	146.3	146.5	146.7	146.9	147.1	147.3	147.5	147.7	147.9	148.1	148.3	148.5	148.7	148.9	149.1	149.3	149.5	149.7	149.9	150.1	150.3	150.5	150.7	150.9	151.1	151.3	151.5	151.7	151.9	152.1	152.3	152.5	152.7	152.9	153.1	153.3	153.5	153.7	153.9	154.1	154.3	154.5	154.7	154.9	155.1	155.3	155.5	155.7	155.9	156.1	156.3	156.5	156.7	156.9	157.1	157.3	157.5	157.7	157.9	158.1	158.3	158.5	158.7	158.9	159.1	159.3	159.5	159.7	159.9	160.1	160.3	160.5	160.7	160.9	161.1	161.3	161.5	161.7	161.9	162.1	162.3	162.5	162.7	162.9	163.1	163.3	163.5	163.7	163.9	164.1	164.3	164.5	164.7	164.9	165.1	165.3	165.5	165.7	165.9	166.1	166.3	166.5	166.7	166.9	167.1	167.3	167.5	167.7	167.9	168.1	168.3	168.5	168.7	168.9	169.1	169.3	169.5	169.7	169.9	170.1	170.3	170.5	170.7	170.9	171.1	171.3	171.5	171.7	171.9	172.1	172.3	172.5	172.7	172.9	173.1	173.3	173.5	173.7	173.9	174.1	174.3	174.5	174.7	174.9	175.1	175.3	175.5	175.7	175.9	176.1	176.3	176.5	176.7	176.9	177.1	177.3	177.5	177.7	177.9	178.1	178.3	178.5	178.7	178.9	179.1	179.3	179.5	179.7	179.9	180.1	180.3	180.5	180.7	180.9	181.1	181.3	181.5	181.7	181.9	182.1	182.3	182.5	182.7	182.9	183.1	183.3	183.5	183.7	183.9	184.1	184.3	184.5	184.7	184.9	185.1	185.3	185.5	185.7	185.9	186.1	186.3	186.5	186.7	186.9	187.1	187.3	187.5	187.7	187.9	188.1	188.3	188.5	188.7	188.9	189.1	189.3	189.5	189.7	189.9	190.1	190.3	190.5	190.7	190.9	191.1	191.3	191.5	191.7	191.9	192.1	192.3	192.5	192.7	192.9	193.1	193.3	193.5	193.7	193.9	194.1	194.3	194.5	194.7	194.9	195.1	195.3	195.5	195.7	195.9	196.1	196.3	196.5	196.7	196.9	197.1	197.3	197.5	197.7	197.9	198.1	198.3	198.5	198.7	198.9	199.1	199.3	199.5	199.7	199.9	200.1	200.3	200.5	200.7	200.9	201.1	201.3	201.5	201.7	201.9	202.1	202.3	202.5	202.7	202.9	203.1	203.3	203.5	203.7	203.9	204.1	204.3	204.5	204.7	204.9	205.1	205.3	205.5	205.7	205.9	206.1	206.3	206.5	206.7	206.9	207.1	207.3	207.5	207.7	207.9	208.1	208.3	208.5	208.7	208.9	209.1	209.3	209.5	209.7	209.9	210.1	210.3	210.5	210.7	210.9	211.1	211.3	211.5	211.7	211.9	212.1	212.3	212.5	212.7	212.9	213.1	213.3	213.5	213.7	213.9	214.1	214.3	214.5	214.7	214.9	215.1	215.3	215.5	215.7	215.9	216.1	216.3	216.5	216.7	216.9	217.1	217.3	217.5	217.7	217.9	218.1	218.3	218.5	218.7	218.9	219.1	219.3	219.5	219.7	219.9	220.1	220.3	220.5	220.7	220.9	221.1	221.3	221.5	221.7	221.9	222.1	222.3	222.5	222.7	222.9	223.1	223.3	223.5	223.7	223.9	224.1	224.3	224.5	224.7	224.9	225.1	225.3	225.5	225.7	225.9	226.1	226.3	226.5	226.7	226.9	227.1	227.3	227.5	227.7	227.9	228.1	228.3	228.5	228.7	228.9	229.1	229.3	229.5	229.7	229.9	230.1	230.3	230.5	230.7	230.9	231.1	231.3	231.5	231.7	231.9	232.1	232.3	232.5	232.7	232.9	233.1	233.3	233.5	233.7	233.9	234.1	234.3	234.5	234.7	234.9	235.1	235.3	235.5	235.7	235.9	236.1	236.3	236.5	236.7	236.9	237.1	237.3	237.5	237.7	237.9	238.1	238.3	238.5	238.7	238.9	239.1	239.3	239.5	239.7	239.9	240.1	240.3	240.5	240.7	240.9	241.1	241.3	241.5	241.7	241.9	242.1	242.3

Steel Usage Port (Giss)	0	0	0
-------------------------	---	---	---

[illegible]

Year - Make - Make Comments	Collage	Cents /	Cents / 5¢ /

LAW OFFICE POST		8009	178	3
COLOR OFFICE PRG		16007	289	

Sewage Discharge		40%	
Hot Water Supply	8,271	14%	
Hot Water Supply for Laundry			

	(number)	Poems	with
--	----------	-------	------

Saver Savings

	Experiments	Martin L.	Final Report
		76	75-76
	Wet Water / 83 1980077 ECU Injection		

[illegible][illegible]

Sample	Time (min)	Perms	Wt
Sample 1	1	5	54
Sample 2	2	5	54
Sample 3	3	5	54
Sample 4	4	5	54
Sample 5	5	5	54
Sample 6	6	5	54
Sample 7	7	5	54
Sample 8	8	5	54
Sample 9	9	5	54
Sample 10	10	5	54
Sample 11	11	5	54
Sample 12	12	5	54
Sample 13	13	5	54
Sample 14	14	5	54
Sample 15	15	5	54
Sample 16	16	5	54
Sample 17	17	5	54
Sample 18	18	5	54
Sample 19	19	5	54
Sample 20	20	5	54
Sample 21	21	5	54
Sample 22	22	5	54
Sample 23	23	5	54
Sample 24	24	5	54
Sample 25	25	5	54
Sample 26	26	5	54
Sample 27	27	5	54
Sample 28	28	5	54
Sample 29	29	5	54
Sample 30	30	5	54
Sample 31	31	5	54
Sample 32	32	5	54
Sample 33	33	5	54
Sample 34	34	5	54
Sample 35	35	5	54
Sample 36	36	5	54
Sample 37	37	5	54
Sample 38	38	5	54
Sample 39	39	5	54
Sample 40	40	5	54
Sample 41	41	5	54
Sample 42	42	5	54
Sample 43	43	5	54
Sample 44	44	5	54
Sample 45	45	5	54
Sample 46	46	5	54
Sample 47	47	5	54
Sample 48	48	5	54
Sample 49	49	5	54
Sample 50	50	5	54
Sample 51	51	5	54
Sample 52	52	5	54
Sample 53	53	5	54
Sample 54	54	5	54
Sample 55	55	5	54
Sample 56	56	5	54
Sample 57	57	5	54
Sample 58	58	5	54
Sample 59	59	5	54
Sample 60	60	5	54
Sample 61	61	5	54
Sample 62	62	5	54
Sample 63	63	5	54
Sample 64	64	5	54
Sample 65	65	5	54
Sample 66	66	5	54
Sample 67	67	5	54
Sample 68	68	5	54
Sample 69	69	5	54
Sample 70	70	5	54
Sample 71	71	5	54
Sample 72	72	5	54
Sample 73	73	5	54
Sample 74	74	5	54
Sample 75	75	5	54
Sample 76	76	5	54
Sample 77	77	5	54
Sample 78	78	5	54
Sample 79	79	5	54
Sample 80	80	5	54
Sample 81	81	5	54
Sample 82	82	5	54
Sample 83	83	5	54
Sample 84	84	5	54
Sample 85	85	5	54
Sample 86	86	5	54
Sample 87	87	5	54
Sample 88	88	5	54
Sample 89	89	5	54
Sample 90	90	5	54
Sample 91	91	5	54
Sample 92	92	5	54
Sample 93	93	5	54
Sample 94	94	5	54
Sample 95	95	5	54
Sample 96	96	5	54
Sample 97	97	5	54
Sample 98	98	5	54
Sample 99	99	5	54
Sample 100	100	5	54


1000

Arapahoe County Domestic Water
Arapahoe Plaza East

				Water Rate		Sewer Rate		0		0	
				Summer rate	\$2.57000	\$3.00000	\$0.00000	\$0.00000	\$0.00000	\$0.00000	\$0.00000
				Winter rate	\$2.14000	\$2.14000	\$0.00000	\$0.00000	\$0.00000	\$0.00000	\$0.00000
					\$0.00000	\$0.00000	\$0.00000	\$0.00000	\$0.00000	\$0.00000	\$0.00000
BILLING DATA											
Average last year	Gallons	Staff days per month	Visitors-days per month	Population days	Sanitary Water Use Model	Balance	Collons Saved	Water Dollars Saved	Sewer Dollars Saved	Total Dollars Saved	
Jan	21,466	22	22	2,657	23,535	3,931	9,474	\$0	\$0	\$0	17%
Feb	24,417	20	20	2,400	21,258	3,159	8,512	\$0	\$0	\$0	15%
Mar	28,954	22	22	2,657	23,535	5,429	9,474	\$0	\$0	\$0	23%
Apr	29,253	21	21	2,571	22,176	6,517	9,120	\$0	\$0	\$0	29%
May	62,933	22	22	2,657	23,535	49,398	9,474	\$0	\$0	\$0	167%
June	74,048	21	21	2,571	22,176	51,272	9,120	\$0	\$0	\$0	225%
Jul	75,183	22	22	2,657	23,535	52,080	9,474	\$0	\$0	\$0	219%
Aug	75,615	22	22	2,657	23,535	52,080	9,474	\$0	\$0	\$0	221%
Sep	57,104	21	21	2,571	22,176	34,328	9,120	\$0	\$0	\$0	151%
Oct	50,020	22	22	2,657	23,535	26,465	9,474	\$0	\$0	\$0	113%
Nov	28,021	21	21	2,571	22,176	5,245	9,120	\$0	\$0	\$0	23%
Dec	22,209	22	22	2,657	23,535	-1,326	9,474	\$0	\$0	\$0	-6%
	555,273	251		31,288	277,107	278,166	110,963	0	0	0	

20%

Non Sanitary Use		Non Sanitary Use-Kcal	Fee-machine	Evaporative coolers	Irrigation	Laundry	Kitchen	Total	Balance	Total Use-Model	Total-Model / Billing
Jan	3,931	4	0	0	0	0	0	0	3,931	23,535	86%
Feb	3,159	3	0	0	0	0	0	0	3,159	21,258	87%
Mar	5,429	5	0	0	0	0	0	0	5,429	23,535	81%
Apr	6,517	7	0	0	24,166	0	0	24,166	-17,649	46,942	160%
May	39,398	39	0	0	41,154	0	0	41,154	-1,756	64,669	103%
June	51,272	51	0	0	42,290	0	0	42,290	8,982	65,066	88%
Jul	51,648	52	0	0	47,508	0	0	47,508	4,140	71,043	94%
Aug	52,080	52	0	0	28,512	0	0	28,512	23,588	52,047	69%
Sep	34,528	34	0	0	21,513	0	0	21,513	12,813	44,291	78%
Oct	26,465	26	0	0	20,709	0	0	20,709	5,776	44,244	86%
Nov	5,245	5	0	0	0	0	0	0	5,245	22,716	81%
Dec	-1,326	-1	0	0	0	0	0	0	-1,326	23,535	105%
	278,166	278	0	0	225,859	0	0	225,859	52,312	302,961	412%



Arapahoe County Domestic Water
Arapahoe Plaza East

Code	Units
1	Gat
2	Kgal
3	Cf
4	CCF
5	MCF
6	2
7	
8	
9	
0	

Water Rate	Sewer Rate
\$2,570.00	\$3,000.00
Summer rate	
Winter rate	\$2,130.00
Service Charge	\$14.60 bi monthly
Storm water fee	\$207.79 annual
Franchise Fee	\$0.60 bi monthly

Read Date	Month	Knot/day	Usage	Gallons	Billing days	Water Charges	Sewer Charges	Total Metered Charges	Total Water Charges	Total Charges
7/31/2004	Jun	1	27,432 Kgal	27,432	28	\$69	\$13	\$82	\$82	\$82
8/25/2004	Jul	1	24,474 Kgal	24,474	30	\$62	\$13	\$75	\$75	\$75
9/25/2004	Aug	1	27,576 Kgal	27,576	30	\$69	\$13	\$82	\$82	\$82
10/25/2004	Sep	1	27,576 Kgal	27,576	30	\$69	\$13	\$82	\$82	\$82
11/25/2004	Oct	1	27,576 Kgal	27,576	30	\$69	\$13	\$82	\$82	\$82
12/25/2004	Nov	2	63 Kgal	62,933	34	\$167	\$13	\$180	\$180	\$180
1/30/2005	Dec	2	74 Kgal	74,048	30	\$190	\$13	\$203	\$203	\$203
2/28/2005	Jan	2	75 Kgal	75,183	31	\$193	\$13	\$206	\$206	\$206
3/30/2005	Feb	2	76 Kgal	75,615	31	\$194	\$13	\$207	\$207	\$207
4/30/2005	Mar	2	57 Kgal	57,104	28	\$147	\$13	\$160	\$160	\$160
5/28/2005	Apr	2	50 Kgal	50,020	33	\$129	\$13	\$142	\$142	\$142
6/28/2005	May	2	28 Kgal	28,228	31	\$68	\$13	\$81	\$81	\$81
7/28/2005	Jun	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
8/28/2005	Jul	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
9/28/2005	Aug	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
10/28/2005	Sep	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
11/28/2005	Oct	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
12/28/2005	Nov	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
1/28/2006	Dec	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
2/28/2006	Jan	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
3/28/2006	Feb	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
4/28/2006	Mar	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
5/28/2006	Apr	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
6/28/2006	May	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
7/28/2006	Jun	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
8/28/2006	Jul	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
9/28/2006	Aug	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
10/28/2006	Sep	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
11/28/2006	Oct	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
12/28/2006	Nov	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
1/28/2007	Dec	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
2/28/2007	Jan	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
3/28/2007	Feb	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
4/28/2007	Mar	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
5/28/2007	Apr	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
6/28/2007	May	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
7/28/2007	Jun	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
8/28/2007	Jul	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
9/28/2007	Aug	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
10/28/2007	Sep	2	27,432 Kgal	27,432	30	\$69	\$13	\$82	\$82	\$82
11/28/2007	Oct	2	27,432 Kgal	27,432	30	\$69	\$13			

27	27,466
24	24,417
29	28,964
29	29,293
63	62,933
74	74,048
75	75,183
76	75,615
57	57,104
50	50,020
28	28,021
22	22,209

Arapahoe County Domestic Water
Arapahoe Plaza Human Services

Assumptions	
Staff Population	90.00
Pop Ratio Female	60.00%
Visitor Population	500
Pop Ratio Female	0.5
Length of Stay (hrs)	0.50
Inmate Population	0
Pop Ratio Female	0.7
Length of Stay (hrs)	4.00
Staff Absentee rate	0.00%
Days/year	236
Site Type (Res Comm)	comm
Laundry Population	0

Water Temperature	
Street	54
DHW supply	130
Boiler Efficiency	100%
Laundry	
Cycle/person/day	0
Gallons/load Pre	37.5
Gallons/load Post	25

Ice Machine Calc.	
Lbs/Day	0 lbs
Lbs/Year	0 lbs
Gallons / year	0 gal
Gallons of water/100 lbs of ice	16 gal
Process waste	0 gal
Est. Storage Waste	0 gal
Number of Ice Machines	1 gal
Total Storage Waste	24 gal
Total Ice Machine Usage (Gallons)	0 gal

Energy Inputs	
DHW heating source	NG
Fuel conversion source	GG
Nat. Gas System Efficiency	100.00%

Lbs/Year	5200
Gallons / year	674
Gallons of water/100 lbs of ice	16
Process waste	832
Est. Storage Waste	8000
Number of Ice Machines	8000
Total Ice Machine Usage (Gallons)	8832

[illegible][illegible]

Time/Date	Activity	Duration	Cost
10:00 AM	Arrival at site	0.5	0.00
10:05 AM	Start work	0.5	0.00
10:10 AM	Work on the road	0.5	0.00
10:15 AM	Work on the road	0.5	0.00
10:20 AM	Work on the road	0.5	0.00
10:25 AM	Work on the road	0.5	0.00
10:30 AM	Work on the road	0.5	0.00
10:35 AM	Work on the road	0.5	0.00
10:40 AM	Work on the road	0.5	0.00
10:45 AM	Work on the road	0.5	0.00
10:50 AM	Work on the road	0.5	0.00
10:55 AM	Work on the road	0.5	0.00
11:00 AM	Work on the road	0.5	0.00
11:05 AM	Work on the road	0.5	0.00
11:10 AM	Work on the road	0.5	0.00
11:15 AM	Work on the road	0.5	0.00
11:20 AM	Work on the road	0.5	0.00
11:25 AM	Work on the road	0.5	0.00
11:30 AM	Work on the road	0.5	0.00
11:35 AM	Work on the road	0.5	0.00
11:40 AM	Work on the road	0.5	0.00
11:45 AM	Work on the road	0.5	0.00
11:50 AM	Work on the road	0.5	0.00
11:55 AM	Work on the road	0.5	0.00
12:00 PM	Work on the road	0.5	0.00
12:05 PM	Work on the road	0.5	0.00
12:10 PM	Work on the road	0.5	0.00
12:15 PM	Work on the road	0.5	0.00
12:20 PM	Work on the road	0.5	0.00
12:25 PM	Work on the road	0.5	0.00
12:30 PM	Work on the road	0.5	0.00
12:35 PM	Work on the road	0.5	0.00
12:40 PM	Work on the road	0.5	0.00
12:45 PM	Work on the road	0.5	0.00
12:50 PM	Work on the road	0.5	0.00
12:55 PM	Work on the road	0.5	0.00
1:00 PM	Work on the road	0.5	0.00
1:05 PM	Work on the road	0.5	0.00
1:10 PM	Work on the road	0.5	0.00
1:15 PM	Work on the road	0.5	0.00
1:20 PM	Work on the road	0.5	0.00
1:25 PM	Work on the road	0.5	0.00
1:30 PM	Work on the road	0.5	0.00
1:35 PM	Work on the road	0.5	0.00
1:40 PM	Work on the road	0.5	0.00
1:45 PM	Work on the road	0.5	0.00
1:50 PM	Work on the road	0.5	0.00
1:55 PM	Work on the road	0.5	0.00
2:00 PM	Work on the road	0.5	0.00
2:05 PM	Work on the road	0.5	0.00
2:10 PM	Work on the road	0.5	0.00
2:15 PM	Work on the road	0.5	0.00
2:20 PM	Work on the road	0.5	0.00
2:25 PM	Work on the road	0.5	0.00
2:30 PM	Work on the road	0.5	0.00
2:35 PM	Work on the road	0.5	0.00
2:40 PM	Work on the road	0.5	0.00
2:45 PM	Work on the road	0.5	0.00
2:50 PM	Work on the road	0.5	0.00
2:55 PM	Work on the road	0.5	0.00
3:00 PM	Work on the road	0.5	0.00
3:05 PM	Work on the road	0.5	0.00
3:10 PM	Work on the road	0.5	0.00
3:15 PM	Work on the road	0.5	0.00
3:20 PM	Work on the road	0.5	0.00
3:25 PM	Work on the road	0.5	0.00
3:30 PM	Work on the road	0.5	0.00
3:35 PM	Work on the road	0.5	0.00
3:40 PM	Work on the road	0.5	0.00
3:45 PM	Work on the road	0.5	0.00
3:50 PM	Work on the road	0.5	0.00
3:55 PM	Work on the road	0.5	0.00
4:00 PM	Work on the road	0.5	0.00
4:05 PM	Work on the road	0.5	0.00
4:10 PM	Work on the road	0.5	0.00
4:15 PM	Work on the road	0.5	0.00
4:20 PM	Work on the road	0.5	0.00
4:25 PM	Work on the road	0.5	0.00
4:30 PM	Work on the road	0.5	0.00
4:35 PM	Work on the road	0.5	0.00
4:40 PM	Work on the road	0.5	0.00
4:45 PM	Work on the road	0.5	0.00
4:50 PM	Work on the road	0.5	0.00
4:55 PM	Work on the road	0.5	0.00
5:00 PM	Work on the road	0.5	0.00

[illegible][illegible][illegible][illegible]


	Number	Percent	Mean
Energy Pay (Amount)	8	81	2.885
Energy Pay (Ratio)	0	0	0
Field	8	81	2.885
Energy Pay (Amount)	8	81	2.885
Energy Savings	0	0	0
% Savings (N/A) Worker	0.02		

Arapahoe County Domestic Water
Arapahoe Plaza Human Services

Billing Data				Water Rate		Sewer Rate		0	
Average last year				Summer rate	\$25.0000	\$3.000000	\$0.000000	\$0.000000	\$0.000000
				Winter rate	\$2.140000	\$0.000000	\$0.000000	\$0.000000	\$0.000000
					\$0.000000	\$0.000000	\$0.000000	\$0.000000	\$0.000000
Billing Data				Water Dollars Saved		Sewer Dollars Saved		Total Dollars Saved	
Average last year	Gallons	Staff days per month	Visitors days per month	Population	Sanitary Water Use Model	Balance	Gallons Saved	Water Dollars Saved	Sewer Dollars Saved
Jan	84,070	22	22	5,314	55,892	28,178	24,299	\$0	\$0
Feb	73,737	20	20	4,800	50,483	22,754	21,948	\$0	\$0
Mar	80,338	22	22	5,314	55,892	24,446	24,299	\$0	\$0
Apr	79,000	21	21	5,143	54,089	24,911	23,515	\$0	\$0
May	72,458	22	22	5,314	55,892	16,567	24,299	\$0	\$0
June	65,238	21	21	5,143	54,089	11,149	23,515	\$0	\$0
Jul	67,931	22	22	5,314	55,892	12,039	24,299	\$0	\$0
Aug	68,305	22	22	5,314	55,892	12,413	24,299	\$0	\$0
Sept	50,508	21	21	5,143	54,089	-3,581	23,515	\$0	\$0
Oct	44,136	22	22	5,314	55,892	-11,756	24,299	\$0	\$0
Nov	89,682	21	21	5,143	54,089	35,593	23,515	\$0	\$0
Dec	92,075	22	22	5,314	55,892	36,183	24,299	\$0	\$0
	656,979	261		62,571	638,086	208,893	286,103	\$0	\$0

33%

Non Sanitary Use		Non Sanitary Use Kgal		Evaporative coolers		Irrigation		Laundry		Kitchen		Total		Total Use Model		Total Model / billing	
Jan	28,178	28	0	0	0	0	0	0	0	0	0	28	28,150	55,920	33%		
Feb	22,754	23	0	0	0	0	0	0	0	0	0	23	22,731	50,506	31%		
Mar	24,446	24	0	0	0	0	0	0	0	0	0	24	24,421	55,917	30%		
Apr	24,911	25	0	0	0	0	0	0	0	0	0	25	24,886	54,114	32%		
May	16,567	17	0	0	0	0	0	0	0	0	0	17	16,550	53,909	23%		
June	11,149	11	0	0	0	0	0	0	0	0	0	11	11,138	54,100	17%		
Jul	12,039	12	0	0	0	0	0	0	0	0	0	12	12,027	55,904	18%		
Aug	12,413	12	0	0	0	0	0	0	0	0	0	12	12,400	55,905	18%		
Sep	-3,581	-4	0	0	0	0	0	0	0	0	0	-4	-3,578	54,086	-7%		
Oct	-11,756	-12	0	0	0	0	0	0	0	0	0	-12	-11,744	53,880	-27%		
Nov	35,593	36	0	0	0	0	0	0	0	0	0	36	35,557	54,125	40%		
Dec	36,183	36	0	0	0	0	0	0	0	0	0	36	36,147	55,928	39%		
	208,893	209	0	0	0	0	0	0	0	0	0	209	208,884	658,295	-32%		



**Arapahoe County Domestic Water
Arapahoe Plaza Human Services**

Code	Units
1	Gal
2	Kgal
3	CF
4	CCF
5	MCF
6	enter unit code

Summer rate
Water rate
\$2,570.00
\$2,180.00

Service Charge
Storm water fee
Fireline Charge
\$32.19 bimonthly
\$207.79
\$15.03 bimonthly

Water Rate
Sewer Rate
per Kgal
per Kgal
per Kgal

Read Date	Month	Kgal/day	Usage	Gallons	Billing days	Water Charges	Sewer Charges	Total Metered Charges	Total Water Charges	Total Charges	\$/gal Water charge	\$/gal Sewer charge	\$/gallon Total
1/31/2004	Jan	84	84	84,070	31	\$1,888.00	\$188.00	\$2,076.00	\$1,888.00	\$3,964.00	\$0.0026	\$0.0028	\$0.0054
2/28/2004	Feb	73	73	73,237	28	\$1,352.00	\$135.20	\$1,487.20	\$1,352.00	\$2,839.20	\$0.0026	\$0.0031	\$0.0057
3/31/2004	Mar	80	80	80,338	31	\$1,776.00	\$177.60	\$1,953.60	\$1,776.00	\$3,729.60	\$0.0026	\$0.0030	\$0.0056
4/30/2004	Apr	79	79	79,000	30	\$1,440.00	\$144.00	\$1,584.00	\$1,440.00	\$2,999.00	\$0.0026	\$0.0030	\$0.0056
5/27/2004	May	72	72	72,459	31	\$1,566.00	\$156.60	\$1,722.60	\$1,566.00	\$3,288.60	\$0.0026	\$0.0030	\$0.0056
6/30/2004	Jun	65	65	65,238	30	\$1,168.00	\$116.80	\$1,284.80	\$1,168.00	\$2,452.80	\$0.0026	\$0.0030	\$0.0056
7/30/2004	Jul	68	68	67,931	31	\$1,752.00	\$175.20	\$1,927.20	\$1,752.00	\$3,679.20	\$0.0026	\$0.0030	\$0.0056
8/30/2004	Aug	68	68	68,305	31	\$1,764.00	\$176.40	\$1,940.40	\$1,764.00	\$3,704.40	\$0.0026	\$0.0030	\$0.0056
9/30/2004	Sep	51	51	50,508	28	\$1,307.00	\$130.70	\$1,437.70	\$1,307.00	\$2,744.70	\$0.0026	\$0.0030	\$0.0056
10/28/2004	Oct	44	44	44,136	31	\$1,113.00	\$111.30	\$1,224.30	\$1,113.00	\$2,337.30	\$0.0026	\$0.0030	\$0.0056
11/30/2004	Nov	44	44	44,075	30	\$1,092.00	\$109.20	\$1,201.20	\$1,092.00	\$2,290.40	\$0.0026	\$0.0030	\$0.0056
12/31/2004	Dec	92	92	92,075	31	\$1,992.00	\$199.20	\$2,191.20	\$1,992.00	\$4,183.20	\$0.0026	\$0.0030	\$0.0056
1/30/2005	Jan				31	\$1,992.00	\$199.20	\$2,191.20	\$1,992.00	\$4,174.40	\$0.0026	\$0.0030	\$0.0056

\$2,014

\$4,791

84,070
73,237
80,338
79,000
72,459
65,238
67,931
68,305
50,508
44,136
89,682
92,075

84
73
80
79
72
65
68
68
51
44
90
92

Arapahoe County Domestic Water
Arapahoe Plaza West Building (County Court)

Assumptions	
Staff Population	30.00
Pop Ratio Female	60.00%
Visitor Population	500
Pop Ratio Female	0.5
Length of Stay (hrs)	2.50
Inmate Population	0
Pop Ratio Female	0.7
Length of Stay (hrs)	4.00
Staff Absentee rate	0.00%
Days/year	236
Site type (Res Comm)	comm
Laundry Population	0

Water Temperature	
Street	54
DHW supply	130
Boiler Efficiency	100%
Laundry	
Cycle/person/day	0
Gallons/load Pre	37.5
Gallons/load Post	25

Ice Machine Calc.	
Lbs/ Day	0 lbs
Lbs/Year	0 lbs
Gallons / year	0 gal
Gallons of water/100 lbs of ice	16 gal
Process waste	0 gal
Est. Storage Waste	0 gal
Number of Ice Machines	1 gal
Total Storage Waste	24 gal
Total Ice Machine Usage (Gallons)	0 gal

Energy Inputs	
DHW heating source	NG
Fuel conversion source	GG
Nat. Gas System Efficiency	100.00%

Lbs/Year	5200
Gallons / year	624
Gallons of water/100 lbs of ice	16
Process waste	832
Est. Storage Waste	8000
Number of Ice Machines	1
8000	8000
Total Ice Machine Usage (Gallons)	8832

අනුමතය

[illegible]

6.37%

[illegible][illegible]

	Male	Female	Male	Female	Male	Female	Units
Cash	0	0	0	0	0	0	4
Debt	0	0	0	0	0	0	0
Equity	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0

[illegible]

Bershiar/ies	Admin 1	Investor Finance
Total Uptake / \$	47	25-36
Uptake / \$ less investment		

[illegible]


	(Munshiy)	Thames	kwh
Energy Pric (Munshiy)	3	27	395
Energy Pric (Munshiy)	0	0	0
Energy Pric (Munshiy)	3	27	395
Energy Pric (Munshiy)	3	27	395
Energy Savings	0	0	0
Energy Pric (Munshiy)	0.00	0	0

Arapahoe County Domestic Water
Arapahoe Plaza West Building (County Court)

					Water Rate		Sewer Rate		0	
					Summer rate	\$7.57000	\$3.00000	\$0.00000	\$0.00000	\$0.00000
					Winter rate	\$2.14000	\$0.00000	\$0.00000	\$0.00000	\$0.00000
					average	\$2.35500	\$0.00000	\$0.00000	\$0.00000	\$0.00000
BILLING DATA					Water Dollars Saved		Sewer Dollars Saved		Total Dollars Saved	
Average last year	Gallons	Staff days per month	Visitors days per month	Population days	Sanitary Water Use Model	Balance	Gallons Saved	Water Dollars Saved	Sewer Dollars Saved	Total Dollars Saved
Jan	88,900	22	22	3,986	52,325	36,575	28,765	\$67,742	\$0	\$67,742
Feb	101,914	20	20	3,600	47,261	54,653	25,982	\$61,187	\$0	\$61,187
Mar	94,652	22	22	3,986	52,325	42,327	28,765	\$67,742	\$0	\$67,742
Apr	79,483	21	21	3,857	50,637	28,846	27,837	\$65,557	\$0	\$65,557
May	96,604	22	22	3,986	52,325	44,479	28,765	\$67,742	\$0	\$67,742
June	94,524	21	21	3,857	50,637	43,887	27,837	\$65,557	\$0	\$65,557
Jul	67,931	22	22	3,986	52,325	15,606	28,765	\$67,742	\$0	\$67,742
Aug	69,619	22	22	3,986	52,325	17,294	28,765	\$67,742	\$0	\$67,742
Sep	66,839	21	21	3,857	50,637	16,202	27,837	\$65,557	\$0	\$65,557
Oct	68,736	22	22	3,986	52,325	16,411	28,765	\$67,742	\$0	\$67,742
Nov	75,455	21	21	3,857	50,637	24,818	27,837	\$65,557	\$0	\$65,557
Dec	77,038	22	22	3,986	52,325	24,713	28,765	\$67,742	\$0	\$67,742
	981,893	261		46,923	616,083	365,812	338,689	\$797,612	\$0	\$797,612

34%

Non Sanitary Use		Non Sanitary Use Kgal	Ice machine	Evaporative coolers	Irrigation	Laundry	Kitchen	Total	Balance	Total Use Model	Total Model / billing
Jan	36,575	37	0	0	0	0	0	0	36,575	52,325	41%
Feb	54,653	55	0	0	0	0	0	0	54,653	47,261	54%
Mar	42,327	42	0	0	0	0	0	0	42,327	52,325	45%
Apr	28,846	29	0	0	0	0	0	0	28,846	50,637	36%
May	44,479	44	0	0	0	0	0	0	44,479	52,325	46%
June	43,887	44	0	0	0	0	0	0	43,887	50,637	46%
Jul	15,606	16	0	0	0	0	0	0	15,606	52,325	23%
Aug	17,294	17	0	0	0	0	0	0	17,294	52,325	25%
Sep	16,202	16	0	0	0	0	0	0	16,202	50,637	24%
Oct	16,411	16	0	0	0	0	0	0	16,411	52,325	24%
Nov	24,818	25	0	0	0	0	0	0	24,818	50,637	33%
Dec	24,713	25	0	0	0	0	0	0	24,713	52,325	32%
	365,812	365	0	0	0	0	0	0	365	616,083	37%



Arapahoe County Domestic Water
Arapahoe Plaza West Building (Co

Code	Units
1	Gal
2	Kgal
3	CF
4	CCF
5	MCF
6	2 <<< enter unit code

Summer rate	\$2,570.00	Sewer Rate	\$3,000.00
Winter rate	\$2,140.00		
Service Charge	\$2,350.00		
Storm water fee	\$14.60 bimonthly		
FireLine Charge	\$207.79 annual		
	\$0.00 bimonthly		

Kgal
Kgal
Kgal

per
per
per

Read Date	Month	Kgal/Gal	Usorn	Gallons	Billing Days	Water Charges	Sewer Charges	Total Metered Charges	Total Water Charges	Total Charges
7/23/2004	Jul	4	69	88,900	25	\$206	\$190	\$396	\$713	\$213
8/23/2004	Aug	3	102	107,914	30	\$206	\$173	\$379	\$713	\$213
9/23/2004	Sep	3	95	94,552	30	\$206	\$173	\$379	\$713	\$213
10/23/2004	Oct	3	97	96,804	34	\$206	\$190	\$396	\$713	\$213
11/23/2004	Nov	3	95	94,552	30	\$206	\$173	\$379	\$713	\$213
12/23/2004	Dec	2	68	67,931	31	\$206	\$173	\$379	\$713	\$213
1/23/2005	Jan	2	70	69,619	31	\$206	\$173	\$379	\$713	\$213
2/23/2005	Feb	2	67	66,839	28	\$206	\$173	\$379	\$713	\$213
3/23/2005	Mar	2	69	68,116	33	\$206	\$173	\$379	\$713	\$213
4/23/2005	Apr	2	72	75,455	31	\$206	\$173	\$379	\$713	\$213
5/23/2005	May	3	77	77,038	31	\$206	\$173	\$379	\$713	\$213
6/23/2005	Jun				30	\$206	\$173	\$379	\$713	\$213
7/23/2005	Jul				30	\$206	\$173	\$379	\$713	\$213

88,900
101,914
94,552
79,483
96,804
94,524
67,931
69,619
66,839
68,736
75,455
77,038

89
102
95
79
97
95
68
70
67
69
75
77

88,900
101,914
94,552
79,483
96,804
94,524
67,931
69,619
66,839
68,736
75,455
77,038

89
102
95
79
97
95
68
70
67
69
75
77

Arapahoe County Domestic Water
Federal Warehouse

Assumptions	
Staff Population	13.00
Pop Ratio Female	0.00%
Visitor Population	15
Pop Ratio Female	0.5
Length of Stay (hrs)	2.40
Inmate Population	0
Pop Ratio Female	0.7
Length of Stay (hrs)	4.00
Staff Absentee rate	0.00%
Days/year	236
Site Type (Res Comm)	comm
Laundry Population	0

Water Temperature	
Street	54
DHW supply	130
Boiler Efficiency	100%
Laundry	
Cycle/person/day	0
Gallons/load Pre	37.5
Gallons/load Post	25

Energy Inputs		Billing units	\$/unit
DHW heating source	NG	therm	\$0.8900
Fuel conversion source	CG	kWh	\$0.1000
Not. Gas System Efficiency		100.00%	

Ice Machine Calc.	
Lbs/Day	0 lbs
Lbs/Year	0 lbs
Gallons / year	0 gal
Gallons of water/100 lbs of ice	16 gal
Process waste	0 gal
Est. Storage Waste	0 gal
Number of Ice Machines	1 gal
Total Storage Waste	24 gal
Total Ice Machine Usage (Gallons)	0 gal

Lbs/Year	5200
Gallons / year	624
Gallons of water/100 lbs of ice	16
Process waste	832
Est. Storage Waste	8000
Number of Ice Machines	1
	8000
Total Ice Machine Usage (Gallons)	8832

15,700

FLASURE DIVERSITY		1970		1971	
	COF	COAST	Average	Applied	
East	14	15	2.08		
West	13	0			
Central	13	0			
South	13	0			
North	13	0			
West	2	1.00	1.50		
East	2	1			

2075

[illegible][illegible][illegible][illegible]

Benjamin's	Admin	Physical Science
Total Weight / 35	N	25-35
Weight / 35 less friction		


	Gels / 1000 ml/hr	Gels / SE / Year	Gels / person / day
Colony			
1	0	0	0
2	0	0	0
3	0	0	0
4	0	0	0
5	0	0	0
6	0	0	0
7	0	0	0
8	0	0	0
9	0	0	0
10	0	0	0
11	0	0	0
12	0	0	0
13	0	0	0
14	0	0	0
15	0	0	0
16	0	0	0
17	0	0	0
18	0	0	0
19	0	0	0
20	0	0	0
21	0	0	0
22	0	0	0
23	0	0	0
24	0	0	0
25	0	0	0
26	0	0	0
27	0	0	0
28	0	0	0
29	0	0	0
30	0	0	0
31	0	0	0
32	0	0	0
33	0	0	0
34	0	0	0
35	0	0	0
36	0	0	0
37	0	0	0
38	0	0	0
39	0	0	0
40	0	0	0
41	0	0	0
42	0	0	0
43	0	0	0
44	0	0	0
45	0	0	0
46	0	0	0
47	0	0	0
48	0	0	0
49	0	0	0
50	0	0	0
51	0	0	0
52	0	0	0
53	0	0	0
54	0	0	0
55	0	0	0
56	0	0	0
57	0	0	0
58	0	0	0
59	0	0	0
60	0	0	0
61	0	0	0
62	0	0	0
63	0	0	0
64	0	0	0
65	0	0	0
66	0	0	0
67	0	0	0
68	0	0	0
69	0	0	0
70	0	0	0
71	0	0	0
72	0	0	0
73	0	0	0
74	0	0	0
75	0	0	0
76	0	0	0
77	0	0	0
78	0	0	0
79	0	0	0
80	0	0	0
81	0	0	0
82	0	0	0
83	0	0	0
84	0	0	0
85	0	0	0
86	0	0	0
87	0	0	0
88	0	0	0
89	0	0	0
90	0	0	0
91	0	0	0
92	0	0	0
93	0	0	0
94	0	0	0
95	0	0	0
96	0	0	0
97	0	0	0
98	0	0	0
99	0	0	0
100	0	0	0

	(Umbo)	Thorns	(Wh)
Scarp Pre (Umbo)		1	15
Scarp	0		4.11
Wall	0	1	0
Scarp Post (Umbo)		1	15
Scarp Stress	1	12	4.3
Scarp Stress	0	3	3.6
Scarp Post Wall	20.02		

Arapahoe County Domestic Water
Federal Warehouse

					Water Rate		Sewer Rate			
					Summer rate	\$2.57000	\$3.00000		0	0
					Winter rate	\$2.14000	\$0.00000	\$0.00000	\$0.00000	\$0.00000
						\$0.00000	\$0.00000	\$0.00000	\$0.00000	\$0.00000
BILLING DATA					Water Dollars		Sewer Dollars		Total Dollars	
Average last	Staff days	Visitors days	Population	Sanitary Water	Balance	Gallons Saved	Balance	Gallons Saved	Balance	Gallons Saved
year - Gallons	per month	per month	days	Use Model						
3,993	22	22	399	2,823	1,170	762	876	762	876	762
3,375	20	20	360	2,549	876	762	762	762	762	762
27,075	22	22	399	2,823	24,252	762	24,252	762	24,252	762
42,293	21	21	386	2,731	39,522	762	39,522	762	39,522	762
90,865	22	22	399	2,823	88,042	762	88,042	762	88,042	762
101,429	21	21	386	2,731	98,698	762	98,698	762	98,698	762
105,545	22	22	399	2,823	102,722	762	102,722	762	102,722	762
104,617	22	22	399	2,823	101,794	762	101,794	762	101,794	762
67,602	21	21	386	2,731	64,871	762	64,871	762	64,871	762
50,570	22	22	399	2,823	47,747	762	47,747	762	47,747	762
14,536	21	21	386	2,731	11,805	762	11,805	762	11,805	762
3,702	22	22	399	2,823	879	762	879	762	879	762
615,552	261	261	4,693	33,233	582,329	9,149	582,329	9,149	582,329	9,149

Non Sanitary Use		Non Sanitary Use Kgal	Ice machine	Evaporative coolers	Irrigation	Laundry	Kitchen	Total	Balance	Total Model
Jan	1,170	1	0	0	0	0	0	1	1,169	2,824
Feb	826	1	0	0	0	0	0	1	825	2,550
Mar	24,252	24	0	0	0	0	0	24	24,228	2,847
Apr	39,522	40	0	0	61,391	0	0	61,430	-21,909	64,162
May	88,042	88	0	0	104,549	0	0	104,537	-16,594	107,459
June	98,698	98	0	0	107,434	0	0	107,533	-8,835	110,264
July	102,722	103	0	0	120,691	0	0	120,794	-18,071	123,616
Aug	101,794	102	0	0	72,431	0	0	72,533	29,261	75,356
Sept	64,871	65	0	0	54,658	0	0	54,723	10,148	57,454
Oct	47,747	48	0	0	52,609	0	0	52,657	-4,909	55,479
Nov	11,805	12	0	0	0	0	0	12	11,793	2,743
Dec	879	1	0	0	0	0	0	1	879	2,823
	582,329	582	0	0	573,762	0	0	574,343	7,964	607,576



**Arapahoe County Domestic Water
Federal Warehouse**

Code	Units
1	Gal
2	Kgal
3	Cf
4	Ccf
5	Mcf
2	<<< enter unit code

Summer rate
Water rate: \$2.57000
Sewer Rate \$1.00000
per per
Kgal Kgal
\$2.14000
\$32.19 bimonthly
\$812.62 annual
\$26.30 bimonthly
Service Charge
Storm water fee
Fireline Charge

Read Date	Mont h	Kgal/day	Usage	Colons	Billing days	Water Charges	Sewer Charges	Total Metered Charges	Total Water Charges	Total Charges	\$/gal Water charge	\$/gal Sewer charge	\$/gallon Total
10/31/2004	Oct	3	91	90.365	34	\$2.44	\$1.15	\$3.59	\$3.59	\$3.59	\$0.0026	\$0.0031	\$0.0057
11/30/2004	Nov	3	101	101.428	30	\$2.61	\$1.15	\$3.76	\$3.76	\$3.76	\$0.0026	\$0.0031	\$0.0057
12/31/2004	Dec	3	108	105.545	31	\$2.71	\$1.15	\$3.86	\$3.86	\$3.86	\$0.0026	\$0.0031	\$0.0057
1/31/2005	Jan	3	105	104.617	31	\$2.69	\$1.15	\$3.84	\$3.84	\$3.84	\$0.0026	\$0.0031	\$0.0057
2/28/2005	Feb	2	68	67.602	28	\$1.74	\$1.15	\$2.89	\$2.71	\$2.71	\$0.0026	\$0.0027	\$0.0053
3/31/2005	Mar	2	51	50.570	33	\$1.40	\$1.15	\$2.55	\$2.71	\$2.71	\$0.0026	\$0.0027	\$0.0053
4/30/2005	Apr	0	15	14.536	31	\$0.51	\$1.15	\$1.66	\$1.66	\$1.66	\$0.0026	\$0.0027	\$0.0053
5/31/2005	May	0	24	23.69	30	\$0.78	\$1.15	\$1.93	\$1.93	\$1.93	\$0.0026	\$0.0027	\$0.0053
17/30/2005	Jun					\$1.541	\$1.15	\$2.69	\$2.69	\$2.69	\$0.0026	\$0.0027	\$0.0053
									\$2.705				

3,993	4
3,375	3
27,075	27
42,253	42
90,865	91
101,429	101
105,545	106
104,617	105
67,602	68
50,570	51
14,536	15
3,702	4

Arapahoe County Domestic Water
Altura Plaza

Assumptions	
Staff Population	145.00
Pop Ratio Female	60.00%
Visitor Population	1600
Pop Ratio Female	0.5
Length of Stay (hrs)	2.50
Inmate Population	0
Pop Ratio Female	0.7
Length of Stay (hrs)	4.00
Staff Absentee rate	0.00%
Days/year	236
Site Type (Res Comm)	comm
Laundry Population	0

Water Temperature	
Street	54
DHW supply	130
Boiler Efficiency	100%
Laundry	
Cycle/person/day	0
Gallons/load Pre	37.5
Gallons/load Post	25

Ice Machine Calc.	
Lbs/Day	0 lbs
Lbs/Year	0 lbs
Gallons / year	0 qal
Gallons of water/100 lbs of ice	16 qal
Process waste	0 qal
Est. Storage Waste	0 qal
Number of Ice Machines	1 qal
Total Storage Waste	24 qal
Total Ice Machine Usage (Gallons)	0 qal

Energy Inputs	
DHW heating source	NG
Fuel conversion source	GG
Nat. Gas System Efficiency	100.00%

Lbs/Year	5200
Gallons / year	624
Gallons of water/100 lbs of ice	16
Process waste	832
Est. Storage Waste	8000
Number of Ice Machines	1
	8000
Total Ice Machine Usage (Gallons)	8832

Altura Plaza

Year	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067	2068	2069	2070	2071	2072	2073	2074	2075	2076	2077	2078	2079	2080	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093	2094	2095	2096	2097	2098	2099	2100																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																			
Population (millions)	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0	3.1	3.2	3.3	3.4	3.5	3.6	3.7	3.8	3.9	4.0	4.1	4.2	4.3	4.4	4.5	4.6	4.7	4.8	4.9	5.0	5.1	5.2	5.3	5.4	5.5	5.6	5.7	5.8	5.9	6.0	6.1	6.2	6.3	6.4	6.5	6.6	6.7	6.8	6.9	7.0	7.1	7.2	7.3	7.4	7.5	7.6	7.7	7.8	7.9	8.0	8.1	8.2	8.3	8.4	8.5	8.6	8.7	8.8	8.9	9.0	9.1	9.2	9.3	9.4	9.5	9.6	9.7	9.8	9.9	10.0	10.1	10.2	10.3	10.4	10.5	10.6	10.7	10.8	10.9	11.0	11.1	11.2	11.3	11.4	11.5	11.6	11.7	11.8	11.9	12.0	12.1	12.2	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2	16.3	16.4	16.5	16.6	16.7	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.8	17.9	18.0	18.1	18.2	18.3	18.4	18.5	18.6	18.7	18.8	18.9	19.0	19.1	19.2	19.3	19.4	19.5	19.6	19.7	19.8	19.9	20.0	20.1	20.2	20.3	20.4	20.5	20.6	20.7	20.8	20.9	21.0	21.1	21.2	21.3	21.4	21.5	21.6	21.7	21.8	21.9	22.0	22.1	22.2	22.3	22.4	22.5	22.6	22.7	22.8	22.9	23.0	23.1	23.2	23.3	23.4	23.5	23.6	23.7	23.8	23.9	24.0	24.1	24.2	24.3	24.4	24.5	24.6	24.7	24.8	24.9	25.0	25.1	25.2	25.3	25.4	25.5	25.6	25.7	25.8	25.9	26.0	26.1	26.2	26.3	26.4	26.5	26.6	26.7	26.8	26.9	27.0	27.1	27.2	27.3	27.4	27.5	27.6	27.7	27.8	27.9	28.0	28.1	28.2	28.3	28.4	28.5	28.6	28.7	28.8	28.9	29.0	29.1	29.2	29.3	29.4	29.5	29.6	29.7	29.8	29.9	30.0	30.1	30.2	30.3	30.4	30.5	30.6	30.7	30.8	30.9	31.0	31.1	31.2	31.3	31.4	31.5	31.6	31.7	31.8	31.9	32.0	32.1	32.2	32.3	32.4	32.5	32.6	32.7	32.8	32.9	33.0	33.1	33.2	33.3	33.4	33.5	33.6	33.7	33.8	33.9	34.0	34.1	34.2	34.3	34.4	34.5	34.6	34.7	34.8	34.9	35.0	35.1	35.2	35.3	35.4	35.5	35.6	35.7	35.8	35.9	36.0	36.1	36.2	36.3	36.4	36.5	36.6	36.7	36.8	36.9	37.0	37.1	37.2	37.3	37.4	37.5	37.6	37.7	37.8	37.9	38.0	38.1	38.2	38.3	38.4	38.5	38.6	38.7	38.8	38.9	39.0	39.1	39.2	39.3	39.4	39.5	39.6	39.7	39.8	39.9	40.0	40.1	40.2	40.3	40.4	40.5	40.6	40.7	40.8	40.9	41.0	41.1	41.2	41.3	41.4	41.5	41.6	41.7	41.8	41.9	42.0	42.1	42.2	42.3	42.4	42.5	42.6	42.7	42.8	42.9	43.0	43.1	43.2	43.3	43.4	43.5	43.6	43.7	43.8	43.9	44.0	44.1	44.2	44.3	44.4	44.5	44.6	44.7	44.8	44.9	45.0	45.1	45.2	45.3	45.4	45.5	45.6	45.7	45.8	45.9	46.0	46.1	46.2	46.3	46.4	46.5	46.6	46.7	46.8	46.9	47.0	47.1	47.2	47.3	47.4	47.5	47.6	47.7	47.8	47.9	48.0	48.1	48.2	48.3	48.4	48.5	48.6	48.7	48.8	48.9	49.0	49.1	49.2	49.3	49.4	49.5	49.6	49.7	49.8	49.9	50.0	50.1	50.2	50.3	50.4	50.5	50.6	50.7	50.8	50.9	51.0	51.1	51.2	51.3	51.4	51.5	51.6	51.7	51.8	51.9	52.0	52.1	52.2	52.3	52.4	52.5	52.6	52.7	52.8	52.9	53.0	53.1	53.2	53.3	53.4	53.5	53.6	53.7	53.8	53.9	54.0	54.1	54.2	54.3	54.4	54.5	54.6	54.7	54.8	54.9	55.0	55.1	55.2	55.3	55.4	55.5	55.6	55.7	55.8	55.9	56.0	56.1	56.2	56.3	56.4	56.5	56.6	56.7	56.8	56.9	57.0	57.1	57.2	57.3	57.4	57.5	57.6	57.7	57.8	57.9	58.0	58.1	58.2	58.3	58.4	58.5	58.6	58.7	58.8	58.9	59.0	59.1	59.2	59.3	59.4	59.5	59.6	59.7	59.8	59.9	60.0	60.1	60.2	60.3	60.4	60.5	60.6	60.7	60.8	60.9	61.0	61.1	61.2	61.3	61.4	61.5	61.6	61.7	61.8	61.9	62.0	62.1	62.2	62.3	62.4	62.5	62.6	62.7	62.8	62.9	63.0	63.1	63.2	63.3	63.4	63.5	63.6	63.7	63.8	63.9	64.0	64.1	64.2	64.3	64.4	64.5	64.6	64.7	64.8	64.9	65.0	65.1	65.2	65.3	65.4	65.5	65.6	65.7	65.8	65.9	66.0	66.1	66.2	66.3	66.4	66.5	66.6	66.7	66.8	66.9	67.0	67.1	67.2	67.3	67.4	67.5	67.6	67.7	67.8	67.9	68.0	68.1	68.2	68.3	68.4	68.5	68.6	68.7	68.8	68.9	69.0	69.1	69.2	69.3	69.4	69.5	69.6	69.7	69.8	69.9	70.0	70.1	70.2	70.3	70.4	70.5	70.6	70.7	70.8	70.9	71.0	71.1	71.2	71.3	71.4	71.5	71.6	71.7	71.8	71.9	72.0	72.1	72.2	72.3	72.4	72.5	72.6	72.7	72.8	72.9	73.0	73.1	73.2	73.3	73.4	73.5	73.6	73.7	73.8	73.9	74.0	74.1	74.2	74.3	74.4	74.5	74.6	74.7	74.8	74.9	75.0	75.1	75.2	75.3	75.4	75.5	75.6	75.7	75.8	75.9	76.0	76.1	76.2	76.3	76.4	76.5	76.6	76.7	76.8	76.9	77.0	77.1	77.2	77.3	77.4	77.5	77.6	77.7	77.8	77.9	78.0	78.1	78.2	78.3	78.4	78.5	78.6	78.7	78.8	78.9	79.0	79.1	79.2	79.3	79.4	79.5	79.6	79.7	79.8	79.9	80.0	80.1	80.2	80.3	80.4	80.5	80.6	80.7	80.8	80.9	81.0	81.1	81.2	81.3	81.4	81.5	81.6	81.7	81.8	81.9	82.0	82.1	82.2	82.3	82.4	82.5	82.6	82.7	82.8	82.9	83.0	83.1	83.2	83.3	83.4	83.5	83.6	83.7	83.8	83.9	84.0	84.1	84.2	84.3	84.4	84.5	84.6	84.7	84.8	84.9	85.0	85.1	85.2	85.3	85.4	85.5	85.6	85.7	85.8	85.9	86.0	86.1	86.2	86.3	86.4	86.5	86.6	86.7	86.8	86.9	87.0	87.1	87.2	87.3	87.4	87.5	87.6	87.7	87.8	87.9	88.0	88.1	88.2	88.3	88.4	88.5	88.6	88.7	88.8	88.9	89.0	89.1	89.2	89.3	89.4	89.5	89.6	89.7	89.8	89.9	90.0	90.1	90.2	90.3	90.4	90.5	90.6	90.7	90.8	90.9	91.0	91.1	91.2	91.3	91.4	91.5	91.6	91.7	91.8	91.9	92.0	92.1	92.2	92.3	92.4	92.5	92.6	92.7	92.8	92.9	93.0	93.1	93.2	93.3	93.4	93.5	93.6	93.7	93.8	93.9	94.0	94.1	94.2	94.3	94.4	94.5	94.6	94.7	94.8	94.9	95.0	95.1	95.2	95.3	95.4	95.5	95.6	95.7	95.8	95.9	96.0	96.1	96.2	96.3	96.4	96.5	96.6	96.7	96.8	96.9	97.0	97.1	97.2	97.3	97.4	97.5	97.6	97.7	97.8	97.9	98.0	98.1	98.2	98.3	98.4	98.5	98.6	98.7	98.8	98.9	99.0	99.1	99.2	99.3	99.4	99.5	99.6	99.7	99.8	99.9	100.0
Population (millions)	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0	3.1	3.2	3.3	3.4	3.5	3.6	3.7	3.8	3.9	4.0	4.1	4.2	4.3	4.4	4.5	4.6	4.7	4.8	4.9	5.0	5.1	5.2	5.3	5.4	5.5	5.6	5.7	5.8	5.9	6.0	6.1	6.2	6.3	6.4	6.5	6.6	6.7	6.8	6.9	7.0	7.1	7.2	7.3	7.4	7.5	7.6	7.7	7.8	7.9	8.0	8.1	8.2	8.3	8.4	8.5	8.6	8.7	8.8	8.9	9.0	9.1	9.2	9.3	9.4	9.5	9.6	9.7	9.8	9.9	10.0	10.1	10.2	10.3	10.4	10.5	10.6	10.7	10.8	10.9	11.0	11.1	11.2	11.3	11.4	11.5	11.6	11.7	11.8	11.9	12.0	12.1	12.2	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2	16.3	16.4	16.5	16.6	16.7	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.8	17.9	18.0	18.1	18.2	18.3	18.4	18.5	18.6	18.7	18.8	18.9	19.0	19.1	19.2	19.3	19.4	19.5	19.6	19.7	19.8	19.9	20.0	20.1	20.2	20.3	20.4	20.5	20.6	20.7	20.8	20.9	21.0	21.1	21.2	21.3	21.4	21.5	21.6	21.7	21.8	21.9	22.0	22.1	22.2	22.3	22.4	22.5	22.6	22.7	22.8	22.9	23.0	23.1	23.2	23.3	23.4	23.5	23.6	23.7	23.8	23.9	24.0	24.1	24.2	24.3	24.4	24.5	24.6	24.7	24.8	24.9	25.0	25.1	25.2	25.3	25.4	25.5	25.6	25.7	25.8	25.9	26.0	26.1	26.2	26.3	26.4	26.5	26.6	26.7	26.8	26.9	27.0	27.1	27.2	27.3	27.4	27.5	27.6	27.7	27.8	27.9	28.0	28.1	28.2	28.3	28.4	28.5	28.6	28.7	28.8	28.9	29.0	29.1	29.2	29.3	29.4	29.5	29.6	29.7	29.8	29.9	30.0	30.1	30.2	30.3	30.4	30.5	30.6	30.7	30																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																				

Bin Temos

[illegible]


Balance sheet

http://cawweather.com/ccd/armcdd.htm

Month	CO ₂	% of CO ₂ in Health	Gases/month
Jan	100	0	0
Feb	100	0	0
Mar	100	0	0
Apr	100	0	0
May	100	0	0
Jun	100	0	0
Jul	100	0	0
Aug	100	0	0
Sep	100	0	0
Oct	100	0	0
Nov	100	0	0
Dec	100	0	0
Total	1000	0	0


Weight of air lb/cf 0.075

Length	DEMER Wet BBS	DEMER RH	DEMER Mean Dry Wet	DEMER High Temp Dry BBS	Wetqsn, High and mean	Psychiatric Start Hardly Ride (fracture 1/2 of an or	gears / month
300	21	49	16.4	43.3	41.8		
350	27	41	15.4	37.3	41.8		
400	31	40	15.1	33.7	48.9		
450	31	40	15.3	50.3	55.2		
500	46	38	16.0	70.5	65.9		
550	54	34	15.2	72.1	74.7	0.007000	54.852
600	41	34	16.2	58.0	83.1	0.005000	37.785
650	31	35	14.8	55.0	80.4	0.005000	57.278
700	46	34	16.3	77.4	56.1	0.001000	21.926
750	41	48	17.0	53.5	48.3		
800	25	52	15.2	44.1	39.7		
850	40	40	16.3	64.2	59.0		



BILLING DATA		Staff: days per month	Visitors: days per month	Population days	Sanitary Water Use: Mgal.	Balance	Water		Sewer		Water Differential	Sewer Differential
Average last: year	Gallons						Gallons Saved	Dollars Saved	Dollars Saved	Dollars		
Jan	231,312	22	22	13,839	122,977	108,335	41,026	\$0	\$0	\$0	88%	
Feb	188,690	20	20	12,500	111,076	77,614	37,055	\$0	\$0	\$0	70%	
Mar	157,555	22	22	13,839	122,977	54,768	41,026	\$0	\$0	\$0	28%	
Apr	247,231	21	21	13,393	119,010	128,221	39,702	\$0	\$0	\$0	108%	
May	327,300	22	22	13,839	122,977	199,323	41,026	\$0	\$0	\$0	162%	
June	347,233	21	21	13,393	119,010	228,223	39,702	\$0	\$0	\$0	192%	
July	387,367	22	22	13,839	122,977	264,390	41,026	\$0	\$0	\$0	215%	
Aug	459,150	22	22	13,839	122,977	316,173	39,702	\$0	\$0	\$0	215%	
Sept	414,267	21	21	13,393	119,010	295,252	39,702	\$0	\$0	\$0	248%	
Oct	361,663	22	22	13,839	122,977	239,066	41,026	\$0	\$0	\$0	194%	
Nov	318,155	21	21	13,393	119,010	199,145	39,702	\$0	\$0	\$0	167%	
Dec	196,791	22	22	13,839	122,977	73,814	41,026	\$0	\$0	\$0	60%	
	3,631,734	261		162,946	1,447,952	2,183,782	483,902	0	0	0	100%	

	Non Sanitary Use	Non Sanitary Kpt.	Sanitary Use	Sanitary Kpt.	Evaporative coolers	Irrigation	Laundry	Kitchen	Total	Balance	Total Model
Jan	108,355	108			0	0	0		0	108,355	122,977
Feb	37,514	36			0		0		0	37,514	111,076
Mar	34,578	35			0		0		0	34,578	122,977
Apr	178,221	128			0		0		0	178,221	165,145
May	199,323	199			776	22,342			23,068	195,135	822
June	228,273	228			8,350	27,197			35,547	163,776	194,070
July	228,273	228			49,012	46,219			95,230	132,953	309,470
Aug	264,350	264			94,756	52,192			146,948	117,442	418,673
Sept	336,173	335			78,782	41,974			120,756	215,417	354,488
Oct	295,257	295			20,694	23,240			43,934	245,333	218,878
Nov	238,706	239			0	18,236			18,236	220,470	159,449
Dec	199,145	199			0	0			199,145	119,010	1,002
Jan	74	74			0	0			74	3,814	127,977
Feb	2,183,762	2,184			252,393	231,400			483,793	694,053	2,427,390



Arapahoe County Domestic Water
Altura Plaza

Code	Units
1	Gal
2	Kgal
3	CF
4	CCF
5	MCF
6	<<< enter unit code

Flat rate	1000000	Water Rate	\$3.34000	Sewer Rate	\$1.64000
Water Service Charge	\$0.00000		\$0.00000		\$0.00000
Sewer Service Charge	\$0.00000		\$0.00000		\$0.00000
Storm water fee	\$12.13	gals			
SD COM component	\$3.83				
	\$90.90				

Water	Differential	Sewer	Differential
\$3.34000		\$1.64000	
\$3.34000		\$1.64000	

Read Date	Month	Usage	Kgal/day	Gallons	Billing days	Water Charges	Sewer Charges	Total Metered Charges	Total Charges	\$/gal Water charge	\$/gal Sewer charge	\$/gallon Total	\$/gallon Total
1/31/2004	Jan	231	9	231,312	25	\$773	\$337	\$2,220	\$2,341	\$0.0033	\$0.0015	\$0.0048	\$0.0096
2/25/2004	Feb	189	6	188,690	30	\$630	\$337	\$1,935	\$2,056	\$0.0033	\$0.0018	\$0.0051	\$0.0103
3/26/2004	Mar	158	5	157,555	35	\$526	\$337	\$1,727	\$1,848	\$0.0033	\$0.0021	\$0.0055	\$0.0110
4/30/2004	Apr	247	9	247,231	27	\$826	\$337	\$2,326	\$2,447	\$0.0033	\$0.0014	\$0.0047	\$0.0094
5/27/2004	May	322	9	322,300	34	\$1,076	\$337	\$2,827	\$2,949	\$0.0033	\$0.0010	\$0.0044	\$0.0088
6/30/2004	Jun	347	12	347,233	30	\$1,160	\$337	\$2,994	\$3,115	\$0.0033	\$0.0010	\$0.0043	\$0.0086
7/30/2004	Jul	387	12	387,367	31	\$1,294	\$337	\$3,262	\$3,383	\$0.0033	\$0.0009	\$0.0042	\$0.0084
8/30/2004	Aug	459	15	459,150	31	\$1,534	\$337	\$3,741	\$3,863	\$0.0033	\$0.0007	\$0.0041	\$0.0081
9/30/2004	Sep	414	15	414,267	28	\$1,384	\$337	\$3,442	\$3,563	\$0.0033	\$0.0008	\$0.0042	\$0.0083
10/28/2004	Oct	362	11	361,683	33	\$1,208	\$337	\$3,090	\$3,212	\$0.0033	\$0.0009	\$0.0043	\$0.0086
11/30/2004	Nov	318	10	318,155	31	\$1,063	\$337	\$2,800	\$2,921	\$0.0033	\$0.0011	\$0.0044	\$0.0088
12/31/2004	Dec	197	7	196,791	30	\$657	\$337	\$1,989	\$2,110	\$0.0033	\$0.0017	\$0.0051	\$0.0101
1/30/2005	Jan												

231	231,312
189	188,690
158	157,555
247	247,231
322	322,300
347	347,233
387	387,367
459	459,150
414	414,267
362	361,683
318	318,155
197	196,791

Arapahoe County Domestic Water
Peoria Shops

Assumptions	
Staff Population	56.00
Pop Ratio Female	30.00%
Visitor Population	0
Pop Ratio Female	0.5
Length of Stay (hrs)	2.40
Inmate Population	0
Pop Ratio Female	0.7
Length of Stay (hrs)	4.00
Staff Absentee rate	50.00%
Days/year	341
Site Type (Res Comm)	comm
Laundry Population	0

Water Temperature	
Street	54
DHW supply	130
Boiler Efficiency	100%
Laundry	
Cycle/person/day	0
Gallons/load Pre	37.5
Gallons/load Post	25

Energy Inputs		Billing units	\$/unit
DHW heating source	NC	Therm	\$0.8900
Fuel conversion source	CG	kWh	\$0.1000
Not. Gas System Efficiency			100.00%

Ice Machine Calc.	
Lbs/Day	0 lbs
Lbs/Year	0 lbs
Gallons / year	0 gal
Gallons of water/100 lbs of ice	16 gal
Process waste	0 gal
Est. Storage Waste	0 gal
Number of Ice Machines	1 gal
Total Storage Waste	24 gal
Total Ice Machine Usage (Gallons)	0 gal

Lbs/Year	5200
Gallons / year	624
Gallons of water/100 lbs of ice	16
Process waste	832
Est. Storage Waste	8000
Number of Ice Machines	1
8000	8000
Total Ice Machine Usage (Gallons)	8832

25,008

Model/82240
77

Remarks	Admin 1	Typical Range
Final Usage / SF	65	75-85
Usage / SF per situation		

[illegible]

	(Mushy)	Thorns	Rain
Sweet Pie (Mushy)	4	37	1 072
Kichen	0	0	0
Jol	4	37	1 072
Sweet Pie (Mushy)	4	37	1 072
Sweet Sausages	0	0	0
Souring Hot Water	0	0	0
	0.0%		

Arapahoe County Domestic Water
Peoria Shops
 Road Maintenance


Street sweepers are deployed when Temps are above 20 °F

Street Sweepers	250	gallons
Capacity		
Quantity	4	
Frequency	237	
Total Usage	59,365	
Patch Trucks		
Capacity	50	
Quantity	3	
Frequency	150	
Total Usage	22,500	
Painters		
Capacity	0	
Quantity	2	
Frequency	150	
Total Usage	0	
Grand Total	81,865	

Recycle factor 0.5
 Total recycle savings 640000
 Estimated cost savings 9600

Total Hours		20
average	Denver	
97	4	0
92	42	0
87	168	0
82	280	0
77	397	0
72	498	0
67	634	0
62	798	0
57	799	0
52	769	0
47	737	0
42	710	0
37	672	0
32	678	0
27	582	0
22	438	0
17	242	242
12	137	137
7	80	80
2	46	46
-3	20	20
-8	11	11
-13	3	3
-18	2	2
		541
		23

Billing Data	Average last year	Staff days per month	Visitors days per month	Population days	Sanitary Water Use Model	Balloons		Water Rate		Sewer Rate		Water Differential	Sewer Differential
						Callons	Saved	Water Dollars	Saved	Sewer Dollars	Saved		
Jan	113,372	22	22	620	9,609	103,763	4,630	\$7.17	\$0.00290	\$0.00232	\$0.00073	\$0.00048	
Feb	103,890	20	20	560	8,680	95,210	4,182	\$6.35	\$0.00263	\$0.00205	\$0.00043	\$0.00018	
Mar	173,374	22	22	620	9,609	163,765	4,830	\$7.17	\$0.00290	\$0.00232	\$0.00073	\$0.00048	
Apr	135,558	21	21	600	9,299	146,259	4,481	\$6.16	\$0.00277	\$0.00219	\$0.00045	\$0.00020	
May	132,547	22	22	620	9,609	122,318	4,630	\$6.35	\$0.00263	\$0.00205	\$0.00043	\$0.00018	
June	148,231	21	21	600	9,299	138,932	4,481	\$6.35	\$0.00263	\$0.00205	\$0.00043	\$0.00018	
July	134,590	22	22	620	9,609	124,981	4,630	\$6.35	\$0.00263	\$0.00205	\$0.00043	\$0.00018	
Aug	138,899	22	22	620	9,609	149,280	4,830	\$7.17	\$0.00290	\$0.00232	\$0.00073	\$0.00048	
Sept	128,592	21	21	600	9,299	119,203	4,481	\$6.16	\$0.00277	\$0.00219	\$0.00045	\$0.00020	
Oct	143,174	22	22	620	9,609	133,515	4,630	\$6.35	\$0.00263	\$0.00205	\$0.00043	\$0.00018	
Nov	117,060	21	21	600	9,299	107,161	4,481	\$6.16	\$0.00277	\$0.00219	\$0.00045	\$0.00020	
Dec	120,167	22	22	620	9,609	110,568	4,630	\$6.35	\$0.00263	\$0.00205	\$0.00043	\$0.00018	
1999-2004	1629,304	261	261	3000	113,144	1,516,160	54,319	\$178.11	\$176.304	\$176.304	\$176.304	\$176.304	

[illegible]

Recycle factor	0.5
total recycle savings	\$540,000
	9600

**Arapahoe County Domestic Water
Peoria Shops**

Code	Units
1	Gal
2	Kgal
3	CC
4	CC
5	NCF
2	<<< enter unit code

Water Rate Sewer Rate
 < 25,000 gal 25,000 \$0.00232
 25,001-200,000 200,000 \$0.00250
 > 200,000 200,000 \$0.00340
 Minimum Usage: 12,000 gals
 Storm water fee \$117.45
 Fireline Charge \$0.00
 Capital Fund Factor \$2.00

Water Differential Sewer Differential
 \$0.00073 \$0.00058
 \$0.00145 \$0.00116

Kgal
Kgal
Kgal

Read Date	Month	Kgal/Mtr	Usage	Gallons	Billing days	Water Charges	Sewer Charges	Total Charges	\$/gal Water charge	\$/gal Sewer charge	\$/gallon Total	\$/gallon Total
7/31/2004	Jul	5	113.372	113,372	31	\$3.17	\$0.00	\$3.17	\$0.0035	\$0.0028	\$0.0063	\$0.0063
8/31/2004	Aug	5	103.890	103,890	31	\$3.17	\$0.00	\$3.17	\$0.0041	\$0.0035	\$0.0076	\$0.0076
9/30/2004	Sep	5	173.374	173,374	30	\$3.17	\$0.00	\$3.17	\$0.0013	\$0.0010	\$0.0023	\$0.0023
10/31/2004	Oct	6	155.558	155,558	31	\$3.17	\$0.00	\$3.17	\$0.0018	\$0.0014	\$0.0032	\$0.0032
11/30/2004	Nov	4	132.547	132,547	30	\$3.17	\$0.00	\$3.17	\$0.0026	\$0.0021	\$0.0046	\$0.0046
12/31/2004	Dec	4	148.231	148,231	31	\$3.17	\$0.00	\$3.17	\$0.0020	\$0.0016	\$0.0036	\$0.0036
1/31/2005	Jan	5	158.889	158,889	31	\$3.17	\$0.00	\$3.17	\$0.0025	\$0.0020	\$0.0045	\$0.0045
2/28/2005	Feb	4	128.502	128,502	29	\$3.17	\$0.00	\$3.17	\$0.0017	\$0.0013	\$0.0030	\$0.0030
3/31/2005	Mar	4	143.124	143,124	31	\$3.17	\$0.00	\$3.17	\$0.0027	\$0.0022	\$0.0049	\$0.0049
4/30/2005	Apr	4	117.060	117,060	30	\$3.17	\$0.00	\$3.17	\$0.0035	\$0.0028	\$0.0063	\$0.0063
5/31/2005	May	4	120.167	120,167	31	\$3.17	\$0.00	\$3.17	\$0.0031	\$0.0025	\$0.0056	\$0.0056
6/30/2005	Jun	4	113.372	113,372	30	\$3.17	\$0.00	\$3.17	\$0.0031	\$0.0025	\$0.0056	\$0.0056

113.372
103.890
173.374
155.558
132.547
148.231
158.889
128.502
143.124
117.060
120.167

\$3.17
\$3.17
\$3.17
\$3.17
\$3.17
\$3.17
\$3.17
\$3.17
\$3.17
\$3.17
\$3.17
\$3.17
\$3.17

\$0.0035
\$0.0041
\$0.0013
\$0.0018
\$0.0026
\$0.0020
\$0.0025
\$0.0017
\$0.0027
\$0.0035
\$0.0031

\$0.0028
\$0.0035
\$0.0010
\$0.0014
\$0.0021
\$0.0016
\$0.0020
\$0.0013
\$0.0022
\$0.0017
\$0.0028
\$0.0025

\$0.0063
\$0.0076
\$0.0023
\$0.0032
\$0.0046
\$0.0036
\$0.0045
\$0.0030
\$0.0049
\$0.0063
\$0.0056

Arapahoe County Domestic Water
ACJC Courthouse

Assumptions	
Staff Population	109.00
Pop Ratio Female	60.00%
Visitor Population	1500
Pop Ratio Female	0.6
Length of Stay (hrs)	1.00
Inmate Population	50
Pop Ratio Female	0.7
Length of Stay (hrs)	4.00
Staff Absentee rate	0.00%
Days/year	355
Site Type (Res Comm)	comm
Laundry Population	0

Water Temperature	
Street	54
DHW supply	130
Boiler Efficiency	100%
Laundry	
Cycle/person/day	0
Gallons/load Pre	37.5
Gallons/load Post	25

Ice Machine Calc.	
Lbs/ Day	50 lbs
Lbs/Year	18250 lbs
Gallons / year	2191 qal
Gallons of water/100 lbs of ice	16 qal
Process waste	2920 qal
Est. Storage Waste	8000 qal
Number of Ice Machines	1 qal
Total Storage Waste	24 qal
Total Ice Machine Usage (Gallons)	10920 qal

Energy Inputs		Billing units	\$/unit
DHW heating source	NG	Therm	\$0.8900
Fuel conversion source	GG	kWh	\$0.1000
Nat. Gas System Efficiency			100.00%

Lbs/Year	5200
Gallons / year	624
Gallons of water/100 lbs of ice	16
Process waste	832
Est. Storage Waste	8000
Number of Ice Machines	1
	8000
Total Ice Machine Usage (Gallons)	8832

148,522

Future Economy			Weighted Average
	GDP	Quantity	Per 1000
Total	1.6	—	5
Food	—	—	24
Commodities	1.6	—	10
Services	3.5	—	1.60
Capital	—	—	9
Unpaid	2	—	1.00

[illegible]

Staff:	100	100	100
Spill:	0.4	0.4	0.4
Spill: Men	0.6	0.6	0.6
Spill: Total	1.0	1.0	1.0
Spill:	0.000	0.000	0.000

[illegible]

	Percent	Processed
Total	385	
Plasma	0	
Vaccine	0	
Off total	0	

	Male	Female
Toilet	7509	6862
Shower	6000	5000
Low Forest	5000	5000
High Forest	5000	5000
Shower (M.F.)	5000	5000

60253-40-1

	Toilet usage women	Toilet usage men
Days/year	355	355
Population:	19	7.5

Minutes	5	\$
Up per day	110.5	\$
Hours % minutes	13.11	
Percent (round for absence*)	1	
CU present	1.60	1.60
CU present	0	0
CU Proposed	0	0

GPU Usage	49,700	21,500
Total Usage Prg (Gpu)	0	0
Total Usage Prg (Cpu)	49,700	21,500
Hot Water Gallons PRE		

	Product	Unit Price	Total	Tax	Total Tax	Total Total	Cash /
	Hot Water Solenoid P801	\$196.75					
	Hot Water Energy Pro (ambus)						
	Hot Water Energy Post (ambus)						
	Hot Water Energy Services (ambus)						

Station	Water Use Summary	Gallons	Person/yr
1	Landsc Irrigat Prc	744,313	84,313
2	Landsc Irrigat Post	1,772	1,772
3	Soft Water Prc	430,998	43,098
4	Soft Water Post	26,713	2,671
5	Soft Water Prc	85,729	8,573
6	Soft Water Post	7,553	755

Transfer Water Prod	506,475	500
Total Water Prod	1,491,572	500
Water Usage	868,060	500
Transfer Water	513,511	500
2 Domestic Water	83	48
2 Domestic Water	53,652	48
2 Domestic Water	3,050	48
2 Domestic Water	3,050	48

	(Units)	Thems
Energy per (Unit)	34	36
Kilowatt	58	63
% Savings (Net)	0	20%
Saved Dollars		

	0	0	0.0%
Total Port Number	34	3684	10.7%
Energy Sources	0	0	0.0%
% Section 198 Water			
			109500

[illegible]

Participants	Admin	Target Range
Total Weight / SF	72	25-35
Weight / SF Mass Unimodal		

[illegible]

--

[illegible]

	(Umbilo)	Thema	Year
Ecce Pre (Umbilo)	34	336	9,041
Kisibon	69		20,311
Ugwi	103	1,079	30,152
Ecce Post (Umbilo)	34	336	9,041

[illegible]


Apache County Domestic Water
ACJC Courthouse

3 Rule of thumb CFM/SF
0.075 lb/cf density of air
148,000 SF of conditioned space
444,000 CFM total

<http://qweather.com/ccd/nrmcd.htm>

Month	CCD	% of CCD in this Month	Gallons/ month
Jan	0	0%	0
Feb	0	0%	0
Mar	0	0%	0
Apr	2	0%	4,572
May	23	3%	52,573
Jun	135	19%	308,617
Jul	261	38%	596,659
Aug	217	31%	496,073
Sep	57	8%	130,303
Oct	0	0%	0
Nov	0	0%	0
Dec	0	0%	0
	695		1,588,806


Month	DENVER Wet Bulb	DENVER RH	DENVER Mean Dry Bulb	DENVER High Temps Dry Bulb	Average, high and mean	Psychrometric Chart Humidity Ratio (#moisture / # of dry air	gallons / month
Jan	24	49	36.4	43.2	39.8		
Feb	27	44	36.5	47.2	41.9		
Mar	31	40	43.1	53.7	48.4		
Apr	38	35	50.9	60.9	55.9		
May	46	38	61.0	70.5	65.8		
Jun	54	35	69.2	82.1	75.7	0.002000	345,393
Jul	58	34	78.2	88.0	83.1	0.003200	552,628
Aug	57	35	74.8	86.0	80.4	0.003000	518,089
Sep	50	34	65.9	77.4	71.7	0.001000	172,596
Oct	41	36	53.2	66.0	59.6		
Nov	31	49	41.0	51.5	46.3		
Dec	25	52	35.2	44.1	39.7		
	40	40	53.8	64.2	59.0		1,588,806



Month	BILLING DATA		Sanitary Water Use Model	Kitchen related total	Non Weather related total	Baseline	Balance	Gallons Saved	New Baseline
	year	Gallons per month							
Jan	176,154	77	119,038	9,125	128,163	116,265	11,898	45,372	80,492
Feb	107,937	20	107,518	9,125	116,643	116,265	378	474	107,742
Mar	174,801	27	119,038	9,125	128,163	116,265	11,898	45,372	123,535
Apr	175,627	27	119,038	9,125	128,163	116,265	11,898	45,372	123,535
May	383,974	27	119,038	9,125	128,163	116,265	11,898	45,372	138,527
June	446,176	21	115,198	9,125	124,323	116,265	8,058	43,312	167,635
July	661,181	22	119,038	9,125	128,163	116,265	11,898	45,372	173,535
Aug	517,454	21	119,038	9,125	128,163	116,265	11,898	45,372	162,087
Sep	619,355	21	115,198	9,125	124,323	116,265	8,058	43,312	172,635
Oct	519,919	21	119,038	9,125	128,163	116,265	11,898	45,372	167,635
Nov	409,107	21	115,198	9,125	124,323	116,265	8,058	43,312	156,035
Dec	106,077	22	119,038	9,125	128,163	116,265	11,898	45,372	141,035
	4,977,027	261	1,401,571	73,000	1,474,571	1,351,922	122,649	523,649	2,000,191

Month	Sanitary Use Model		Evaporative coolers	Laundry	Total	Model Total	Balance (gal)	Model total to billing
	Non Sanitary Use	Sanitary Use Model						
Jan	7,116	0	0	0	0	128,163	-121,047	107%
Feb	474	0	0	0	0	116,643	-115,169	106%
Mar	5,653	6	0	0	0	128,163	-122,510	102%
Apr	60,424	60	4,372	0	4,372	128,163	-123,835	102%
May	264,785	265	52,579	0	52,579	180,742	-180,742	100%
June	370,938	371	308,617	0	308,617	439,540	-439,540	89%
July	548,123	549	596,659	0	596,659	724,822	-724,822	103%
Aug	418,446	418	496,075	0	496,075	624,236	-624,236	116%
Sep	564,157	564	130,305	0	130,305	754,628	-754,628	137%
Oct	419,871	420	0	0	0	128,163	-127,682	102%
Nov	293,909	294	0	0	0	124,323	-124,323	100%
Dec	113,071	113	0	0	0	128,163	-116,092	107%
	2,941,131	2,941	1,588,805	0	1,588,805	3,069,871	-3,069,871	103%

1538.605162



Apache County Domestic Water
ACJC Courthouse

Code	Units
1	Gal
2	Kgal
3	CCF
4	CCF
5	MCF
2	<<< enter unit code

< 25,000g gal 25000 \$0.00290 \$0.00232
 25,001-200,000 200000 \$0.00363 \$0.00290
 >200,000 200000 \$0.00435 \$0.00348
 144,000 gals
 Minimum Usage \$15.30
 Storm water fee \$1,142.04
 FireLineCharge \$317.50
 Capitol Fund

Water Differential \$0.00073 \$0.00058
 Sewer Differential \$0.00145 \$0.00116

Read Date	Mont h	Kgal/day	Usage	Gallons	Billing days	Water Charges	Sewer Charges	Total Charges	Total Charges	\$/gal Water charge	\$/gal Sewer charge	\$/gallon Total	\$/gallon Total
1/31/2004	Jan	5	126	Kgal	25	\$360	\$287	\$1,295		\$0.00285	0.0022776	0.0051324	0.0102849
2/25/2004	Feb	4	108	Kgal	30	\$413	\$329	\$1,485		\$0.00382	0.0030508	0.0068735	0.0137470
3/26/2004	Mar	4	125	Kgal	35	\$364	\$290	\$1,308		\$0.00291	0.0023237	0.0052363	0.0104726
4/30/2004	Apr	7	176	Kgal	27	\$217	\$173	\$779		\$0.00123	0.0009825	0.0022164	0.0044329
5/27/2004	May	11	384	Kgal	34	\$1,526	\$1,220	\$5,491		\$0.00397	0.0031778	0.0071526	0.0143052
6/30/2004	Jun	16	486	Kgal	30	\$1,971	\$1,576	\$7,094		\$0.00405	0.0032414	0.0072952	0.0145904
7/30/2004	Jul	22	667	Kgal	31	\$2,758	\$2,206	\$9,928		\$0.00413	0.0033061	0.0074403	0.0148806
8/30/2004	Aug	17	537	Kgal	31	\$2,194	\$1,754	\$7,897		\$0.00408	0.0032642	0.0073463	0.0146925
9/30/2004	Sep	24	679	Kgal	28	\$2,811	\$2,248	\$10,119		\$0.00414	0.0033092	0.0074473	0.0148946
10/28/2004	Oct	16	539	Kgal	33	\$2,200	\$1,759	\$7,919		\$0.00408	0.0032648	0.0073475	0.0146951
11/30/2004	Nov	13	409	Kgal	31	\$1,636	\$1,308	\$5,887		\$0.00400	0.0031965	0.0071945	0.0143889
12/31/2004	Dec	4	106	Kgal	30	\$419	\$334	\$1,505		\$0.00395	0.0031508	0.0070988	0.0141976
1/30/2005	Jan												

126,154
 107,992
 124,901
 175,622
 383,824
 486,176
 667,161
 537,484
 679,355
 538,909
 409,107
 106,017

Arapahoe County Domestic Water Administrative II

Assumptions	
Staff Population	250.00
Pop Ratio Female	60.00%
Visitor Population	150
Pop Ratio Female	0.5
Length of Stay (hrs)	0.50
Inmate Population	0
Pop Ratio Female	0.7
Length of Stay (hrs)	4.00
Staff Absentee rate	0.00%
Days/year	236
Site Type (Res Comm)	comm
Laundry Population	0

Water Temperature	
Street	54
DHW supply	130
Boiler Efficiency	100%
Laundry	
Cycle/person/day	0
Gallons/load Pre	37.5
Gallons/load Post	25

Ice Machine Calc.	
Lbs/Day	50
Lbs/Year	18250
Gallons / year	2191
Gallons of water/100 lbs of ice	16
Process waste	2928
Est. Storage Waste	8000
Number of Ice Machines	1
Total Storage Waste	24
Total Ice Machine Usage (Gallons)	10920

Energy Inputs	
DHW heating source	NG
Fuel conversion source	CG
Nat. Gas System Efficiency	100.00%

Lbs/Year	5200
Gallons / year	624
Gallons of water/100 lbs of ice	16
Process waste	832
Est. Storage Waste	8000
Number of Ice Machines	1
Total Ice Machine Usage (Gallons)	8832

03/01/15

பெரிய நகரங்களில்

DATE	TIME	LOCATION	WIND	TEMP	REL	WIND	TEMP	REL	WIND	TEMP	REL
0004											
0005											
0006											
0007											
0008											
0009											
0010											
0011											
0012											
0013											
0014											
0015											
0016											
0017											
0018											
0019											
0020											
0021											
0022											
0023											
0024											
0025											
0026											
0027											
0028											
0029											
0030											
0031											
0032											
0033											
0034											
0035											
0036											
0037											
0038											
0039											
0040											
0041											
0042											
0043											
0044											
0045											
0046											
0047											
0048											
0049											
0050											
0051											
0052											
0053											
0054											
0055											
0056											
0057											
0058											
0059											


[illegible][illegible]

Arapahoe County Domestic Water Administrative II

Billing Data	Average last year	Staff days per month	Visitors days per month	Population	Sanitary Water Use Model	Balance	Gallons Saved	Water Dollars Saved	Sewer Dollars Saved	Total Dollars Saved	Water Differential	Sewer Differential
Jan	50,667	22	22	6,532	58,950	-6,283	17,614	\$77	\$61	\$138	-11%	-11%
Feb	62,424	20	20	5,900	51,438	10,986	15,909	\$69	\$55	\$125	21%	21%
Mar	67,807	22	22	6,532	58,950	10,857	17,614	\$77	\$61	\$138	19%	19%
Apr	74,499	22	22	6,532	58,950	19,387	17,614	\$77	\$61	\$138	35%	35%
May	52,803	22	22	6,532	58,950	-4,147	17,614	\$77	\$61	\$138	-7%	-7%
June	64,498	21	21	6,532	58,950	9,386	17,614	\$77	\$61	\$138	17%	17%
July	56,908	22	22	6,532	58,950	-42	17,614	\$77	\$61	\$138	10%	10%
Aug	62,375	22	22	6,532	58,950	5,425	17,614	\$77	\$61	\$138	10%	10%
Sept	58,965	22	22	6,532	58,950	3,853	17,614	\$77	\$61	\$138	7%	7%
Oct	60,856	22	22	6,532	58,950	3,908	17,614	\$77	\$61	\$138	17%	17%
Nov	61,749	21	21	6,532	58,950	6,677	17,614	\$77	\$61	\$138	17%	17%
Dec	52,392	22	22	6,532	58,950	-4,558	17,614	\$77	\$61	\$138	-8%	-8%
	725,943	261	261	75,911	670,535	55,408	207,385	\$902	\$722	\$1,624		

29%

Non-Sanitary Use	Non-Sanitary Use Kgal	Ice machine	Evaporative coolers	Laundry	Kitchen	Total Modeled non-sanitary use	Balance	Total Use Model	Total Use Model
Jan	-6,283	910	0	0	0	910	-7,193	57,860	113%
Feb	10,386	11	0	0	0	910	10,076	52,348	80%
Mar	10,857	11	0	0	0	910	9,947	57,860	83%
Apr	19,397	19	0	0	0	910	18,477	56,022	86%
May	-4,147	-4	0	0	0	910	-5,057	57,860	109%
June	9,386	9	0	0	0	910	8,476	56,022	85%
July	-42	0	0	0	0	910	-952	57,860	102%
Aug	5,425	5	0	0	0	910	4,515	57,860	92%
Sept	3,853	4	0	0	0	910	2,943	56,022	85%
Oct	3,908	4	0	0	0	910	2,998	57,860	95%
Nov	6,677	7	0	0	0	910	5,777	56,022	90%
Dec	-4,558	-5	0	0	0	910	-5,468	57,860	110%
	55,408	55	10,920	0	0	10,975	44,433	681,455	94%



— BILLING DATA Average last year Gallons
--- Sanitary Water Use Model

Arapahoe County Domestic Water Administrative II


Code	Units
1	Gal
2	Kgal
3	CF
4	CCF
5	MCF
2	<<< enter unit code

Water Rate	Sewer Rate
< 25,000 gal	\$0.00232
25,000-200,000	\$0.00290
>200,000	\$0.00348
Minimum Usage	144,000 gals
Storm water fee	\$15.30
Fireline Charge	\$1,142.04
Capitol Fund	\$317.50

Water	Sewer
Differential	Differential
\$0.00073	\$0.00058
\$0.00145	\$0.00116

Read Date	Month	Kash/day	Usage	Gallons	Billing days	Water Charges	Sewer Charges	Total Charges	\$/gal Water charge	\$/gal Sewer charge	\$/gallon Total	\$/gallon Total
1/31/2004	Jan	2	51	50,667	25	\$579	\$462	\$1,041	\$0.0114	\$0.0091	\$0.0205	\$0.0411
2/25/2004	Feb	2	62	62,424	30	\$545	\$435	\$980	\$0.0087	\$0.0070	\$0.0157	\$0.0314
3/26/2004	Mar	2	68	67,807	35	\$529	\$423	\$952	\$0.0078	\$0.0062	\$0.0140	\$0.0281
4/30/2004	Apr	3	74	74,499	27	\$510	\$407	\$917	\$0.0068	\$0.0055	\$0.0123	\$0.0245
5/21/2004	May	2	53	52,803	34	\$573	\$457	\$1,030	\$0.0108	\$0.0087	\$0.0195	\$0.0390
6/30/2004	Jun	2	64	64,498	30	\$539	\$430	\$969	\$0.0084	\$0.0067	\$0.0150	\$0.0301
7/30/2004	Jul	2	57	56,908	31	\$561	\$448	\$1,009	\$0.0091	\$0.0079	\$0.0177	\$0.0355
8/30/2004	Aug	2	62	62,375	31	\$545	\$435	\$980	\$0.0087	\$0.0070	\$0.0157	\$0.0314
9/30/2004	Sep	2	59	58,965	28	\$555	\$443	\$998	\$0.0094	\$0.0075	\$0.0169	\$0.0339
10/28/2004	Oct	2	61	60,856	33	\$550	\$439	\$989	\$0.0090	\$0.0072	\$0.0162	\$0.0325
11/30/2004	Nov	2	62	61,749	31	\$547	\$437	\$984	\$0.0089	\$0.0071	\$0.0159	\$0.0319
12/31/2004	Dec	2	52	52,392	30	\$574	\$458	\$1,032	\$0.0110	\$0.0088	\$0.0197	\$0.0394
1/30/2005	Jan											

50,667	50,667
62,424	62,424
67,807	67,807
74,499	74,499
52,803	52,803
64,498	64,498
56,908	56,908
62,375	62,375
58,965	58,965
60,856	60,856
61,749	61,749
52,392	52,392



ECM 3 – Install New/Upgrade Energy Management System

Please refer to the Energy Conservation Measure (ECM) section of this report for additional information.

Existing Condition to Warrant an ECM Opportunity:

Some of the facilities within Arapahoe County currently have an energy management control system (EMCS). In most cases, the equipment in these facilities operates during periods of the little or no occupancy. So, some of the existing operating schedules programmed into the EMCS can be modified to better match the actual occupancy schedules.

Many facilities within Arapahoe County are currently without an EMCS. These facilities utilize time clocks, programmable thermostats, and non-programmable thermostats for control of their equipment. In most cases, the equipment operates during periods of little or no occupancy. The installation of a new EMCS will allow the maintenance staff to easily modify the equipment operating schedules to better match the actual occupancy schedules.

Savings Calculation Methodology:

The implementation of this ECM shall result in both natural gas and electrical savings. The savings for this ECM were calculated utilizing two Trane Trace building energy simulation models. The first model included the existing operating schedules for each piece of equipment. The second model was modified to include the new operating schedules for each piece of equipment. The annual energy consumption calculated from each model was subtracted from one another to produce the annual energy savings.

Spreadsheet calculations were performed on the buildings that were not modeled. The spreadsheet calculations used the same methodology described above.

Figure 1

Arapahoe County - Admin I Building
Computer Model Calibration for Electric Energy Use

ELECTRIC ENERGY USAGE (kWh)			
Month	BASELINE	MODEL	
Jan	217,183	160,605	26%
Feb	189,788	145,184	24%
Mar	229,311	168,223	27%
Apr	218,456	194,211	11%
May	243,374	236,417	3%
Jun	248,088	246,541	1%
Jul	270,700	246,323	9%
Aug	264,710	258,730	2%
Sep	243,348	223,995	8%
Oct	232,915	230,945	1%
Nov	220,561	174,307	21%
Dec	216,466	156,768	28%
	2,794,900	2,442,249	13%





Figure 2

Arapahoe County - Admin I Building
Computer Model Calibration for Natural Gas

NATURAL GAS USAGE (Therms)			
Month	BASELINE	MODEL	
Jan	5,080	6,648	-31%
Feb	4,650	5,870	-26%
Mar	3,950	6,011	-52%
Apr	3,550	3,128	12%
May	2,140	1,521	29%
Jun	1,740	449	74%
Jul	1,010	353	65%
Aug	1,390	443	68%
Sep	2,220	1,421	36%
Oct	4,110	2,921	29%
Nov	4,850	5,181	-7%
Dec	4,870	6,142	-26%
	39,560	40,089	-1%



MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe County - Admin I - Match

Utility	Monthly Energy Consumption													Total
Electric	On-Pk Cons. (kWh)	160,605	145,184	168,223	194,211	236,417	246,541	246,323	258,730	223,995	230,945	174,307	156,768	2,442,249
	On-Pk Demand (kW)	410	410	410	648	665	673	684	676	665	664	575	410	684
Gas	On-Pk Cons. (therms)	6,648	5,870	6,011	3,128	1,521	449	353	443	1,421	2,921	5,181	6,142	40,089
	On-Pk Demand (therms/hr)	38	39	38	36	35	6	2	3	35	36	37	38	39
Water	Cons. (1000gal)	0	0	0	104	215	258	298	281	197	155	24	0	1,533
Building Energy Consumption = 110,260 Btu/(ft2-year)														
Source Energy Consumption = 261,072 Btu/(ft2-year)														
Floor Area = 111,956 ft2														

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe County - Admin I - Lighting Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	140,796	127,277	147,458	172,897	212,943	223,527	222,829	233,874	199,514	211,337	138,488	137,436	2,168,375
On-Pk Demand (kW)	358	358	358	586	593	609	619	612	607	600	358	358	619
Gas													
On-Pk Cons. (therms)	6,751	5,968	6,114	3,168	1,499	476	353	465	1,708	2,917	5,907	6,238	41,562
On-Pk Demand (therms/hr)	37	37	37	35	34	6	2	3	35	35	36	37	37
Water													
Cons. ('1000gal)	0	0	0	91	197	235	277	260	179	145	0	0	1,385
Building Energy Consumption =													
Source Energy Consumption =	103,227 Btu/(ft2-year)												
Floor Area =	237,407 Btu/(ft2-year)												
	111,956 ft2												

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe County - Admin I - EMCS Run

Monthly Energy Consumption														
Utility		Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric	On-Pk Cons. (kWh)	130,120	117,639	137,067	149,284	177,616	184,908	184,820	196,456	161,483	176,125	128,253	126,618	1,870,390
	On-Pk Demand (kW)	358	358	358	586	616	638	646	636	614	600	358	358	646
Gas	On-Pk Cons. (therms)	4,845	4,278	3,815	1,265	415	388	353	405	353	1,373	3,805	4,449	25,743
	On-Pk Demand (therms/hr)	37	37	36	34	12	2	2	2	2	31	36	37	37
Water	Cons. (1000gal)	0	0	0	70	145	186	200	210	124	103	0	0	1,037
Building Energy Consumption = 80,013 Btu/(ft2-year)														
Source Energy Consumption = 195,278 Btu/(ft2-year)														
Floor Area = 111,956 ft2														

MODELING NOTES

ARAPAHOE COUNTY - ADMIN I BUILDING

ECM Run: Install New EMCS

Fan System	Item Changed	Previous Run Input	Current Run Input
AH-1	Fan Schedule	M-F: 5am-11pm; Sat-Sun: 8am-4pm	M-F: 6am-6:30pm; Sat-Sun: Off
AH-2	Fan Schedule	M-F: 5am-11pm; Sat-Sun: 8am-4pm	M-F: 6am-6:30pm; Sat-Sun: Off
AH-3	Fan Schedule	M-F: 5am-11pm; Sat-Sun: 8am-4pm	M-F: 6am-6:30pm; Sat-Sun: Off
AH-4	Fan Schedule	M-F: 5am-11pm; Sat-Sun: 8am-4pm	M-F: 6am-6:30pm; Sat-Sun: Off

Previous Run (New Lighting Run):

Annual kWh Usage: 2,168,375
Annual kW Usage: 6,016
Annual Therms Usage: 41,562

Current Run (Install New EMCS Run):

Annual kWh Usage: 1,870,390
Annual kW Usage: 6,125
Annual Therms Usage: 25,743

Savings (Install New EMCS Savings):

Annual kWh Savings: 297,985
Annual kW Savings: -109
Annual Therms Savings: 15,819

Notes:

1. The negative kW savings is the result of the chiller have to work harder in the mornings due to the schedule change. These negative savings shall not be accounted for since the upgraded EMCS shall cool each space down gradually without having to "overload" the chillers in the morning.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

Admin I - DHW Pump EMCS Savings

Pump ID:	HP:	LF:	Efficiency:	kW:	Existing Run Hrs:	New Run Hrs:	kWh Savings:
DHWP-1	0.17	0.75	0.7	0.13	8,760	3,259	733
HX Pump	0.25	0.75	0.7	0.20	8,760	3,259	1,099

Total kWh Savings: 1,832

Note: The existing run hours are 24 h/d, 7 d/w. The new run hours are 12.5 h/d, 5 d/w. These savings shall be added to the EMCS savings that were calculated in the Trane Trace building simulation model.

Figure 1

Arapahoe County - Arapahoe Plaza East Building
Computer Model Calibration for Electric Energy Use

ELECTRIC ENERGY USAGE (kWh)		
Month	BASELINE	MODEL
Jan	33,024	29,670
Feb	28,866	26,813
Mar	33,384	30,602
Apr	28,336	28,562
May	28,416	30,213
Jun	28,020	29,748
Jul	29,354	30,148
Aug	31,700	31,074
Sep	29,611	28,642
Oct	30,668	30,136
Nov	27,862	29,028
Dec	31,304	29,204
	360,545	353,840
		2%




Figure 2

Arapahoe County - Arapahoe Plaza East Building
Computer Model Calibration for Natural Gas

NATURAL GAS USAGE (Therms)		
Month	BASELINE	MODEL
Jan	0	0
Feb	0	0
Mar	0	0
Apr	0	0
May	0	0
Jun	0	0
Jul	0	0
Aug	0	0
Sep	0	0
Oct	0	0
Nov	0	0
Dec	0	0
	0	0
		#DIV/0!




Figure 1

Arapahoe County - Arapahoe Human Services
Computer Model Calibration for Electric Energy Use

ELECTRIC ENERGY USAGE (kWh)		
Month	BASILINE	MODEL
Jan	56,825	59,538
Feb	53,311	53,809
Mar	57,360	61,379
Apr	55,422	65,372
May	57,204	88,176
Jun	69,488	96,267
Jul	102,970	112,971
Aug	83,302	107,725
Sep	80,601	85,398
Oct	83,325	78,622
Nov	73,482	58,109
Dec	56,864	58,611
	830,154	925,977
		-12%




Figure 2

Arapahoe County - Arapahoe Human Services
Computer Model Calibration for Natural Gas

NATURAL GAS USAGE (Therms)		
Month	BASILINE	MODEL
Jan	6,316	4,401
Feb	5,567	4,013
Mar	5,364	3,706
Apr	3,074	2,406
May	2,324	1,602
Jun	1,054	1,203
Jul	605	691
Aug	873	1,129
Sep	1,523	1,596
Oct	4,029	2,418
Nov	6,131	3,477
Dec	6,336	4,222
	43,196	30,865
		29%




Figure 1

Arapahoe County - Arapahoe Plaza West Building
Computer Model Calibration for Electric Energy Use

ELECTRIC ENERGY USAGE (kWh)		
Month	BASELINE	MODEL
Jan	34,674	30,921 11%
Feb	32,763	27,950 15%
Mar	36,092	32,238 11%
Apr	32,596	29,711 9%
May	32,167	31,652 2%
Jun	32,748	31,235 5%
Jul	34,057	30,975 9%
Aug	34,661	32,667 6%
Sep	32,809	29,781 9%
Oct	33,233	31,579 5%
Nov	32,757	30,370 7%
Dec	34,647	30,263 13%
	403,204	369,343 8%





Figure 2

Arapahoe County - Arapahoe Plaza West Building
Computer Model Calibration for Natural Gas

NATURAL GAS USAGE (Therms)		
Month	BASELINE	MODEL
Jan	0	0 #DIV/0!
Feb	0	0 #DIV/0!
Mar	0	0 #DIV/0!
Apr	0	0 #DIV/0!
May	0	0 #DIV/0!
Jun	0	0 #DIV/0!
Jul	0	0 #DIV/0!
Aug	0	0 #DIV/0!
Sep	0	0 #DIV/0!
Oct	0	0 #DIV/0!
Nov	0	0 #DIV/0!
Dec	0	0 #DIV/0!
	0	0 #DIV/0!



MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe Plaza Bldgs - Match Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
---------	-----	-----	-----	-----	-----	------	------	-----	------	-----	-----	-----	-------

Electric

On-Pk Cons. (kWh)	120,129	108,572	124,218	123,646	150,041	157,250	174,094	171,467	143,821	140,337	117,507	118,078	1,649,160
On-Pk Demand (kW)	271	271	271	342	398	416	458	439	413	370	271	271	458

Gas

On-Pk Cons. (therms)	4,401	4,013	3,706	2,406	1,602	1,203	691	1,129	1,596	2,418	3,477	4,222	30,865
On-Pk Demand (therms/hr)	18	19	11	9	8	7	6	7	8	9	11	18	19

Building Energy Consumption =
Source Energy Consumption =
Floor Area =

91,864 Btu/(ft2-year)
212,253 Btu/(ft2-year)
94,870 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe Plaza Bldgs - East Light Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	118,071	106,775	122,061	121,729	147,526	154,642	171,372	168,814	141,501	138,154	115,482	116,070	1,622,198
On-Pk Demand (kW)	265	265	265	336	394	408	452	431	405	362	265	265	452
Gas													
On-Pk Cons. (therms)	4,437	4,045	3,743	2,437	1,620	1,218	692	1,143	1,617	2,452	3,511	4,256	31,170
On-Pk Demand (therms/hr)	18	18	11	9	8	7	6	7	8	9	11	18	18
Building Energy Consumption =	91,215 Btu/(ft2-year)												
Source Energy Consumption =	209,681 Btu/(ft2-year)												
Floor Area =	94,870 ft2												

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe Plaza Bldgs - East Emcs Run

Monthly Energy Consumption											
Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Total
Electric											
On-Pk Cons. (kWh)	109,469	99,011	113,863	112,852	137,847	145,741	160,512	161,270	133,531	128,286	1,516,895
On-Pk Demand (kW)	265	265	265	336	394	413	457	438	416	362	457
Gas											
On-Pk Cons. (therms)	3,817	3,482	3,214	1,951	1,287	992	598	941	1,246	1,978	26,138
On-Pk Demand (therms/hr)	13	14	10	8	6	5	5	5	6	7	14

Building Energy Consumption = 82,123 Btu/(ft2-year)
Source Energy Consumption = 192,731 Btu/(ft2-year)
Floor Area = 94,870 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe Plaza Bldgs - South Light Run

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
----- Monthly Energy Consumption -----													
Electric													
On-Pk Cons. (kWh)	93,060	84,184	96,738	95,697	116,059	124,401	133,489	137,225	113,657	109,637	90,976	90,849	1,285,972
On-Pk Demand (kW)	239	239	239	311	366	391	423	410	391	337	239	239	423
Gas													
On-Pk Cons. (therms)	2,926	2,677	2,302	1,148	580	357	129	303	560	1,091	2,135	2,718	16,926
On-Pk Demand (therms/hr)	12	12	10	7	4	3	3	3	4	5	9	11	12
Building Energy Consumption = 64,105 Btu/(ft2-year)													
Source Energy Consumption = 157,585 Btu/(ft2-year)													
Floor Area = 94,870 ft2													

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe Plaza Bldgs - South EMCS Run

Utility	Monthly Energy Consumption												Total	
	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec		
Electric	On-Pk Cons. (kWh)	77,494	70,071	82,261	80,380	100,815	110,366	112,393	123,313	101,119	94,994	76,802	75,110	1,105,118
	On-Pk Demand (kW)	239	239	239	317	390	405	423	414	402	357	250	239	423
Gas	On-Pk Cons. (therms)	1,815	1,673	1,403	307	33	0	0	0	0	262	1,220	1,613	8,326
	On-Pk Demand (therms/hr)	13	14	10	7	2	0	0	0	0	3	9	12	14
Building Energy Consumption = 48,534 Btu/(ft2-year)														
Source Energy Consumption = 128,522 Btu/(ft2-year)														
Floor Area = 94,870 ft2														

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe Plaza Bldgs - West Light Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kW/h)	106,284	96,069	110,478	109,641	133,731	141,541	155,871	156,690	129,723	124,651	104,109	104,026	1,472,813
On-Pk Demand (kW)	257	257	257	328	382	401	445	427	404	351	257	257	445
Gas													
On-Pk Cons. (therms)	3,843	3,505	3,237	1,968	1,277	980	581	928	1,240	1,995	3,023	3,657	26,234
On-Pk Demand (therms/hr)	12	13	10	8	6	5	4	5	6	7	9	13	13
Building Energy Consumption =	80,638 Btu/(ft2-year)												
Source Energy Consumption =	188,080 Btu/(ft2-year)												
Floor Area =	94,870 ft2												

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe Plaza Bldgs - West EMCS Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
---------	-----	-----	-----	-----	-----	------	------	-----	------	-----	-----	-----	-------

Electric

On-Pk Cons. (kWh)	99,488	89,995	103,593	102,432	124,422	133,329	142,186	146,650	121,696	117,222	97,033	97,117	1,375,163
On-Pk Demand (kW)	257	257	257	333	390	415	446	432	414	366	257	257	446

Gas

On-Pk Cons. (therms)	2,792	2,554	2,203	1,065	533	338	126	284	518	1,007	2,043	2,621	16,084
On-Pk Demand (therms/hr)	11	11	10	7	4	3	4	3	4	5	8	11	11

Building Energy Consumption =
Source Energy Consumption =
Floor Area =

66,426 Btu/(ft2-year)
166,277 Btu/(ft2-year)
94,870 ft2

MODELING NOTES

ARAPAHOE COUNTY - ARAPAHOE PLAZA EAST BUILDING

ECM Run: Install New EMCS

Room/Fan System	Item Changed	Previous Run Input	Current Run Input
AHU-E1	Fan Schedule	M-F: 6am-10pm; Sat-Sun: 8am-4:30pm	M-F: 7am-6pm; Sat-Sun: OFF
AHU-E2	Fan Schedule	M-F: 6am-10pm; Sat-Sun: 8am-4:30pm	M-F: 7am-6pm; Sat-Sun: OFF

Previous Run (New Lighting Run):

Annual kWh Usage: 1,622,198
Annual kW Usage: 4,116
Annual Therms Usage: 31,170

Current Run (Install New EMCS Run):

Annual kWh Usage: 1,516,895
Annual kW Usage: 4,142
Annual Therms Usage: 26,138

Savings (Install New EMCS Savings):

Annual kWh Savings: 105,303
Annual kW Savings: -27
Annual Therms Savings: 5,032

Notes:

1. The negative kW savings is the result of the chiller have to work harder in the mornings due to the schedule change. These negative savings shall not be accounted for since the upgraded EMCS shall cool each space down gradually without having to "overload" the chillers in the morning.

Electric Savings Safety Factor: 0.73

Natural Gas Savings Safety Factor: 0.5

MODELING NOTES

ARAPAHOE COUNTY - ARAPAHOE HUMAN SERVICES BUILDING

ECM Run: Install New EMCS

Room/Fan System	Item Changed	Previous Run Input	Current Run Input
AHU-SW1	Fan Schedule	M-F: 6am-10pm; Sat-Sun: 8am-4:30pm	M-F: 7am-6pm; Sat-Sun: OFF
AHU-SE1	Fan Schedule	M-F: 6am-10pm; Sat-Sun: 8am-4:30pm	M-F: 7am-6pm; Sat-Sun: OFF
AHU-SW2	Fan Schedule	M-F: 6am-10pm; Sat-Sun: 8am-4:30pm	M-F: 7am-6pm; Sat-Sun: OFF
AHU-SE2	Fan Schedule	M-F: 6am-10pm; Sat-Sun: 8am-4:30pm	M-F: 7am-6pm; Sat-Sun: OFF

Previous Run (New Lighting Run):

Annual kWh Usage: 1,285,972
Annual kW Usage: 3,827
Annual Therms Usage: 16,926

Current Run (Install New EMCS Run):

Annual kWh Usage: 1,105,118
Annual kW Usage: 3,916
Annual Therms Usage: 8,326

Savings (Install New EMCS Savings):

Annual kWh Savings: 180,854
Annual kW Savings: -89
Annual Therms Savings: 8,600

Notes:

1. The negative kW savings is the result of the chiller have to work harder in the mornings due to the schedule change. These negative savings shall not be accounted for since the upgraded EMCS shall cool each space down gradually without having to "overload" the chillers in the morning.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.5

MODELING NOTES

ARAPAHOE COUNTY - ARAPAHOE PLAZA WEST BUILDING

ECM Run: Install New EMCS

Room/Fan System	Item Changed	Previous Run Input	Current Run Input
AHU-W1	Fan Schedule	M-F: 24 h/d; Sat-Sun: 4am-6pm	M-F: 7am-6pm; Sat-Sun: OFF
AHU-W2	Fan Schedule	M-F: 24 h/d; Sat-Sun: 4am-6pm	M-F: 7am-6pm; Sat-Sun: OFF

Previous Run (New Lighting Run):

Annual kWh Usage: 1,472,813
Annual kW Usage: 4,023
Annual Therms Usage: 26,234

Current Run (Install New EMCS Run):

Annual kWh Usage: 1,375,163
Annual kW Usage: 4,081
Annual Therms Usage: 16,084

Savings (Install New EMCS Savings):

Annual kWh Savings: 97,650
Annual kW Savings: -58
Annual Therms Savings: 10,151

Notes:

1. The negative kW savings is the result of the chiller have to work harder in the mornings due to the schedule change. These negative savings shall not be accounted for since the upgraded EMCS shall cool each space down gradually without having to "overload" the chillers in the morning.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.5

Figure 1

Arapahoe County - Altura Plaza
Computer Model Calibration for Electric Energy Use

Month	ELECTRIC ENERGY USAGE (kWh)	
	BASELINE	MODEL
Jan	121,594	112,997
Feb	103,244	100,020
Mar	112,618	114,465
Apr	112,883	107,205
May	120,411	113,295
Jun	122,653	116,146
Jul	139,482	122,622
Aug	138,135	125,874
Sep	126,767	109,882
Oct	120,855	112,745
Nov	119,468	107,850
Dec	126,428	107,003
	1,464,538	1,350,104
		8%





Figure 1

Arapahoe County - Altura Plaza
Computer Model Calibration for NG usage

Month	NG USAGE (Therms)	
	BASELINE	MODEL
Jan	18,160	7,038
Feb	11,670	6,450
Mar	5,160	5,962
Apr	5,010	3,362
May	4,150	1,450
Jun	3,700	933
Jul	4,530	186
Aug	6,300	682
Sep	7,530	1,276
Oct	14,900	3,421
Nov	18,330	5,074
Dec	8,440	6,277
	107,880	42,111
		61%



By Release 2.006

Monthly Energy Consumption

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	112,997	130,020	114,465	107,205	113,235	116,146	122,622	125,874	108,882	112,745	107,650	107,003	1,350,105
On-Pk Demand (kW)	445	445	445	445	445	446	448	446	446	445	445	445	446
Gas													
On-Pk Cons. (therms)	7,038	6,450	5,962	3,362	1,450	933	188	682	1,276	3,421	5,074	5,277	42,112
On-Pk Demand (therms/hr)	19	19	17	13	9	7	4	5	8	12	15	18	19
Water													
Cons. (1000gals)	56	43	88	43	92	121	176	152	104	104	72	52	1,031

Building Energy Consumption =	134,046	Btu/(ft2-year)
Source Energy Consumption =	277,511	Btu/(ft2-year)
Floor Area =	65,792	ft2

Project Name:	Arapahoe County
Dataset Name:	C:\CDST\FACE700\Projects\Arapahoe\Altura Plaza\Altura Plaza-Q-Match\3.frc

TRACE® 700 v4.1 calculated at 03:32 PM on 08/22/2005
Alternative - 1 Monthly Energy Consumption report

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 Altura Plaza

Utility Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWht)	86,256	84,809	85,876	90,994	85,250	97,213	104,972	106,138	83,140	94,296	90,714	90,718	1,140,374
On-Pk Demand (kW)	364	364	364	364	364	365	366	365	365	365	364	364	366

Gas

On-Pk Cons. (therms)	7,147	6,548	6,042	3,441	1,493	958	186	725	1,301	3,445	5,125	6,373	42,783
On-Pk Demand (therms/hr)	19	19	17	13	9	7	4	5	8	12	15	18	19

Water

Cons. (1000gal)	44	31	53	30	77	104	159	135	90	88	58	39	908
-----------------	----	----	----	----	----	-----	-----	-----	----	----	----	----	-----

Building Energy Consumption =
Source Energy Consumption =
Floor Area =

124,186 Btu/(ft2-year)
245,941 Btu/(ft2-year)
65,792 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 Altura Plaza

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	67,168	59,744	68,625	56,875	64,113	67,495	71,387	76,143	81,955	85,341	81,442	61,037	781,336
On-Pk Demand (kW)	364	364	364	364	364	365	366	365	365	365	367	384	367
Gas													
On-Pk Cons. (therms)	5,799	5,381	5,185	1,398	667	378	186	332	588	3,242	4,319	5,239	32,717
On-Pk Demand (therms/hr)	24	25	24	15	15	8	0	8	15	22	23	24	25
Water													
Cons. (1000gal)	33	25	44	27	65	88	120	111	72	68	44	30	725

Building Energy Consumption = 90,280 Btu/(ft2-year)
 Source Energy Consumption = 173,954 Btu/(ft2-year)
 Floor Area = 65,792 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 Altura Plaza

Utility Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	67,586	60,139	68,831	57,057	64,174	67,546	71,397	76,169	62,010	66,402	61,556	61,378	783,256
On-Pk Demand (kW)	364	364	364	364	364	365	366	365	365	365	366	364	368

Gas													
On-Pk Cons. (therms)	5,381	5,015	4,872	1,105	551	390	186	287	490	3,119	4,094	4,909	30,348
On-Pk Demand (therms/hr)	20	20	20	14	12	6	0	6	11	16	19	20	20

Water													
Cons. (1000gal)	33	25	44	27	65	86	120	111	72	58	44	30	725

Building Energy Consumption = 86,760 Btu/(ft2-year)
 Source Energy Consumption = 170,483 Btu/(ft2-year)
 Floor Area = 65,792 ft2

MODELING NOTES

ARAPAHOE COUNTY - ALTURA PLAZA

ECM Run: Install New EMCS

Fan System	Item Changed	Previous Run Input	Current Run Input
WSHP	Fan Schedule/Cycle with People	Available 100%	M-F: 6am-6:30pm; Sat-Sun: Off
Pre-Heat WSHP	Fan Schedule/Cycle with People	Available 100%	M-F: 7am-6:30pm; Sat-Sun: Off
Fan Coil	Fan Schedule/Cycle with People	Available 100%	M-F: 7am-6:30pm; Sat-Sun: Off

Previous Run (New Lighting Run):

Annual kWh Usage: 1,140,374
Annual kW Usage: 4,374
Annual Therm Usage: 42,784

Current Run (Install New EMCS Run):

Annual kWh Usage: 781,336
Annual kW Usage: 4,377
Annual Therm Usage: 32,718

Savings (Install New EMCS Savings):

Annual kWh Savings: 359,038
Annual kW Savings: -3
Annual Therm Savings: 10,066

Notes:

1. An additional 65,769 Therms were added to the 10,066 Therms savings shown above. This is a result of the building's existing natural gas usage being way out of line, so much so that we were unable to force our computer model to reflect the building's actual natural gas usage. So, the 65,769 Therms is the difference in the building's actual usage and the computer model's "match usage." Refer to the attached spreadsheet.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

Figure 1

Arapahoe County - Altura Plaza
Computer Model Calibration for NG usage

Month	NG USAGE (Therms)			Adjusted Baseline Savings
	BASELINE	MODEL		
Jan	18,160	7,038	61%	11,122
Feb	11,670	6,450	45%	5,220
Mar	5,160	5,962	-16%	-802
Apr	5,010	3,362	33%	1,648
May	4,150	1,450	65%	2,700
Jun	3,700	938	75%	2,767
Jul	4,530	186	96%	4,344
Aug	6,300	682	89%	5,618
Sep	7,530	1,276	83%	6,254
Oct	14,900	3,421	77%	11,479
Nov	18,330	5,074	72%	13,256
Dec	8,440	6,277	26%	2,163
	107,880	42,111	61%	65,769




Figure 1

Arapahoe County - ACJC Courthouse
Computer Model Calibration for Electric Energy Use

ELECTRIC ENERGY USAGE (kWh)		
Month	BASELINE	MODEL
Jan	202,551	197,435 3%
Feb	172,659	178,589 -3%
Mar	234,751	203,151 13%
Apr	234,674	190,309 19%
May	248,888	221,458 11%
Jun	247,557	224,685 9%
Jul	293,663	238,057 19%
Aug	276,365	238,231 14%
Sep	228,143	211,261 7%
Oct	214,985	213,383 1%
Nov	201,979	192,946 4%
Dec	199,199	194,492 2%
	2,755,414	2,503,997 9%





Figure 1

Arapahoe County - ACJC Courthouse
Computer Model Calibration for NG usage

NG USAGE (Therms)		
Month	BASELINE	MODEL
Jan	9,680	8,570 11%
Feb	8,870	7,938 11%
Mar	7,540	7,540 0%
Apr	6,710	5,356 20%
May	4,560	3,860 15%
Jun	4,020	2,835 29%
Jul	2,730	1,484 46%
Aug	3,710	2,446 34%
Sep	3,870	3,639 6%
Oct	6,020	5,366 11%
Nov	6,770	7,029 -4%
Dec	8,320	8,374 -1%
	72,800	64,437 11%



MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 ACJC Courthouse

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric	On-Pk Cons. (kWh)	197,435	178,589	203,151	221,458	224,685	235,057	238,231	211,281	213,383	192,946	194,492	2,503,985
	On-Pk Demand (kW)	409	409	409	436	583	581	574	516	490	409	409	581
Gas	On-Pk Cons. (therms)	8,570	7,838	7,540	3,880	2,835	1,484	2,446	3,639	5,368	7,029	8,374	64,439
	On-Pk Demand (therms/hr)	45	44	44	44	44	44	44	44	44	44	44	45
Water	Cons. (1000gal)	0	0	0	82	109	155	132	81	56	0	0	615

Building Energy Consumption = 142,485 Btu/(ft2-year)
Source Energy Consumption = 308,201 Btu/(ft2-year)
Floor Area = 105,204 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 ACJC Courthouse

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	172,576	155,952	177,036	166,190	194,011	196,562	206,966	208,391	185,310	186,583	166,343	169,990	2,189,927
On-Pk Demand (kW)	346	346	346	350	415	488	501	491	443	417	346	346	501
Gas													
On-Pk Cons. (therms)	8,696	8,063	7,873	5,455	3,915	2,859	1,436	2,445	3,694	5,460	7,148	8,475	65,319
On-Pk Demand (therms/hr)	42	42	42	42	42	42	42	42	42	42	42	42	42
Water													
Cons. (1000gal)	0	0	0	0	67	90	129	108	66	46	0	0	506
Building Energy Consumption = 133,133 Btu/(ft2-year) Source Energy Consumption = 278,513 Btu/(ft2-year) Floor Area = 105,204 ft2													

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 ACJC Courthouse

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	164,194	148,361	158,067	158,423	184,563	188,552	203,494	197,971	175,898	178,072	160,172	182,178	2,087,862
On-Pk Demand (kW)	346	346	346	350	415	488	501	491	443	417	346	346	501

Gas

On-Pk Cons. (therms)	8,519	7,900	7,409	4,930	3,084	1,916	800	1,394	2,877	4,830	6,839	8,276	58,575
On-Pk Demand (therms/hr)	42	42	42	42	33	13	7	10	31	42	42	42	42

Water

Cons. (1000gal)	0	0	0	0	65	85	133	104	62	46	0	0	496
-----------------	---	---	---	---	----	----	-----	-----	----	----	---	---	-----

Building Energy Consumption = 123,411 Btu/(ft2-year)
 Source Energy Consumption = 261,829 Btu/(ft2-year)
 Floor Area = 105,204 ft2

MODELING NOTES

ARAPAHOE COUNTY - ACJC COURTHOUSE

ECM Run: Upgrade Existing EMCS

Fan System	Item Changed	Previous Run Input	Current Run Input
AH-1	Fan Schedule Changed	M-F - 4am-11pm, Sat-Sun: 8am-17pm	M-F: 5:30am-9:30pm; Sat-Sun: 8am-17pm
AHU-1	Fan Schedule Changed	M-F - 4am-11pm, Sat-Sun: 8am-17pm	M-F: 5:30am-9:30pm; Sat-Sun: 8am-17pm
AHIU-2	Fan Schedule Changed	M-F - 4am-11pm, Sat-Sun: 8am-17pm	M-F: 5:30am-9:30pm; Sat-Sun: 8am-17pm

Previous Run (New Lighting Run):

Annual kWh Usage: 2,189,928
Annual kW Usage: 4,835
Annual Therm Usage: 65,319

Current Run (Upgrade Existing EMCS Run):

Annual kWh Usage: 2,087,853
Annual kW Usage: 4,835
Annual Therm Usage: 58,576

Savings (Upgrade Existing EMCS Savings):

Annual kWh Savings: 102,075
Annual kW Savings: 0
Annual Therm Savings: 6,743

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

Figure 1

Arapahoe County - ACJC Admin II Building
Computer Model Calibration for Electric Energy Use

ELECTRIC ENERGY USAGE (kWh)		
Month	BASELINE	MODEL
Jan	149,668	117,519
Feb	123,955	106,449
Mar	137,823	125,967
Apr	166,962	120,398
May	183,024	150,964
Jun	185,588	161,275
Jul	204,313	170,641
Aug	202,649	178,772
Sep	187,481	141,905
Oct	170,057	141,498
Nov	153,399	115,011
Dec	152,731	111,523
	2,017,650	1,641,920
		19%





Figure 2

Arapahoe County - ACJC Admin II Building
Computer Model Calibration for Natural Gas

NATURAL GAS USAGE (Therms)		
Month	BASELINE	MODEL
Jan	3,292	2,762
Feb	2,623	2,527
Mar	2,661	2,629
Apr	1,611	1,677
May	1,342	1,242
Jun	773	1,001
Jul	650	672
Aug	841	999
Sep	897	1,175
Oct	977	1,842
Nov	2,320	2,343
Dec	3,238	2,547
	21,225	21,417
		-1%



By Release 2.007

Monthly Energy Consumption

Building Energy Consumption =	95,541	Btu/(ft2-year)
Source Energy Consumption =	235,198	Btu/(ft2-year)
Floor Area =	81,071	ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 ACJC Admin II - Lighting Run

		Monthly Energy Consumption												Total	
Utility		Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec		
Electric	On-Pk Cons. (kWh)	103,095	93,293	110,380	103,857	132,054	140,854	152,364	156,782	124,987	123,969	100,353	97,688	1,439,677	
	On-Pk Demand (kW)	330	331	330	369	404	418	477	455	427	391	309	323	477	
Gas	On-Pk Cons. (therms)	2,888	2,646	2,781	1,803	1,335	1,077	724	1,079	1,261	1,963	2,476	2,675	22,709	
	On-Pk Demand (therms/hr)	13	13	12	10	10	9	9	9	9	10	11	12	13	
Building Energy Consumption =		88,621 Btu/(ft2-year)													
Source Energy Consumption =		211,331 Btu/(ft2-year)													
Floor Area =		81,071 ft2													

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 ACJC Admin II - EMCS Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	101,636	91,993	108,591	102,210	128,575	137,751	150,090	154,105	121,916	122,297	98,669	96,267	1,414,100
On-Pk Demand (kW)	330	331	330	370	404	426	476	458	427	396	309	323	476
Gas													
On-Pk Cons. (therms)	2,685	2,462	2,516	1,558	1,087	852	580	841	1,041	1,696	2,227	2,465	20,011
On-Pk Demand (therms/hr)	12	13	12	10	7	6	5	6	8	10	11	12	13
Building Energy Consumption =													
Source Energy Consumption =													
Floor Area =													
	84,215 Btu/(ft2-year)												
	204,596 Btu/(ft2-year)												
	81,071 ft2												

MODELING NOTES

ARAPAHOE COUNTY - ACJC ADMIN II BUILDING

ECM Run: Upgrade Existing EMCS

Fan System	Item Changed	Previous Run Input	Current Run Input
AHU-1	Fan Schedule	M-F: 7am-10:30pm; Sat-Sun: OFF	M-F: 7am-8:30pm; Sat-Sun: OFF
AHU-2	Fan Schedule	M-F: 5:30am-10:30pm; Sat-Sun: OFF	M-F: 5:30am-8:30pm; Sat-Sun: OFF
AHU-4	Fan Schedule	M-F: 7am-10:45pm; Sat-Sun: OFF	M-F: 7am-8:30pm; Sat-Sun: OFF
AHU-6	Fan Schedule	M-F: 7am-11pm; Sat-Sun: 8am-5pm	M-F: 7am-8:30pm; Sat-Sun: 8am-5pm

Previous Run (New Lighting Run):

Annual kWh Usage: 1,439,677
Annual kW Usage: 4,563
Annual Therms Usage: 22,709

Current Run (Upgrade Existing EMCS Run):

Annual kWh Usage: 1,414,100
Annual kW Usage: 4,581
Annual Therms Usage: 20,011


Savings (Upgrade Existing EMCS Savings):

Annual kWh Savings: 25,577
Annual kW Savings: -18
Annual Therms Savings: 2,699

Notes:

1. The negative kW savings is the result of the chiller have to work harder in the mornings due to the schedule change. These negative savings shall not be accounted for since the upgraded EMCS shall cool each space down gradually without having to "overload" the chillers in the morning.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73



ECM 4 – Install Programmable Thermostats

Please refer to the Energy Conservation Measure (ECM) section of this report for additional information.

Existing Condition to Warrant an ECM Opportunity:

Many of the facilities within Arapahoe County currently don't have an energy management control system (EMCS). These facilities utilize non-programmable thermostats for control of their equipment. In most cases, the equipment operates during periods of little or no occupancy. The installation of programmable thermostats will allow the maintenance staff to easily modify the equipment operating schedules to better match the actual occupancy schedules.

Savings Calculation Methodology:

The implementation of this ECM shall result in both natural gas and electrical savings. The majority of the savings for this ECM were calculated utilizing two Trane Trace building energy simulation models. The first model included the existing operating schedules for each piece of equipment. The second model was modified to include the new operating schedules for each piece of equipment. The annual energy consumption calculated from each model was subtracted from one another to produce the annual energy savings.

Spreadsheet calculations were performed on the buildings that were not modeled. The spreadsheet calculations used the same methodology described above.

Federal Warehouse EMCS & Programmable Thermostats Savings Summary

Building	Unit ID:	Fan Motor Savings (kWh)	Cooling Savings (kWh):	Heating Savings (Therms):	Total Savings (kWh):
Federal Warehouse	RTU-2,3,5,6,8,9	3,320	5,705	935	9,025
Federal Warehouse	RTU-7	552	861	169	1,413
Federal Warehouse	RTU-10	2,056	2,520	743	4,576
TOTALS		5,928	9,086	1,847	15,014

Date: 6/30/05
Building: Federal Warehouse
Equip. Name: RTU-235689(10 Tons)

NOTE: Highlighted Cells are user inputs.

Current Occupancy Schedule:

EXAMPLE (6:00am to 6 pm)			From	To	Hours
SMTWRRFS			6	18	12
Mon			6	18	12
Tues			6	18	12
Wed			6	18	12
Thu			6	18	12
Fri			6	18	12
Sat			6	18	12
Sun			6	18	12

Supply Fan Motor Savings:

Inputs: HP: 3
Efficiency: 0.8
Load Factor: 0.75
of Fans: 16
Existing Yearly Hrs: 773
Proposed Yearly Hrs: 510

kWh_savings: 3,320

Proposed Occupancy Schedule:

EXAMPLE (6:00am to 6 pm)			From	To	Hours
SMTWRRFS			6	18	12
Mon			6	18	0
Tues			6	18	11
Wed			6	18	11
Thu			6	18	11
Fri			6	18	11
Sat			6	18	0
Sun			6	18	55

Note: Enter Start hours as 5, for example 5.5 not 5.30

Date: 6/20/05
Building: Federal Warehouse
Equip. Name: RTU-2,3,5,6,9,10 (Tons)

NOTE: Highlighted Cells are User Inputs

CURRENT CONDITIONS		PROPOSED CONDITIONS	
Heating Discharge Air Temp (DAT)	55.00 F	Heating Discharge Air Temp (DAT)	55.00 F
Cooling Discharge Air Temp (DAT)	55.00 F	Cooling Discharge Air Temp (DAT)	55.00 F
Heating Return Air Temp (RAT)	55.00 F	Heating Return Air Temp (RAT)	55.00 F
Cooling Return Air Temp (RAT)	55.00 F	Cooling Return Air Temp (RAT)	55.00 F
OA%	10%	OA%	10%
RA%	90%	RA%	90%
kW/Ton range of air-cooled A/C Unit	0.75 - 1.1	kW/Ton range of air-cooled A/C Unit	0.75 - 1.1
Supply Fan CFM	4000	Supply Fan CFM	4000
Min. OA CFM	400	Min. OA CFM	400
Cooling Minimum Mixed Air Temp	55 F	Cooling Minimum Mixed Air Temp	55 F
Furnace Efficiency (0.75-75%)	0.8	Furnace Efficiency (0.75-75%)	0.8

Current Occupancy Schedule	
From	To
Mon	6:00am to 5:00pm
Tues	6:00am to 5:00pm
Wed	6:00am to 5:00pm
Thurs	6:00am to 5:00pm
Fri	6:00am to 5:00pm
Sat	0:00am to 0:00pm
Sun	0:00am to 0:00pm

Proposed Occupancy Schedule	
From	To
Mon	6:00am to 5:00pm
Tues	6:00am to 5:00pm
Wed	6:00am to 5:00pm
Thurs	6:00am to 5:00pm
Fri	6:00am to 5:00pm
Sat	0:00am to 0:00pm
Sun	0:00am to 0:00pm

Existing Hours												Proposed Hours											
DAT	Cycling Factor	OAT BIN	CFM To Be Hld. Or Ctl.	Outside Air CFM	Mixed Air Temp	BTU/Hr	kW/Ton & Therm/H	Run Hours	Energy kWh/yr & Therm/yr	OAT BIN	SF CFM	Outside Air CFM	Mixed Air Temp	BTU/Hr	kW/Ton & Therm/H	Run Hours	Energy kWh/yr & Therm/yr						
55.00	0.75	97	4,000	400	73.10	80,924	1.1 8.33	5	44	107	4,000	400	73.10	80,924	1.1 8.08	4	33						
55.00	0.50	92	4,000	400	77.00	88,036	1.1 7.18	24	210	102	4,000	400	76.00	85,643	1.1 7.07	22	183						
55.00	0.25	87	4,000	400	77.10	87,158	1.1 7.16	40	342	97	4,000	400	76.10	85,643	1.1 7.05	42	350						
55.00	0.00	82	4,000	400	76.00	85,265	1.1 7.02	71	596	85	4,000	400	77.50	90,975	1.1 7.16	18	405						
55.00	0.25	77	4,000	400	76.10	85,379	1.1 7.04	31	263	87	4,000	400	77.00	87,158	1.1 7.06	46	385						
7.50.00	0.20	72	4,000	400	76.80	87,409	1.1 7.47	67	466	82	4,000	400	76.00	85,265	1.1 7.03	41	325						
55.00	0.75	67	4,000	400	76.40	86,658	1.1 7.30	58	357	77	4,000	400	76.50	87,000	1.1 7.26	52	389						
55.00	0.50	62	4,000	400	74.00	77,120	1.1 6.18	38	278	73	4,000	400	74.50	81,492	1.1 6.30	32	256						
55.00	0.25	57	4,000	400	73.10	80,924	1.1 6.78	18	126	65	4,000	400	74.00	80,600	1.1 6.72	22	186						
55.00	0.00	52	4,000	400	73.80	78,827	1.1 6.78	34	228	57	4,000	400	74.10	75,073	0.8 6.84	12	11						
85.00	0.05	47	4,000	400	70.80	67,529	0.8 1.09	13	33	52	4,000	400	71.80	63,756	0.8 1.05	21	22						
85.00	0.10	42	4,000	400	70.30	69,415	0.8 1.12	48	51	47	4,000	400	71.30	65,643	0.8 1.07	28	31						
95.00	0.15	37	4,000	400	69.80	61,302	0.8 1.14	59	67	42	4,000	400	70.60	67,529	0.8 1.09	38	41						
95.00	0.25	32	4,000	400	69.30	53,188	0.8 1.16	57	67	37	4,000	400	70.30	68,415	0.8 1.12	37	41						
95.00	0.30	27	4,000	400	68.80	53,075	0.8 1.19	46	55	32	4,000	400	68.60	61,302	0.8 1.14	29	33						
95.00	0.35	17	4,000	400	68.30	56,981	0.8 1.21	32	38	27	4,000	400	68.30	61,302	0.8 1.16	20	23						
85.00	0.40	12	4,000	400	67.80	68,847	0.8 1.24	21	26	22	4,000	400	68.80	85,075	0.8 1.19	13	16						
95.00	0.45	7	4,000	400	67.30	100,734	0.8 1.26	15	18	17	4,000	400	68.00	86,961	0.8 1.21	10	12						
95.00	0.50	2	4,000	400	66.80	102,520	0.8 1.28	11	13	12	4,000	400	67.80	88,947	0.8 1.24	7	6						
95.00	0.55	-3	4,000	400	66.30	104,397	0.8 1.31	7	7	11	4,000	400	67.50	90,975	0.8 1.26	4	4						
85.00	0.60	-8	4,000	400	65.80	106,270	0.8 1.33	2	2	2	4,000	400	66.30	102,520	0.8 1.30	0	0						
55.00	0.65	-13	4,000	400	65.30	108,279	0.8 1.35	1	1	-3	4,000	400	65.80	104,507	0.8 1.33	0	0						
85.00	0.75	-18	4,000	400	64.80	110,169	0.8 1.38	1	1	-8	4,000	400	65.30	106,393	0.8 1.35	1	0						
55.00	1.00	-23	4,000	400	64.30	112,652	0.8 1.40	0	0	-13	4,000	400	65.30	108,279	0.8 1.35	0	0						
95.00	1.00	-28	4,000	400	63.80	113,939	0.8 1.42	0	0	-18	4,000	400	64.80	110,165	0.8 1.38	0	0						

CFM

4000

Correction Factor

0.9432

Existing Cooling Usage (kWh):

19,420

Existing Heating Usage (Therm):

2,420

Cooling Savings (kWh):

3,765

Heating Savings (Therm):

935

NOTE: Highlighted Cells are User Inputs.

Date: 6/30/05
Building: Federal Warehouse
Equip. Name: RTU-7 (10 Tons)

Current Occupancy Schedule:

EXAMPLE (6:00am to 6 pm)	From: 6	To: 18	Hours:
SMTWRFS			12
Mon	5	17	12
Tues	6	17	12
Wed	5	17	12
Thu	5	17	12
Fri	5	17	12
Sat	5	17	12
Sun	5	17	84

Supply Fan Motor Savings:

Inputs
HP: 3
Efficiency: 0.8
Load Factor: 0.75
of Fans: 1
Existing Yearly Hrs: 773
Proposed Yearly Hrs: 510

kWh_savings: 552

Proposed Occupancy Schedule:

EXAMPLE (6:00am to 6 pm)	From: 6	To: 18	Hours:
SMTWRFS			12
Mon	6	17	11
Tues	6	17	11
Wed	6	17	11
Thu	6	17	11
Fri	6	17	11
Sat	6	17	0
Sun	6	17	0
			55

Note: Enter Half hours as .5, for example 6.5 not 6:30

CURRENT CONDITIONS				PROPOSED CONDITIONS			
Heating Discharge Air Temp (DAT)	55 F	55 F	55 F	Heating Discharge Air Temp (DAT)	55 F	55 F	55 F
Cooling Discharge Air Temp (DAT)	55 F	55 F	55 F	Cooling Discharge Air Temp (DAT)	55 F	55 F	55 F
Heating Return Air Temp (RAT)	70 F	70 F	70 F	Heating Return Air Temp (RAT)	70 F	70 F	70 F
Cooling Return Air Temp (RAT)	70 F	70 F	70 F	Cooling Return Air Temp (RAT)	70 F	70 F	70 F
Supply Fan CFM	400	400	400	Supply Fan CFM	4000	4000	4000
kW/ton rating of air-cooled A/C Unit	1.1	1.1	1.1	kW/ton rating of air-cooled A/C Unit	1.1	1.1	1.1
Min. OA CFM	400	400	400	Min. OA CFM	4000	4000	4000
Cooling Minimum Mixed Air Temp	55 F	55 F	55 F	Cooling Minimum Mixed Air Temp	55 F	55 F	55 F
Furnace Efficiency (0.75 to 75%)	0.8	0.8	0.8	Furnace Efficiency (0.75 to 75%)	0.8	0.8	0.8
Current Occupancy Schedule				Proposed Occupancy Schedule			
EXAMPLE (6:00am to 6 pm)		From	To	EXAMPLE (6:00am to 6 pm)		From	To
SMTWRFSS		6	18	SMTWRFSS		6	18
Mon	0	0	0	Mon	0	0	0
Tues	5	17	17	Tues	6	17	17
Wed	5	17	17	Wed	6	17	17
Thurs	5	17	17	Thurs	6	17	17
Fri	5	17	17	Fri	6	17	17
Sat	5	17	17	Sat	0	0	0
Sun	5	17	17	Sun	0	0	0

Existing Hours										Proposed Hours									
DAT	Cycling Factor	CFM To Be In	CFM To Be Out	Macz Air	Temp	BTU/Hr	kW/Ton & Therm/Hr	Run Hours	Energy kWh/yr	OAT BIN	5°F CFM	4°F CFM	Outside Macz Air	Temp	BTU/Hr	kW/Ton & Therm/Hr	Run Hours	Energy kWh/yr	
																			QAT BIN
35.00	0.75	97	4,000	400	78.10	80,824	9.3	5	48	107	4,000	400	78.10	80,824	9.3	5	48	48	
50.00	0.50	42	4,000	400	77.60	84,038	1.1	8.33	23	57	4,000	400	77.60	84,038	1.1	8.33	25	11	
55.00	0.30	37	4,000	400	77.10	87,157	1.1	7.00	34	52	4,000	400	77.10	87,157	1.1	7.00	35	22	
55.00	0.20	32	4,000	400	76.60	90,276	1.1	6.67	47	42	4,000	400	76.60	90,276	1.1	6.67	38	31	
55.00	0.25	27	4,000	400	76.10	93,395	1.1	6.33	59	37	4,000	400	76.10	93,395	1.1	6.33	29	41	
55.00	0.35	22	4,000	400	75.60	96,514	1.1	5.99	69	32	4,000	400	75.60	96,514	1.1	5.99	33	41	
55.00	0.45	17	4,000	400	75.10	99,633	1.1	5.66	81	27	4,000	400	75.10	99,633	1.1	5.66	23	41	
55.00	0.55	12	4,000	400	74.60	102,752	1.1	5.33	93	22	4,000	400	74.60	102,752	1.1	5.33	16	41	
55.00	0.65	7	4,000	400	74.10	105,871	1.1	5.00	105	17	4,000	400	74.10	105,871	1.1	5.00	12	41	
55.00	0.75	2	4,000	400	73.60	108,990	1.1	4.67	117	12	4,000	400	73.60	108,990	1.1	4.67	7	41	
55.00	0.85	2	4,000	400	73.10	112,109	1.1	4.33	129	7	4,000	400	73.10	112,109	1.1	4.33	3	41	
55.00	0.95	2	4,000	400	72.60	115,228	1.1	4.00	141	2	4,000	400	72.60	115,228	1.1	4.00	1	41	
55.00	1.00	23	4,000	400	72.10	118,347	1.1	3.67	153	-3	4,000	400	72.10	118,347	1.1	3.67	0	1	
55.00	1.00	23	4,000	400	71.60	121,466	1.1	3.33	165	-8	4,000	400	71.60	121,466	1.1	3.33	0	1	
55.00	1.00	28	4,000	400	71.10	124,585	1.1	3.00	177	-13	4,000	400	71.10	124,585	1.1	3.00	0	1	
55.00	1.00	28	4,000	400	70.60	127,704	1.1	2.67	189	-18	4,000	400	70.60	127,704	1.1	2.67	0	1	
55.00	1.00	28	4,000	400	70.10	130,823	1.1	2.33	201	-18	4,000	400	70.10	130,823	1.1	2.33	0	1	
55.00	1.00	28	4,000	400	69.60	133,942	1.1	2.00	213	-18	4,000	400	69.60	133,942	1.1	2.00	0	1	
55.00	1.00	28	4,000	400	69.10	137,061	1.1	1.67	225	-18	4,000	400	69.10	137,061	1.1	1.67	0	1	
55.00	1.00	28	4,000	400	68.60	140,180	1.1	1.33	237	-18	4,000	400	68.60	140,180	1.1	1.33	0	1	
55.00	1.00	28	4,000	400	68.10	143,299	1.1	1.00	249	-18	4,000	400	68.10	143,299	1.1	1.00	0	1	
55.00	1.00	28	4,000	400	67.60	146,418	1.1	0.67	261	-18	4,000	400	67.60	146,418	1.1	0.67	0	1	
55.00	1.00	28	4,000	400	67.10	149,537	1.1	0.33	273	-18	4,000	400	67.10	149,537	1.1	0.33	0	1	
55.00	1.00	28	4,000	400	66.60	152,656	1.1	0.00	285	-18	4,000	400	66.60	152,656	1.1	0.00	0	1	
55.00	1.00	28	4,000	400	66.10	155,775	1.1	-0.33	297	-18	4,000	400	66.10	155,775	1.1	-0.33	0	1	
55.00	1.00	28	4,000	400	65.60	158,894	1.1	-0.67	309	-18	4,000	400	65.60	158,894	1.1	-0.67	0	1	
55.00	1.00	28	4,000	400	65.10	162,013	1.1	-0.99	321	-18	4,000	400	65.10	162,013	1.1	-0.99	0	1	
55.00	1.00	28	4,000	400	64.60	165,132	1.1	-1.33	333	-18	4,000	400	64.60	165,132	1.1	-1.33	0	1	
55.00	1.00	28	4,000	400	64.10	168,251	1.1	-1.67	345	-18	4,000	400	64.10	168,251	1.1	-1.67	0	1	
55.00	1.00	28	4,000	400	63.60	171,370	1.1	-2.00	357	-18	4,000	400	63.60	171,370	1.1	-2.00	0	1	
55.00	1.00	28	4,000	400	63.10	174,489	1.1	-2.33	369	-18	4,000	400	63.10	174,489	1.1	-2.33	0	1	
55.00	1.00	28	4,000	400	62.60	177,608	1.1	-2.67	381	-18	4,000	400	62.60	177,608	1.1	-2.67	0	1	
55.00	1.00	28	4,000	400	62.10	180,727	1.1	-3.00	393	-18	4,000	400	62.10	180,727	1.1	-3.00	0	1	
55.00	1.00	28	4,000	400	61.60	183,846	1.1	-3.33	405	-18	4,000	400	61.60	183,846	1.1	-3.33	0	1	
55.00	1.00	28	4,000	400	61.10	186,965	1.1	-3.67	417	-18	4,000	400	61.10	186,965	1.1	-3.67	0	1	
55.00	1.00	28	4,000	400	60.60	190,084	1.1	-4.00	429	-18	4,000	400	60.60	190,084	1.1	-4.00	0	1	
55.00	1.00	28	4,000	400	60.10	193,203	1.1	-4.33	441	-18	4,000	400	60.10	193,203	1.1	-4.33	0	1	
55.00	1.00	28	4,000	400	59.60	196,322	1.1	-4.67	453	-18	4,000	400	59.60	196,322	1.1	-4.67	0	1	
55.00	1.00	28	4,000	400	59.10	199,441	1.1	-5.00	465	-18	4,000	400	59.10	199,441	1.1	-5.00	0	1	
55.00	1.00	28	4,000	400	58.60	202,560	1.1	-5.33	477	-18	4,000	400	58.60	202,560	1.1	-5.33	0	1	
55.00	1.00	28	4,000	400	58.10	205,679	1.1	-5.67	489	-18	4,000	400	58.10	205,679	1.1	-5.67	0	1	
55.00	1.00	28	4,000	400	57.60	208,798	1.1	-6.00	501	-18	4,000	400	57.60	208,798	1.1	-6.00	0	1	
55.00	1.00	28	4,000	400	57.10	211,917	1.1	-6.33	513	-18	4,000	400	57.10	211,917	1.1	-6.33	0	1	
55.00	1.00	28	4,000	400	56.60	215,036	1.1	-6.67	525	-18	4,000	400	56.60	215,036	1.1	-6.67	0	1	
55.00	1.00	28	4,000	400	56.10	218,155	1.1	-7.00	537	-18	4,000	400	56.10	218,155	1.1	-7.00	0	1	
55.00	1.00	28	4,000	400	55.60	221,274	1.1	-7.33	549	-18	4,000	400	55.60	221,274	1.1	-7.33	0	1	
55.00	1.00	28	4,000	400	55.10	224,393	1.1	-7.67	561	-18	4,000	400	55.10	224,393	1.1	-7.67	0	1	
55.00	1.00	28	4,000	400	54.60	227,512	1.1	-8.00	573	-18	4,000	400	54.60	227,512	1.1	-8.00	0	1	
55.00	1.00	28	4,000	400	54.10	230,631	1.1	-8.33	585	-18	4,000	400	54.10	230,631	1.1	-8.33	0	1	
55.00	1.00	28	4,000	400	53.60	233,750	1.1	-8.67	597	-18	4,000	400	53.60	233,750	1.1	-8.67	0	1	
55.00	1.00	28	4,000	400	53.10	236,869	1.1	-9.00	609	-18	4,000	400	53.10	236,869	1.1	-9.00	0	1	
55.00	1.00	28	4,000	400	52.60	240,000	1.1	-9.33	621	-18	4,000	400	52.60	240,000	1.1	-9.33	0	1	
55.00	1.00	28	4,000	400	52.10	243,120	1.1	-9.67	633	-18	4,000	400	52.10	243,120	1.1	-9.67	0	1	
55.00	1.00	28	4,000	400	51.60	246,240	1.1	-10.00	645	-18	4,000	400	51.60	246,240	1.1	-10.00	0	1	
55.00	1.00	28	4,000	400	51.10	249,360	1.1	-10.33	657	-18	4,000	400	51.10	249,360	1.1	-10.33	0	1	
55.00	1.00	28	4,000	400	50.60	252,480	1.1	-10.67	669	-18	4,000	400	50.60	252,480	1.1	-10.67	0	1	
55.00	1.00	28	4,000	400	50.10	255,600	1.1	-11.00	681	-18	4,000	400	50.10	255,600	1.1	-11.00	0	1	
55.00	1.00	28	4,000	400	49.60	258,720	1.1	-11.33	693	-18	4,000	400	49.60	258,720	1.1	-11.33	0	1	
55.00	1.00	28	4,000	400	49.10	261,840	1.1	-11.67	705	-18	4,000	400	49.10	261,840	1.1	-11.67	0	1	
55.00	1.00	28	4,000	400	48.60	264,960	1.1	-12.00	717	-18	4,000	400	48.60	264,960	1.1	-12.00	0	1	
55.00	1.00	28	4,000	400	48.10	268,080	1.1	-12.33	729	-18	4,000	400	48.10	268,080	1.1	-12.33	0	1	
55.00	1.00	28	4,000	400	47.60	271,200	1.1	-12.67	741	-18	4,000	400	47.60	271,200	1.1	-12.67	0	1	
55.00	1.00	28	4,000	400	47.10	274,320	1.1	-13.00	753	-18	4,000	400	47.10	274,320	1.1	-13.00	0	1	
55.00	1.00	28	4,000	400	46.60	277,440	1.1	-13.33	765	-18	4,000	400	46.60	277,440	1.1	-13.33	0	1	
55.00	1.00	28	4,000	400	46.10	280,560	1.1	-13.67	777	-18	4,000	400	46.10	280,560	1.1	-13.67	0	1	
55.00	1.00	28	4,000	400	45.60	283,680	1.1	-14.00	789	-18	4,000	400	45.60	283,680	1.1	-14.00	0	1	
55.00	1.00	28	4,000	400	45.10	286,800	1.1	-14.33	801	-18	4,000	400	45.10	286,800	1.1	-14.33	0	1	
55.00	1.00	28	4,000	400	44.60	289,920	1.1	-14.67	813	-18	4,000	400	44.60	289,920	1.1	-14.67	0	1	
55.00	1.00	28	4,000	400	44.10	293,040	1.1	-15.00	825	-18	4,000	400	44.10	293,040	1.1	-15.00	0	1	
55.00	1.00	28	4,000	400	43.60	296,160	1.1	-15.33	837	-18	4,000	400	43.60	296,160	1.1	-15.33	0	1	
55.00	1.00	28	4,000	400	43.10														

Date: 6/30/05
Building: Federal Warehouse
Equip. Name: RTU-10 (10 Tons)

NOTE: Highlighted Cells are user inputs.

Current Occupancy Schedule:

EXAMPLE (6:00am to 6 pm)			From:	To:	Hours:
SMTWRFSS			6	18	12
Mon	0.0001	24			0
Tues	0.0001	24			24
Wed	0.0001	24			24
Thu	0.0001	24			24
Fri	0.0001	24			24
Sat	0.0001	24			24
Sun	0.0001	24			24

Supply Fan Motor Savings:

Inputs:

HP: 3
Efficiency: 0.8
Load Factor: 0.75
of Fans: 1
Existing Yearly Hrs: 1,489
Proposed Yearly Hrs: 510

kWh savings: 2,056

Proposed Occupancy Schedule:

EXAMPLE (6:00am to 6 pm)			From:	To:	Hours:
SMTWRFSS			6	18	12
Mon	6	17			0
Tues	6	17			11
Wed	6	17			11
Thu	6	17			11
Fri	6	17			11
Sat					0
Sun					0

Note: Enter Half hours only, for example 6.5 not 6.39

Tri County Health EMCS & Programmable Thermostats Savings Summary

Building	Unit ID:	Fan Motor Savings (kWh)	Cooling Savings (kWh):	Heating Savings (Therms):	Total Savings (kWh):
Tri County Health	RTU-1 & RTU-3	391	1,472	451	1,863
Tri County Health	AC-1, F-3 to F-6	979	4,906	1,505	5,884
Tri County Health	RTU-2	381	1,226	376	1,607
TOTALS		1,750	7,604	2,332	9,354

Date: 6/30/05
Building: Tri County Health
Equip. Name: RTU-1 & RTU-3 (3 Tons)

NOTE: Highlighted Cells are user inputs

Current Occupancy Schedule:

EXAMPLE (6:00am to 6 pm)			From:	To:	Hours:
			6	18	12
SMTWRFSS					0
Mon			0.0001	24	24
Tues			0.0001	24	24
Wed			0.0001	24	24
Thu			0.0001	24	24
Fri			0.0001	24	24
Sat			0.0001	24	24
Sun			0.0001	24	169

Note: Enter Half hours as .5, for example 6.5 not 6 30

Proposed Occupancy Schedule:

EXAMPLE (6:00am to 6 pm)			From:	To:	Hours:
			6	18	12
SMTWRFSS					0
Mon			7	18	11
Tues			7	18	11
Wed			7	18	11
Thu			7	18	11
Fri			7	18	11
Sat					0
Sun					55

Note: Enter Half hours as .5, for example 6.5 not 6 30

Supply Fan Motor Savings:

Inputs:

HP: 0.25
Efficiency: 0.7
Load Factor: 0.75
of Fans: 2
Existing Yearly Hrs: 1,489
Proposed Yearly Hrs: 510

kWh_savings: 391

Date: 6/30/05
Building: Tri County Health
Equip Name: RTU-1 & RTU-3 (3 Tons)

NOTE: Highlighted Cells are user inputs

CURRENT CONDITIONS		PROPOSED CONDITIONS	
Heating Discharge Air Temp (DAT)	55 F	Heating Discharge Air Temp (DAT)	55 F
Cooling Discharge Air Temp (DAT)	55 F	Cooling Discharge Air Temp (DAT)	55 F
Heating Return Air Temp (RAT)	74 F	Heating Return Air Temp (RAT)	74 F
Cooling Return Air Temp (RAT)	73 F	Cooling Return Air Temp (RAT)	73 F
OA% 100%		OA% 100%	
Unit 1		Unit 1	
kWh/ton rating of air-cooled A/C Unit 3200 cfm		kWh/ton rating of air-cooled A/C Unit 1200 cfm	
Supply Fan CFM 120		Supply Fan CFM 55 F	
Cooling Minimum Mixed Air Temp 55 F		Cooling Minimum Mixed Air Temp 55 F	
Purview Efficiency (0.75-15%) 0.8		Purview Efficiency (0.75-15%) 0.8	

CURRENT OCCUPANCY SCHEDULE		PROPOSED OCCUPANCY SCHEDULE	
From	To	From	To
EXAMPLE (6:00am to 6:00pm)			
Mon	0	SMTWRFSS	0
Tue	0.0001	Mon	0
Wed	0.0001	Tue	7
Thu	0.0001	Wed	7
Fri	0.0001	Thu	7
Sat	0.0001	Fri	7
Sun	0.0001	Sat	0
		Sun	0

Existing Hours										Proposed Hours									
DAY	Cycling Factor	CFM To 8c Hid Q-C-4	QAT BIN	CFM To 8c Hid Q-C-4	Outside Air Temp	BTU/Hr	kW & Therm/Hr		Run Hours	Energy kW/HR & Therm/HR	QAT BIN	SF CFM	Outside Air Temp	BTU/Hr	kW & Therm/Hr		Run Hours	Energy kW/HR & Therm/HR	
							kW/Ton & Bk Eff	Therm/Hr							kW/Ton & Bk Eff	Therm/Hr			
55.00	0.75	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
54.00	0.50	80	82	1200	120	77.80	24.711	1.1	2.45	35	104	1200	120	78.40	23.84	2.2	23	48	
53.00	0.40	80	82	1200	120	77.10	26.166	1.1	2.40	70	107	1200	120	78.60	24.32	2.2	48	98	
53.00	0.24	80	82	1200	120	76.80	25.810	1.1	2.34	206	97	1200	120	77.80	24.711	2.41	57	124	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200	87	1200	120	78.10	23.217	4.1	2.50	5	107	1200	120	78.10	23.240	2.80	4	10	
55.00	0.90	1200																	

Date: 6/30/05
Building: Tri County Health
Equip. Name: AC-1 & F-3 to F-8 (4 Tons)

NOTE: Highlighted Cells are user inputs

Current Occupancy Schedule

EXAMPLE (6:00am to 6 pm)				From:	To:	Hours
SMTWTFSS				6	18	12
Mon	0.0001	0.0001	0.0001	6	18	24
Tues	0.0001	0.0001	0.0001	6	18	24
Wed	0.0001	0.0001	0.0001	6	18	24
Thu	0.0001	0.0001	0.0001	6	18	24
Fri	0.0001	0.0001	0.0001	6	18	24
Sat	0.0001	0.0001	0.0001	6	18	24
Sun	0.0001	0.0001	0.0001	6	18	24
						168

Proposed Occupancy Schedule:

EXAMPLE (6:00am to 6 pm)				From:	To:	Hours:
SMTWTFSS				6	18	12
Mon	0.0001	0.0001	0.0001	6	18	11
Tues	0.0001	0.0001	0.0001	6	18	11
Wed	0.0001	0.0001	0.0001	6	18	11
Thu	0.0001	0.0001	0.0001	6	18	11
Fri	0.0001	0.0001	0.0001	6	18	11
Sat	0.0001	0.0001	0.0001	6	18	0
Sun	0.0001	0.0001	0.0001	6	18	0
						55

Note: Enter Hall hours as 5, for example: 5 5 not 6 30

Note: Enter Hall hours as 5, for example: 5 5 not 6 30

Supply Fan Motor Savings.

Inputs:

HP: 0.25
Efficiency: 0.7
Load Factor: 0.75
of Fans: 5
Existing Yearly Hrs: 1,489
Proposed Yearly Hrs: 510

kWh_savings: 979

[illegible]

Date: 6/30/05
Building: Tri County Health
Equip Name: RTU-2 (5 Tons)

NOTE: Highlighted Cells are user inputs.

Current Occupancy Schedule:				Proposed Occupancy Schedule:			
From:	To:	Hours:		From:	To:	Hours:	
6	18	12		6	18	12	
EXAMPLE (6:00am to 6 pm)				EXAMPLE (6:00am to 6 pm)			
SMTWRS		0	Note: Enter full hours as 5, for example 5 5 not 5.34	SMTWRS		0	Note: Enter full hours as 5, for example 5 5 not 5.34
Mon	0.0001	24		Mon	7	11	
Tues	0.0001	24		Tues	7	11	
Wed	0.0001	24		Wed	7	11	
Thu	0.0001	24		Thu	7	11	
Fri	0.0001	24		Fri	7	11	
Sat	0.0001	24		Sat		0	
Sun	0.0001	24		Sun		0	
			168				55

Supply Fan Motor Savings:

Inputs:

HP: 0.5

Efficiency: 0.72

Load Factor: 0.75

of Fans: 1

Existing Yearly Hrs: 1489

Proposed Yearly Hrs: 510

kWh_savings: 381

Date: 6/30/05
Building: Tri County Health
Enab. Name: RTU-2 (S Ford)

NOTE: Highlighted Cells are user inputs

CURRENT CONDITIONS		PROPOSED CONDITIONS	
Heating Design Air Temp (DAT)	55.00 F	Heating Design Air Temp (DAT)	55.00 F
Cooling Design Air Temp (DAT)	55.00 F	Cooling Design Air Temp (DAT)	55.00 F
Heating Return Air Temp (RAT)	74.00 F	Heating Return Air Temp (RAT)	74.00 F
Cooling Return Air Temp (RAT)	74.00 F	Cooling Return Air Temp (RAT)	74.00 F
OAT	10%	OAT	10%
RAV	90%	RAV	90%
kW/Ton rating of air-cooled A/C Unit			
Supply Fan CFM	2000 cfm	Supply Fan CFM	2000 cfm
Min OA CFM	200	Min OA CFM	200
Cooling Maximum Mixed Air Temp	55.00 F	Cooling Maximum Mixed Air Temp	55.00 F
Purified Efficiency (0.75-75%)	0.8	Purified Efficiency (0.75-75%)	0.8

Current Occupancy Schedule		Proposed Occupancy Schedule	
From	To	From	To
EXAMPLE (6.00am to 6 pm)	6 18	EXAMPLE (6.00am to 6 pm)	6 18
SMTWTFSS	0 0 0 0 0	SMTWTFSS	0 0 0 0 0
Mon	7 18	Mon	7 18
Tues	7 18	Tues	7 18
Wed	7 18	Wed	7 18
Thur	7 18	Thur	7 18
Fri	7 18	Fri	7 18
Sat	0 0	Sat	0 0
Sun	0 0	Sun	0 0

Existing Hours										Proposed Hours									
DAT	Cycling Factor	OAT BIN	CFM To Be Htd Or Cld	Outside Air CFM	Mixed Air Temp	BTU/Hr	kW/Ton & Therms/Hr	Br. Eff.	Run Hours	Energy kWh/yr & Therms/yr	OAT BIN	SF CFM	Outside Air CFM	Mixed Air Temp	BTU/Hr	kW/Ton & Therms/Hr	Br. Eff.	Run Hours	Energy kWh/yr & Therms/yr
55.00	0.75	97	2,000	2,000	73.10	45,482	1.1	4.17	5	22	107	2,000	2,000	73.10	41,348	1.1	4.17	5	10
55.00	0.50	92	2,000	2,000	77.60	41,518	1.1	4.08	38	182	102	2,000	2,000	78.10	41,735	1.1	4.08	38	182
55.00	0.40	87	2,000	2,000	77.10	42,578	1.1	3.98	70	278	97	2,000	2,000	78.10	41,619	1.1	3.98	70	278
55.00	0.25	82	2,000	2,000	78.80	42,625	1.1	3.91	80	341	92	2,000	2,000	77.30	44,619	1.1	3.91	80	341
55.00	0.20	77	2,000	2,000	78.10	41,685	1.1	3.92	85	365	87	2,000	2,000	78.80	42,625	1.1	3.92	85	365
55.00	0.15	72	2,000	2,000	75.10	39,810	1.1	3.65	83	335	82	2,000	2,000	75.10	41,685	1.1	3.65	83	335
55.00	0.10	67	2,000	2,000	75.10	39,810	1.1	3.48	79	285	77	2,000	2,000	77.60	41,746	1.1	3.48	79	285
55.00	0.05	62	2,000	2,000	73.60	38,873	1.1	3.35	35	153	72	2,000	2,000	75.10	39,810	1.1	3.35	35	153
55.00	0.05	57	2,000	2,000	73.60	38,873	1.1	3.35	37	158	67	2,000	2,000	74.60	38,802	1.1	3.35	37	158
55.00	0.05	47	2,000	2,000	73.10	39,428	0.8	0.49	39	18	62	2,000	2,000	74.10	37,538	0.8	0.47	11	5
55.00	0.10	42	2,000	2,000	70.80	43,784	0.8	0.55	75	41	57	2,000	2,000	71.80	41,878	0.8	0.52	21	11
55.00	0.15	37	2,000	2,000	70.30	44,709	0.8	0.58	109	91	52	2,000	2,000	71.30	42,821	0.8	0.54	29	15
55.00	0.20	32	2,000	2,000	69.80	45,651	0.8	0.57	141	80	47	2,000	2,000	70.80	43,784	0.8	0.55	37	20
55.00	0.25	27	2,000	2,000	69.30	46,594	0.8	0.56	139	81	42	2,000	2,000	70.30	44,709	0.8	0.56	35	20
55.00	0.30	22	2,000	2,000	68.80	47,537	0.8	0.56	119	70	37	2,000	2,000	69.80	45,651	0.8	0.56	33	16
55.00	0.40	17	2,000	2,000	68.30	48,480	0.8	0.56	89	52	32	2,000	2,000	69.30	46,594	0.8	0.56	19	11
55.00	0.45	12	2,000	2,000	67.80	49,424	0.8	0.63	55	34	27	2,000	2,000	68.80	47,537	0.8	0.59	12	7
55.00	0.50	7	2,000	2,000	67.30	50,367	0.8	0.63	38	24	22	2,000	2,000	68.30	48,480	0.8	0.61	9	8
55.00	0.55	2	2,000	2,000	66.80	51,310	0.8	0.64	27	17	17	2,000	2,000	67.80	49,424	0.8	0.62	6	4
55.00	0.60	-3	2,000	2,000	66.30	52,253	0.8	0.65	12	8	12	2,000	2,000	67.30	50,367	0.8	0.63	3	2
55.00	0.65	-8	2,000	2,000	65.80	53,196	0.8	0.66	8	5	7	2,000	2,000	66.80	51,310	0.8	0.64	1	1
55.00	0.70	-13	2,000	2,000	65.30	54,140	0.8	0.68	3	2	2	2,000	2,000	66.30	52,253	0.8	0.65	0	0
55.00	0.75	-18	2,000	2,000	64.80	55,083	0.8	0.68	2	2	-8	2,000	2,000	65.80	53,196	0.8	0.66	1	0
55.00	1.00	-23	2,000	2,000	64.30	56,026	0.8	0.70	1	0	-13	2,000	2,000	64.80	55,083	0.8	0.68	0	0
55.00	1.00	-28	2,000	2,000	63.80	56,969	0.8	0.71	0	0	-18	2,000	2,000	64.30	55,083	0.8	0.68	0	0

CFM 2000
Correction Factor 0.9432
Existing Cooling Usage (kWh): 2,403
Existing Heating Usage (Therms): 495
Cooling Savings (kWh): 1,226
Heating Savings (Therms): 376

MODELING NOTES

ARAPAHOE COUNTY - PEORIA SHOPS

ECM Run: Install a New EMCS/Programmable Thermostats

Fan System	Item Changed	Previous Run Input	Current Run Input
Rm 1 (UHs & MAUs)	Heating Driftpoint	70F	55F
Rm 2 (RTU-3)	Heating Driftpoint	70F	55F
Rm 3 (RTU-1 & RTU-2)	Cooling Driftpoint	75F	95F
	Heating Driftpoint	70F	55F

NOTE: The units above shall cycle on during the occupied period to maintain the space temperature setpoint as governed by the existing space thermostat. The units above shall cycle on during the unoccupied period to maintain the night setback temperatures above as governed by the new EMCS or programmable thermostat.

Previous Run (New Lighting Run):

Annual kWh Usage:	194,579
Annual kW Usage:	773
Annual Therms Usage:	24,278

Current Run (Install New EMCS/Prog Tstat Run):


Annual kWh Usage:	186,287
Annual kW Usage:	778
Annual Therms Usage:	12,476

Savings (Install New EMCS/Prog Tstat Savings):

Annual kWh Savings:	8,292
Annual kW Savings:	-5
Annual Therms Savings:	11,801

Notes:

1. The negative kW savings is the result of all of the unit heaters coming on at once in the mornings due to the schedule change. These negative savings shall not be accounted for since the upgraded EMCS shall heat each space up gradually.



ECM 5 – Replace the Existing Chillers and Cooling Tower

Please refer to the Energy Conservation Measure (ECM) section of this report for additional information.

Existing Condition to Warrant an ECM Opportunity:

Currently, cooling is provided to building 01-Administration Building by two water-cooled, reciprocating chillers that have heat recovery capabilities. Each chiller is equipped with two different condensers. The first condenser is piped to a cooling tower which transfers the heat generated in the building to the outdoors. The second condenser is piped to the building's hot water system which transfers the heat generated in the building to the hot water return line, preheating the hot water before it re-enters the boilers. This type of chilled water system works best when there is a need for chilled water throughout the entire winter, which is not the case at this facility. The four main air handling units in this building are equipped with air-side economizers which can be utilized during the winter to provide cooling, instead of the chillers. This type of chilled water system has caused some operational problems due to the complexity of the system. For example, the hot water return water flows through the heat recovery condenser at all times, there are no valves installed to enable the hot water return to bypass the condenser. This causes the chiller to operate in heat recovery mode whenever the hot water pumps are running, which may not always be the ideal time for the heat recovery condenser to be running. The chiller operates at a lower efficiency using the heat recovery condenser since the water temperature entering the condenser is a lot hotter than the water coming from the cooling tower, thus causing the chiller to consume more energy. The chillers have also reached the end of their useful lives and their efficiencies have started to deteriorate. The cooling tower has reached the end of its useful life too. This ECM concerns replacing the existing chillers and cooling tower. The two new chillers shall be high efficient, water-cooled chillers.

Savings Calculation Methodology:

The implementation of this ECM shall result in positive electrical savings and negative natural gas savings. The savings for this ECM were calculated utilizing two Trane Trace building energy simulation models. The first model included the existing heat recovery chillers and the second model was modified to include the new high efficient chillers. The annual energy consumption calculated from each model was subtracted from one another to produce the annual energy savings. The negative natural gas savings reflects the effects of the heat recovery chiller no longer being used to preheat the hot water return.

Figure 1

Arapahoe County - Admin I Building
Computer Model Calibration for Electric Energy Use

ELECTRIC ENERGY USAGE (kWh)		
Month	BASELINE	MODEL
Jan	217,183	160,605
Feb	189,788	145,184
Mar	229,311	168,223
Apr	218,456	194,211
May	243,374	236,417
Jun	248,088	246,541
Jul	270,700	246,323
Aug	264,710	258,730
Sep	243,348	223,995
Oct	232,915	230,945
Nov	220,561	174,307
Dec	216,466	156,768
	2,794,900	2,442,249
		13%





Figure 2

Arapahoe County - Admin I Building
Computer Model Calibration for Natural Gas

NATURAL GAS USAGE (Therms)		
Month	BASELINE	MODEL
Jan	5,080	6,648
Feb	4,650	5,870
Mar	3,950	6,011
Apr	3,550	3,128
May	2,140	1,521
Jun	1,740	449
Jul	1,010	353
Aug	1,390	443
Sep	2,220	1,421
Oct	4,110	2,921
Nov	4,850	5,181
Dec	4,870	6,142
	39,560	40,089
		-1%



MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe County - Admin I - Match

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric	On-Pk Cons. (kWh)	160,605	145,184	168,223	194,211	236,417	246,541	246,323	258,730	223,995	230,945	174,307	2,442,249
	On-Pk Demand (kW)	410	410	410	648	665	673	684	676	665	664	575	684
Gas	On-Pk Cons. (therms)	6,648	5,870	6,011	3,128	1,521	449	353	443	1,421	2,921	5,181	40,089
	On-Pk Demand (therms/hr)	38	39	38	36	35	6	2	3	35	36	37	39
Water	Cons. (1000gal)	0	0	0	104	215	258	298	281	197	155	24	1,533
Building Energy Consumption = 110,260 Btu/(ft2-year)													
Source Energy Consumption = 261,072 Btu/(ft2-year)													
Floor Area = 111,956 ft2													

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe County - Admin I - Lighting Run

		Monthly Energy Consumption												Total
Utility		Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	
Electric	On-Pk Cons. (kWh)	140,796	127,277	147,458	172,897	212,943	223,527	222,829	233,874	199,514	211,337	138,488	137,436	2,168,375
	On-Pk Demand (kW)	358	358	358	586	593	609	619	612	607	600	358	358	619
Gas	On-Pk Cons. (therms)	6,751	5,968	6,114	3,168	1,499	476	353	465	1,708	2,917	5,907	6,238	41,562
	On-Pk Demand (therms/hr)	37	37	37	35	34	6	2	3	35	35	36	37	37
Water	Cons. (1000gal)	0	0	0	91	197	236	277	260	179	145	0	0	1,385
Building Energy Consumption =		103,227 Btu/(ft2-year)												
Source Energy Consumption =		237,407 Btu/(ft2-year)												
Floor Area =		111,956 ft2												

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe County - Admin I - EMCS Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kW/h)	130,120	117,639	137,067	149,284	177,616	184,908	184,820	196,456	161,483	176,125	128,253	126,618	1,870,390
On-Pk Demand (kW)	358	358	358	586	616	638	646	636	614	600	358	358	646
Gas													
On-Pk Cons. (therms)	4,845	4,278	3,815	1,265	415	388	353	405	353	1,373	3,805	4,449	25,743
On-Pk Demand (therms/hr)	37	37	36	34	12	2	2	2	2	31	36	37	37
Water													
Cons. (1000gal)	0	0	0	70	145	186	200	210	124	103	0	0	1,037
Building Energy Consumption = 80,013 Btu/(ft2-year)													
Source Energy Consumption = 195,278 Btu/(ft2-year)													
Floor Area = 111,956 ft2													

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe County - Admin I - Chiller Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
---------	-----	-----	-----	-----	-----	------	------	-----	------	-----	-----	-----	-------

Electric

On-Pk Cons. (kWh)	130,120	117,639	137,067	137,608	162,083	169,765	170,264	180,497	148,025	153,040	128,253	126,618	1,760,979
On-Pk Demand (kW)	358	358	358	457	569	585	588	585	566	465	358	358	588

Gas

On-Pk Cons. (therms)	4,845	4,278	3,815	1,442	477	388	353	405	419	2,048	3,805	4,449	26,723
On-Pk Demand (therms/hr)	37	37	36	34	12	2	2	2	4	31	36	37	37

Water

Cons. (1000gal)	0	0	0	61	130	170	184	193	111	92	0	0	940
-----------------	---	---	---	----	-----	-----	-----	-----	-----	----	---	---	-----

Building Energy Consumption =
Source Energy Consumption =
Floor Area =

77,553 Btu/(ft2-year)
186,192 Btu/(ft2-year)
111,956 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe County - Admin I - Boiler Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	131,144	118,565	138,188	138,242	162,302	169,765	170,264	180,497	148,163	153,880	129,276	127,593	1,767,880
On-Pk Demand (kW)	362	362	362	461	569	585	588	585	566	469	362	362	588
Gas													
On-Pk Cons. (therms)	4,335	3,829	3,426	1,318	467	388	353	405	412	1,858	3,414	3,982	24,186
On-Pk Demand (therms/hr)	33	33	32	30	11	2	2	2	3	27	32	33	33
Water													
Cons. (1000gal)	0	0	0	61	130	170	184	193	111	92	0	0	940
Building Energy Consumption =													
Source Energy Consumption =	75,497 Btu/(ft2-year)												
Floor Area =	184,439 Btu/(ft2-year)												
	111,956 ft2												

MODELING NOTES

ARAPAHOE COUNTY - ADMIN I BUILDING

ECM Run: Install New EMCS

Fan System	Item Changed	Previous Run Input	Current Run Input
AH-1	Fan Schedule	M-F: 5am-11pm; Sat-Sun: 8am-4pm	M-F: 6am-6:30pm; Sat-Sun: Off
AH-2	Fan Schedule	M-F: 5am-11pm; Sat-Sun: 8am-4pm	M-F: 6am-6:30pm; Sat-Sun: Off
AH-3	Fan Schedule	M-F: 5am-11pm; Sat-Sun: 8am-4pm	M-F: 6am-6:30pm; Sat-Sun: Off
AH-4	Fan Schedule	M-F: 5am-11pm; Sat-Sun: 8am-4pm	M-F: 6am-6:30pm; Sat-Sun: Off

Previous Run (New Lighting Run):

Annual kWh Usage: 2,168,375
Annual kW Usage: 6,016
Annual Therms Usage: 41,562

Current Run (Install New EMCS Run):

Annual kWh Usage: 1,870,390
Annual kW Usage: 6,125
Annual Therms Usage: 25,743

Savings (Install New EMCS Savings):

Annual kWh Savings: 297,985
Annual kW Savings: -109
Annual Therms Savings: 15,819

Notes:

1. The negative kW savings is the result of the chiller have to work harder in the mornings due to the schedule change. These negative savings shall not be accounted for since the upgraded EMCS shall cool each space down gradually without having to "overload" the chillers in the morning.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

Admin I - DHW Pump EMCS Savings

Pump ID:	HP:	LF:	Efficiency:	kW:	Existing Run Hrs:	New Run Hrs:	kWh Savings:
DHWP-1	0.17	0.75	0.7	0.13	8,760	3,259	733
HX Pump	0.25	0.75	0.7	0.20	8,760	3,259	1,099
Total kWh Savings:							1,832

Note: The existing run hours are 24 h/d, 7 d/w. The new run hours are 12.5 h/d, 5 d/w. These savings shall be added to the EMCS savings that were calculated in the Trane Trace building simulation model.

MODELING NOTES

ARAPAHOE COUNTY - ADMIN I BUILDING

ECM Run: Replace the Existing Chillers

Cooling Equipment Tag	Item Changed	Previous Run Input	Current Run Input
Heat Recovery Chillers	Equipment Type	Water-Cooled Recip Chiller w/ Ht. Rec. (Clg.-1 kW/ton @ 260 Tons, Ht. Rec.-1.35 kW/ton @ 220 Tons)	New Admin I Chiller (0.625 kW/ton @ 100% Load)

Previous Run (New EMCS Run):

Annual kWh Usage: 1,870,390
Annual kW Usage: 6,125
Annual Therms Usage: 25,743

Current Run (Replace the Existing Chillers Run):

Annual kWh Usage: 1,760,979
Annual kW Usage: 5,606
Annual Therms Usage: 26,723


Savings (Replace the Existing Chillers Savings):

Annual kWh Savings: 109,411
Annual kW Savings: 519
Annual Therms Savings: -980

Notes:

1. The negative therms savings is the result of the heat recovery chiller no longer being used to preheat the hot water return. So, now the boiler has to burn more natural gas to account for this. These negative savings shall not be accounted for since the heat recovery system no longer functions properly.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73



ECM 6 – Replace the Existing Natural Gas-Fired Boilers

Please refer to the Energy Conservation Measure (ECM) section of this report for additional information.

Existing Condition to Warrant an ECM Opportunity:

The majority of the hot water boilers used for heating in the Arapahoe County facilities are natural gas-fired, atmospheric boilers. Atmospheric boilers aren't the most efficient boilers available. Also, these boilers are beginning to reach the end of their useful lives. This ECM concerns replacing each of the atmospheric boilers with a more efficient natural gas-fired, forced draft boiler.

Savings Calculation Methodology:

The implementation of this ECM shall result in positive natural gas savings and negative electrical savings. The savings for this ECM were calculated utilizing two Trane Trace building energy simulation models. The first model included the existing atmospheric boiler and the second model was modified to include the new forced draft boiler. The annual energy consumption calculated from each model was subtracted from one another to produce the annual energy savings. The negative electrical savings reflects the energy usage of the new boiler's forced draft fan.

Figure 1

Arapahoe County - Admin I Building
Computer Model Calibration for Electric Energy Use

Month	ELECTRIC ENERGY USAGE (kWh)	
	BASELINE	MODEL
Jan	217,183	160,605
Feb	189,788	145,184
Mar	229,311	168,223
Apr	218,456	194,211
May	243,374	236,417
Jun	248,088	246,541
Jul	270,700	246,323
Aug	264,710	258,730
Sep	243,348	223,995
Oct	232,915	230,945
Nov	220,561	174,307
Dec	216,466	156,768
	2,794,900	2,442,249
		13%





Figure 2

Arapahoe County - Admin I Building
Computer Model Calibration for Natural Gas

Month	NATURAL GAS USAGE (Therms)	
	BASELINE	MODEL
Jan	5,080	6,648
Feb	4,650	5,870
Mar	3,950	6,011
Apr	3,550	3,128
May	2,140	1,521
Jun	1,740	449
Jul	1,010	353
Aug	1,390	443
Sep	2,220	1,421
Oct	4,110	2,921
Nov	4,850	5,181
Dec	4,870	6,142
	39,560	40,089
		-1%



MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe County - Admin I - Match

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	160,605	145,184	168,223	194,211	236,417	246,541	246,323	258,730	223,995	230,945	174,307	156,768	2,442,249
On-Pk Demand (kW)	410	410	410	648	665	673	684	676	665	664	575	410	684
Gas													
On-Pk Cons. (therms)	6,648	5,870	6,011	3,128	1,521	449	353	443	1,421	2,921	5,181	6,142	40,089
On-Pk Demand (therms/hr)	38	39	38	36	35	6	2	3	35	36	37	38	39
Water													
Cons. (1000gal)	0	0	0	104	215	258	298	281	197	155	24	0	1,533
Building Energy Consumption =	110,260 Btu/(ft2-year)												
Source Energy Consumption =	261,072 Btu/(ft2-year)												
Floor Area =	111,956 ft2												

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe County - Admin I - Lighting Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	140,796	127,277	147,458	172,897	212,943	223,527	222,829	233,874	199,514	211,337	138,488	137,436	2,168,375
On-Pk Demand (kW)	358	358	358	586	593	609	619	612	607	600	358	358	619
Gas													
On-Pk Cons. (therms)	6,751	5,968	6,114	3,168	1,499	476	353	465	1,708	2,917	5,907	6,238	41,562
On-Pk Demand (therms/hr)	37	37	37	35	34	6	2	3	35	35	36	37	37
Water													
Cons. (1000gal)	0	0	0	91	197	235	277	260	179	145	0	0	1,385
Building Energy Consumption =													
Source Energy Consumption =									103,227	Btu/(ft2-year)			
Floor Area =									237,407	Btu/(ft2-year)			
									111,956	ft2			

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe County - Admin I - EMCS Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	130,120	117,639	137,067	149,284	177,616	184,908	184,820	196,456	161,483	176,125	128,253	126,618	1,870,390
On-Pk Demand (kW)	358	358	358	586	616	638	646	636	614	600	358	358	646
Gas													
On-Pk Cons. (therms)	4,845	4,278	3,815	1,255	415	388	353	405	353	1,373	3,805	4,449	25,743
On-Pk Demand (therms/hr)	37	37	36	34	12	2	2	2	2	31	36	37	37
Water													
Cons. (1000gal)	0	0	0	70	145	186	200	210	124	103	0	0	1,037

Building Energy Consumption = 80,013 Btu/(ft2-year)
Source Energy Consumption = 195,278 Btu/(ft2-year)
Floor Area = 111,956 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe County - Admin I - Chiller Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	130,120	117,539	137,067	137,608	162,083	169,765	170,264	180,497	148,025	153,040	128,253	126,618	1,760,979
On-Pk Demand (kW)	358	358	358	457	569	585	588	585	566	465	358	358	588
Gas													
On-Pk Cons. (therms)	4,845	4,278	3,815	1,442	477	388	353	405	419	2,048	3,805	4,449	26,723
On-Pk Demand (therms/hr)	37	37	36	34	12	2	2	2	4	31	36	37	37
Water													
Cons. (1000gal)	0	0	0	61	130	170	184	193	111	92	0	0	940
Building Energy Consumption =													
Source Energy Consumption =													
Floor Area =													
			77,553	Btu/(ft2-year)									
			186,192	Btu/(ft2-year)									
			111,956	ft2									

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 Arapahoe County - Admin I - Boiler Run

----- Monthly Energy Consumption -----											
Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Total
Electric	On-Pk Cons. (kWh)	131,144	118,565	138,188	138,242	162,302	169,765	170,264	180,497	148,163	1,767,880
	On-Pk Demand (kW)	362	362	362	461	569	585	588	585	469	588
Gas	On-Pk Cons. (therms)	4,335	3,829	3,426	1,318	467	388	353	405	412	24,186
	On-Pk Demand (therms/hr)	33	33	32	30	11	2	2	2	3	33
Water	Cons. (1000gal)	0	0	0	61	130	170	184	193	111	940
Building Energy Consumption = 75,497 Btu/(ft2-year)											
Source Energy Consumption = 184,439 Btu/(ft2-year)											
Floor Area = 111,956 ft2											

MODELING NOTES

ARAPAHOE COUNTY - ADMIN I BUILDING

ECM Run: Install New EMCS

Fan System	Item Changed	Previous Run Input	Current Run Input
AH-1	Fan Schedule	M-F: 5am-11pm; Sat-Sun: 8am-4pm	M-F: 6am-6:30pm; Sat-Sun: Off
AH-2	Fan Schedule	M-F: 5am-11pm; Sat-Sun: 8am-4pm	M-F: 6am-6:30pm; Sat-Sun: Off
AH-3	Fan Schedule	M-F: 5am-11pm; Sat-Sun: 8am-4pm	M-F: 6am-6:30pm; Sat-Sun: Off
AH-4	Fan Schedule	M-F: 5am-11pm; Sat-Sun: 8am-4pm	M-F: 6am-6:30pm; Sat-Sun: Off

Previous Run (New Lighting Run):

Annual kWh Usage: 2,168,375
Annual kW Usage: 6,016
Annual Therms Usage: 41,562

Current Run (Install New EMCS Run):

Annual kWh Usage: 1,870,390
Annual kW Usage: 6,125
Annual Therms Usage: 25,743

Savings (Install New EMCS Savings):

Annual kWh Savings: 297,985
Annual kW Savings: -109
Annual Therms Savings: 15,819

Notes:

1. The negative kW savings is the result of the chiller have to work harder in the mornings due to the schedule change. These negative savings shall not be accounted for since the upgraded EMCS shall cool each space down gradually without having to "overload" the chillers in the morning.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

Admin I - DHW Pump EMCS Savings

Pump ID:	HP:	LF:	Efficiency:	kW:	Existing Run Hrs:	New Run Hrs:	kWh Savings:
DHWP-1	0.17	0.75	0.7	0.13	8,760	3,259	733
HX Pump	0.25	0.75	0.7	0.20	8,760	3,259	1,099

Total kWh Savings: 1,832

Note: The existing run hours are 24 h/d, 7 d/w. The new run hours are 12.5 h/d, 5 d/w. These savings shall be added to the EMCS savings that were calculated in the Trane Trace building simulation model.

MODELING NOTES
ARAPAHOE COUNTY - ADMIN I BUILDING

ECM Run: Replace the Existing Chillers

Cooling Equipment Tag	Item Changed	Previous Run Input	Current Run Input
Heat Recovery Chillers	Equipment Type	Water-Cooled Recip Chiller w/ Ht. Rec. (Clg.-1 kW/ton @ 260 Tons, Ht. Rec.-1.35 kW/ton @ 220 Tons)	New Admin I Chiller (0.625 kW/ton @ 100% Load)

Previous Run (New EMCS Run):

Annual kWh Usage: 1,870,390
Annual kW Usage: 6,125
Annual Therms Usage: 25,743

Current Run (Replace the Existing Chillers Run):

Annual kWh Usage: 1,760,979
Annual kW Usage: 5,606
Annual Therms Usage: 26,723

Savings (Replace the Existing Chillers Savings):

Annual kWh Savings: 109,411
Annual kW Savings: 519
Annual Therms Savings: -980

Notes:

1. The negative therms savings is the result of the heat recovery chiller no longer being used to preheat the hot water return. So, now the boiler has to burn more natural gas to account for this. These negative savings shall not be accounted for since the heat recovery system no longer functions properly.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

MODELING NOTES

ARAPAHOE COUNTY - ADMIN I BUILDING

ECM Run: Replace the Existing Boilers

Cooling Equipment Tag	Item Changed	Previous Run Input	Current Run Input
NG Fired HW Boilers	Equipment Type	Atmospheric Boiler (70% Efficient Energy Rate)	Gas Fired Hot Water Boiler (79% Efficient Energy Rate)

Previous Run (Replace the Existing Chillers Run):

Annual kWh Usage: 1,760,979
Annual kW Usage: 5,606
Annual Therms Usage: 26,723

Current Run (Replace the Existing Boilers Run):

Annual kWh Usage: 1,767,880
Annual kW Usage: 5,634
Annual Therms Usage: 24,186

Savings (Replace the Existing Boilers Savings):

Annual kWh Savings: -6,901
Annual kW Savings: -28
Annual Therms Savings: 2,536

Notes:

1. The negative kW and kWh savings is the energy used by the forced draft burner on the new boiler.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

Figure 1

Arapahoe County - Altura Plaza
Computer Model Calibration for Electric Energy Use

Month	ELECTRIC ENERGY USAGE (kWh)	
	BASELINE	MODEL
Jan	121,594	112,997
Feb	103,244	100,020
Mar	112,618	114,465
Apr	112,883	107,205
May	120,411	113,295
Jun	122,653	116,146
Jul	139,482	122,622
Aug	138,135	125,874
Sep	126,767	109,882
Oct	120,855	112,745
Nov	119,468	107,850
Dec	126,428	107,003
	1,464,538	1,350,104
		8%





Figure 1

Arapahoe County - Altura Plaza
Computer Model Calibration for NG usage

Month	NG USAGE (Therms)	
	BASELINE	MODEL
Jan	18,160	7,038
Feb	11,670	6,450
Mar	5,160	5,962
Apr	5,010	3,362
May	4,150	1,450
Jun	3,700	933
Jul	4,530	186
Aug	6,300	682
Sep	7,530	1,276
Oct	14,900	3,421
Nov	18,330	5,074
Dec	8,440	6,277
	107,880	42,111
		61%



MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 Altura Plaza

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	112,997	100,020	114,485	107,205	113,295	116,146	122,922	125,874	109,862	112,745	107,550	107,003	1,350,105
On-Pk Demand (kW)	445	445	445	445	445	445	445	445	445	445	445	445	445
Gas													
On-Pk Cons. (therms)	7,038	6,450	5,982	3,362	1,450	503	186	682	1,276	3,421	5,074	6,277	42,112
On-Pk Demand (therms/hr)	19	19	17	13	9	7	4	5	8	12	15	18	19
Water													
Cons. (1000gal)	56	43	66	43	92	121	176	152	104	104	72	52	1,031

Building Energy Consumption = 134,046 Btu/(ft2-year)
Source Energy Consumption = 277,511 Btu/(ft2-year)
Floor Area = 65,792 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 Altura Plaza

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
---------	-----	-----	-----	-----	-----	------	------	-----	------	-----	-----	-----	-------

Electric

On-Pk Cons. (kWh)	96,256	84,808	85,876	90,994	95,250	97,213	104,972	106,138	83,140	94,236	90,714	90,718	1,140,374
On-Pk Demand (kW)	364	364	364	364	364	365	366	365	365	365	364	364	366

Gas

On-Pk Cons. (therms)	7,147	6,548	6,042	3,441	1,483	958	186	725	1,301	3,445	5,125	6,373	42,783
On-Pk Demand (therms/hr)	19	19	17	13	9	7	4	5	8	12	15	18	19

Water

Cons. (1000gal)	44	31	53	30	77	104	159	135	80	88	58	39	908
-----------------	----	----	----	----	----	-----	-----	-----	----	----	----	----	-----

Building Energy Consumption = 124,186 Btu/(ft2-year)
 Source Energy Consumption = 245,941 Btu/(ft2-year)
 Floor Area = 65,792 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 Altura Plaza

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	67,188	58,744	68,625	50,875	64,113	67,496	71,397	76,143	81,955	85,341	81,442	81,037	781,398
On-Pk Demand (kW)	364	364	364	364	364	365	368	365	365	365	367	364	367
Gas													
On-Pk Cons. (therms)	5,799	5,391	5,185	1,398	667	378	186	332	588	3,242	4,319	5,233	32,717
On-Pk Demand (therms/hr)	24	25	24	18	16	6	0	8	15	22	23	24	25
Water													
Cons. (1000gal)	33	25	44	27	65	88	120	111	72	68	44	30	725

Building Energy Consumption = 90,280 Btu/(ft2-year)
 Source Energy Consumption = 173,954 Btu/(ft2-year)
 Floor Area = 85,792 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 Altura Plaza

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	67,596	60,139	68,831	57,057	64,174	67,546	71,397	76,169	82,040	65,402	61,558	61,378	783,258
On-Pk Demand (kW)	364	364	364	364	364	365	366	365	365	365	368	364	368
Gas													
On-Pk Cons. (therms)	5,381	5,015	4,872	1,105	551	330	186	287	490	3,119	4,084	4,909	30,348
On-Pk Demand (therms/hr)	20	20	20	14	12	8	0	6	11	18	19	20	20
Water													
Cons. (1000gal)	33	25	44	27	65	88	120	111	72	68	44	30	725

Building Energy Consumption = 86,760 Btu/(ft2-year)
 Source Energy Consumption = 170,463 Btu/(ft2-year)
 Floor Area = 65,782 ft2

MODELING NOTES

ARAPAHOE COUNTY - ALTURA PLAZA

ECM Run: Install New EMCS

Fan System	Item Changed	Previous Run Input	Current Run Input
WSHP	Fan Schedule/Cycle with People	Available 100%	M-F: 6am-6:30pm; Sat-Sun: Off
Pre-Heat WSHP	Fan Schedule/Cycle with People	Available 100%	M-F: 7am-6:30pm; Sat-Sun: Off
Fan Coil	Fan Schedule/Cycle with People	Available 100%	M-F: 7am-6:30pm; Sat-Sun: Off

Previous Run (New Lighting Run):

Annual kWh Usage: 1,140,374
Annual kW Usage: 4,374
Annual Therm Usage: 42,784

Current Run (Install New EMCS Run):

Annual kWh Usage: 781,336
Annual kW Usage: 4,377
Annual Therm Usage: 32,718

Savings (Install New EMCS Savings):

Annual kWh Savings: 359,038
Annual kW Savings: -3
Annual Therm Savings: 10,066

Notes:


1. An additional 65,769 Therms were added to the 10,066 Therms savings shown above. This is a result of the building's existing natural gas usage being way out of line, so much so that we were unable to force our computer model to reflect the building's actual natural gas usage. So, the 65,769 Therms is the difference in the building's actual usage and the computer model's "match usage." Refer to the attached spreadsheet.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

Figure 1

Arapahoe County - Altura Plaza
Computer Model Calibration for NG usage

Month	NG USAGE (Therms)			Adjusted Baseline Savings
	BASELINE	MODEL		
Jan	18,160	7,038	61%	11,122
Feb	11,670	6,450	45%	5,220
Mar	5,160	5,962	-16%	-802
Apr	5,010	3,362	33%	1,648
May	4,150	1,450	65%	2,700
Jun	3,700	933	75%	2,767
Jul	4,530	186	96%	4,344
Aug	6,300	682	89%	5,618
Sep	7,530	1,276	83%	6,254
Oct	14,900	3,421	77%	11,479
Nov	18,330	5,074	72%	13,256
Dec	8,440	6,277	26%	2,163
	107,880	42,111	61%	65,769



MODELING NOTES

ARAPAHOE COUNTY - ALTURA PLAZA

ECM Run: Replace the Existing Boilers

Cooling Equipment Tag	Item Changed	Previous Run Input	Current Run Input
NG Fired HW Boilers	Efficiency	Gas Fired Hot Water Boiler (60% Efficient Energy Rate)	Gas Fired Hot Water Boiler (79% Efficient Energy Rate)

Previous Run (Install New EMCS Run):

Annual kWh Usage: 781,336
Annual kW Usage: 4,377
Annual Therm Usage: 32,718

Current Run (Replace the Existing Boilers Run):

Annual kWh Usage: 783,257
Annual kW Usage: 4,378
Annual Therm Usage: 30,349

Savings (Replace the Existing Boilers Savings):

Annual kWh Savings: -1,921
Annual kW Savings: -1
Annual Therm Savings: 2,369

Notes:

1. The negative kW and kWh savings is the energy used by the forced draft burner on the new boiler.

Electric Savings Safety Factor: 0.73

Natural Gas Savings Safety Factor: 0.73

Figure 1

Arapahoe County - ACJC Courthouse
Computer Model Calibration for Electric Energy Use

Month	ELECTRIC ENERGY USAGE (kWh)	
	BASELINE	MODEL
Jan	202,551	197,435 3%
Feb	172,659	178,589 -3%
Mar	234,751	203,151 13%
Apr	234,674	190,309 19%
May	248,888	221,458 11%
Jun	247,557	224,685 9%
Jul	293,663	238,057 19%
Aug	276,365	238,231 14%
Sep	228,143	211,261 7%
Oct	214,985	213,383 1%
Nov	201,979	192,946 4%
Dec	199,199	194,492 2%
	2,755,414	2,503,997 9%





Figure 1

Arapahoe County - ACJC Courthouse
Computer Model Calibration for NG usage

Month	NG USAGE (Therms)	
	BASELINE	MODEL
Jan	9,680	8,570 11%
Feb	8,870	7,938 11%
Mar	7,540	7,540 0%
Apr	6,710	5,356 20%
May	4,560	3,860 15%
Jun	4,020	2,835 29%
Jul	2,730	1,484 46%
Aug	3,710	2,446 34%
Sep	3,870	3,639 6%
Oct	6,020	5,366 11%
Nov	6,770	7,029 -4%
Dec	8,320	8,374 -1%
	72,800	64,437 11%



MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 ACJC Courthouse

		Monthly Energy Consumption												Total
Utility		Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	
Electric	On-Pk Cons. (kWh)	197,435	178,589	203,151	190,308	221,458	224,885	238,057	238,231	211,281	213,383	192,946	194,492	2,503,985
	On-Pk Demand (kW)	409	409	409	430	486	583	581	574	516	490	409	409	581
Gas	On-Pk Cons. (therms)	8,570	7,938	7,540	5,356	3,860	2,835	1,494	2,446	3,639	5,366	7,029	8,374	64,439
	On-Pk Demand (therms/hr)	45	44	44	44	44	44	44	44	44	44	44	44	45
Water	Cons. (1000gal)	0	0	0	0	82	109	155	132	81	56	0	0	615

Building Energy Consumption = 142,485 Btu/(ft2-year)
 Source Energy Consumption = 308,201 Btu/(ft2-year)
 Floor Area = 105,204 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 ACJC Courthouse

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	172,576	155,952	177,035	166,190	194,041	198,562	208,985	208,391	185,310	186,583	188,343	169,990	2,189,927
On-Pk Demand (kW)	346	346	346	350	415	488	501	491	443	417	346	346	501
Gas													
On-Pk Cons. (therms)	8,695	8,663	7,873	5,455	3,915	2,859	1,436	2,445	3,654	5,460	7,149	8,475	66,319
On-Pk Demand (therms/hr)	42	42	42	42	42	42	42	42	42	42	42	42	42
Water													
Cons. (1000gal)	0	0	0	0	67	90	129	108	65	46	0	0	506
Building Energy Consumption = 133,133 Btu/(ft2-year) Source Energy Consumption = 278,513 Btu/(ft2-year) Floor Area = 105,204 ft2													

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 ACJC Courthouse

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kW/h)	154,194	148,361	158,067	158,423	184,563	186,552	203,494	197,971	175,808	178,072	160,172	162,176	2,087,862
On-Pk Demand (kW)	346	346	346	350	415	468	501	491	443	417	346	346	501
Gas													
On-Pk Cons. (therms)	8,519	7,900	7,409	4,930	3,084	1,916	600	1,394	2,877	4,830	6,839	8,278	58,575
On-Pk Demand (therms/hr)	42	42	42	42	33	13	7	10	31	42	42	42	42
Water													
Cons. (1000gal)	0	0	0	0	65	85	133	104	62	46	0	0	496
Building Energy Consumption =													
Source Energy Consumption =													
Floor Area =													
			123,411	Btu/(ft2-year)									
			261,829	Btu/(ft2-year)									
			105,204	ft2									

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 ACJC Courthouse

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
---------	-----	-----	-----	-----	-----	------	------	-----	------	-----	-----	-----	-------

Electric

On-Pk Cons. (kWh)	165,187	149,258	169,076	159,381	185,535	187,457	204,004	198,853	176,722	179,073	161,138	163,159	2,098,842
On-Pk Demand (kW)	349	349	349	353	417	488	501	481	446	420	349	349	501

Gas

On-Pk Cons. (therms)	7,042	6,530	6,123	4,089	2,570	1,608	527	1,180	2,399	4,007	5,659	6,844	48,583
On-Pk Demand (therms/hr)	35	34	34	34	27	10	6	6	26	34	34	34	35

Water

Cons. (1000gal)	0	0	0	0	65	85	133	104	62	46	0	0	496
-----------------	---	---	---	---	----	----	-----	-----	----	----	---	---	-----

Building Energy Consumption =
Source Energy Consumption =
Floor Area =

114,269 Btu/(ft2-year)
252,900 Btu/(ft2-year)
105,204 ft2

MODELING NOTES

ARAPAHOE COUNTY - ACJC COURTHOUSE

ECM Run: Upgrade Existing EMCS

Fan System	Item Changed	Previous Run Input	Current Run Input
AH-1	Fan Schedule Changed	M-F - 4am-11pm, Sat-Sun: 8am-17pm	M-F: 5:30am-9:30pm; Sat-Sun: 8am-17pm
AHU-1	Fan Schedule Changed	M-F - 4am-11pm, Sat-Sun: 8am-17pm	M-F: 5:30am-9:30pm; Sat-Sun: 8am-17pm
AHU-2	Fan Schedule Changed	M-F - 4am-11pm, Sat-Sun: 8am-17pm	M-F: 5:30am-9:30pm; Sat-Sun: 8am-17pm

Previous Run (New Lighting Run):

Annual kWh Usage: 2,189,928
Annual kW Usage: 4,835
Annual Therm Usage: 65,319

Current Run (Upgrade Existing EMCS Run):

Annual kWh Usage: 2,087,853
Annual kW Usage: 4,835
Annual Therm Usage: 58,576

Savings (Upgrade Existing EMCS Savings):

Annual kWh Savings: 102,075
Annual kW Savings: 0
Annual Therm Savings: 6,743

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

MODELING NOTES

ARAPAHOE COUNTY - ACJC COURTHOUSE

ECM Run: Replace the Existing Boilers

Cooling Equipment Tag	Item Changed	Previous Run Input	Current Run Input
NG Fired HW Boilers	Efficiency	Atmospheric Boiler (65% Efficient Energy Rate)	Gas Fired Hot Water Boiler (79% Efficient Energy Rate)

Previous Run (Upgrade Existing EMCS Run):

Annual kWh Usage: 2,087,853
Annual kW Usage: 4,835
Annual Therm Usage: 58,576

Current Run (Replace the Existing Boilers Run):

Annual kWh Usage: 2,098,843
Annual kW Usage: 4,861
Annual Therm Usage: 48,584

Savings (Replace the Existing Boilers Savings):

Annual kWh Savings: -10,990
Annual kW Savings: -26
Annual Therm Savings: 9,992

Notes:

1. The negative kW and kWh savings is the energy used by the forced draft burner on the new boiler.

Electric Savings Safety Factor: 0.73

Natural Gas Savings Safety Factor: 0.73

Figure 1

Arapahoe County - ACJC Admin II Building
Computer Model Calibration for Electric Energy Use

Month	ELECTRIC ENERGY USAGE (kWh)	
	BASELINE	MODEL
Jan	149,668	117,519
Feb	123,955	106,449
Mar	137,823	125,967
Apr	166,962	120,398
May	183,024	150,964
Jun	185,588	161,275
Jul	204,313	170,641
Aug	202,649	178,772
Sep	187,481	141,905
Oct	170,057	141,498
Nov	153,399	115,011
Dec	152,731	111,523
	2,017,650	1,641,920
		19%





Figure 2

Arapahoe County - ACJC Admin II Building
Computer Model Calibration for Natural Gas

Month	NATURAL GAS USAGE (Therms)	
	BASELINE	MODEL
Jan	3,292	2,762
Feb	2,623	2,527
Mar	2,661	2,629
Apr	1,611	1,677
May	1,342	1,242
Jun	773	1,001
Jul	650	672
Aug	841	999
Sep	897	1,175
Oct	977	1,842
Nov	2,320	2,343
Dec	3,238	2,547
	21,225	21,417
		-1%



MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 ACJC Admin II - Match Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	117,519	106,449	125,967	120,398	150,964	161,275	170,641	178,772	141,905	141,498	115,011	111,523	1,641,920
On-Pk Demand (kW)	370	371	363	420	455	470	530	508	478	446	349	349	530
Gas													
On-Pk Cons. (therms)	2,762	2,527	2,629	1,677	1,242	1,001	672	999	1,175	1,842	2,343	2,547	21,417
On-Pk Demand (therms/hr)	12	12	11	10	9	9	7	9	9	10	10	12	12
Building Energy Consumption = 95,541 Btu/(ft2-year) Source Energy Consumption = 235,198 Btu/(ft2-year) Floor Area = 81,071 ft2													

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 ACJC Admin II - Lighting Run

		----- Monthly Energy Consumption -----													
Utility		Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total	
Electric	On-Pk Cons. (kWh)	103,095	93,293	110,380	103,857	132,054	140,854	152,364	156,782	124,987	123,969	100,353	97,688	1,439,677	
	On-Pk Demand (kW)	330	331	330	369	404	418	477	455	427	391	309	323	477	
Gas	On-Pk Cons. (therms)	2,888	2,646	2,781	1,803	1,335	1,077	724	1,079	1,261	1,963	2,476	2,675	22,709	
	On-Pk Demand (therms/hr)	13	13	12	10	10	9	9	9	9	10	11	12	13	
Building Energy Consumption =		88,621 Btu/(ft2-year)													
Source Energy Consumption =		211,331 Btu/(ft2-year)													
Floor Area =		81,071 ft2													

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 ACJC Admin II - EMCS Run

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	101,636	91,993	108,591	102,210	128,575	137,751	150,090	154,105	121,916	122,297	98,669	96,267	1,414,100
On-Pk Demand (kW)	330	331	330	370	404	426	476	458	427	396	309	323	476
Gas													
On-Pk Cons. (therms)	2,685	2,462	2,516	1,558	1,087	852	580	841	1,041	1,696	2,227	2,465	20,011
On-Pk Demand (therms/hr)	12	13	12	10	7	6	5	6	8	10	11	12	13
Building Energy Consumption = 84,215 Btu/(ft2-year)													
Source Energy Consumption = 204,596 Btu/(ft2-year)													
Floor Area = 81,071 ft2													

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 ACJC Admin II - New Boiler Run

		Monthly Energy Consumption												
Utility		Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric	On-Pk Cons. (kWh)	102,620	92,871	109,497	102,881	129,228	138,360	150,581	154,695	122,547	123,036	99,480	97,162	1,422,959
	On-Pk Demand (kW)	333	333	332	373	406	428	476	458	430	399	311	325	476
Gas	On-Pk Cons. (therms)	2,353	2,157	2,206	1,368	957	752	514	743	916	1,489	1,953	2,160	17,568
	On-Pk Demand (therms/hr)	11	11	10	9	6	5	4	5	7	8	9	11	11
Building Energy Consumption =		81,575 Btu/(ft2-year)												
Source Energy Consumption =		202,544 Btu/(ft2-year)												
Floor Area =		81,071 ft2												

MODELING NOTES**ARAPAHOE COUNTY - ACJC ADMIN II BUILDING**

ECM Run: Upgrade Existing EMCS

Fan System	Item Changed	Previous Run Input	Current Run Input
AHU-1	Fan Schedule	M-F: 7am-10:30pm; Sat-Sun: OFF	M-F: 7am-8:30pm; Sat-Sun: OFF
AHU-2	Fan Schedule	M-F: 5:30am-10:30pm; Sat-Sun: OFF	M-F: 5:30am-8:30pm; Sat-Sun: OFF
AHU-4	Fan Schedule	M-F: 7am-10:45pm; Sat-Sun: OFF	M-F: 7am-8:30pm; Sat-Sun: OFF
AHU-6	Fan Schedule	M-F: 7am-11pm; Sat-Sun: 8am-5pm	M-F: 7am-8:30pm; Sat-Sun: 8am-5pm

Previous Run (New Lighting Run):

Annual kWh Usage: 1,439,677
Annual kW Usage: 4,563
Annual Therms Usage: 22,709

Current Run (Upgrade Existing EMCS Run):

Annual kWh Usage: 1,414,100
Annual kW Usage: 4,581
Annual Therms Usage: 20,011

Savings (Upgrade Existing EMCS Savings):

Annual kWh Savings: 25,577
Annual kW Savings: -18
Annual Therms Savings: 2,699

Notes:

1. The negative kW savings is the result of the chiller have to work harder in the mornings due to the schedule change. These negative savings shall not be accounted for since the upgraded EMCS shall cool each space down gradually without having to "overload" the chillers in the morning.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

MODELING NOTES

ARAPAHOE COUNTY - ACJC ADMIN II BUILDING

ECM Run: Replace the Existing Boilers

Cooling Equipment Tag	Item Changed	Previous Run Input	Current Run Input
HW Boilers	Equipment Type	Atmospheric Boiler (69% Efficient Energy Rate)	Gas Fired Hot Water Boiler (79% Efficient Energy Rate)

Previous Run (Upgrade Existing EMCS Run):

Annual kWh Usage: 1,414,100
Annual kW Usage: 4,581
Annual Therms Usage: 20,011

Current Run (Replace the Existing Boilers Run):

Annual kWh Usage: 1,422,959
Annual kW Usage: 4,605
Annual Therms Usage: 17,568

Savings (Replace the Existing Boilers Savings):


Annual kWh Savings: -8,859
Annual kW Savings: -24
Annual Therms Savings: 2,443

Notes:

1. The negative kW and kWh savings is the energy used by the forced draft burner on the new boiler.

Electric Savings Safety Factor: 0.73

Natural Gas Savings Safety Factor: 0.73



ECM 7– Install a New VFD on the Existing Exhaust Fan

Please refer to the Energy Conservation Measure (ECM) section of this report for additional information.

Existing Condition to Warrant an ECM Opportunity:

The two main air handling systems (AH-3 and AH-4) at building 01-Administration Building are variable air volume (VAV) reheat systems. The supply fans on each unit are equipped with variable frequency drives (VFD's) that modulate the speed of the fan in accordance to the building's heating/cooling load. But, the exhaust/return fan on each unit is constant volume – it operates at 100% of its capacity at all times. The installation of a VFD on the exhaust/return fan shall enable the fan to operate in the same manner as the supply fan.

Savings Calculation Methodology:

The implementation of this ECM shall result in electrical savings. The first step in the savings calculation was to determine what the heating and cooling loads are for each air handling unit. These loads were calculated utilizing a Trane Trace building simulation model. Once the loads were calculated then the new exhaust/return fan energy (with the VFD installed) required at each load condition was calculated. The new fan energy consumption was then subtracted from the existing fan energy consumption.

Install VFD on AH-3 Return/Exhaust Fan Savings Calculation

Total Run Hours (6am to 6:30pm, M-F): 3,259
 % Total Cooling Run Hours: 0.49
 % Total Heating Run Hours: 0.51

Cooling Period Electric Savings

Percent Design Load:	Capacity (Tons):	Run Hours (%):	Run Hours:	Exist. Fan kW:	New Fan kW:	kW Savings:	kWh Savings:
0 - 5	5.79	0	0	6.51	0.59	5.92	0
5 - 10	11.58	0	0	6.51	0.59	5.92	0
10 - 15	17.37	0	0	6.51	0.59	5.92	0
15 - 20	23.15	0	0	6.51	0.59	5.92	0
20 - 25	28.94	0	0	6.51	0.59	5.92	0
25 - 30	34.73	0	0	6.51	0.59	5.92	0
30 - 35	40.52	0	0	6.51	0.59	5.92	0
35 - 40	46.31	0	0	6.51	0.59	5.92	0
40 - 45	52.1	0	0	6.51	0.59	5.92	0
45 - 50	57.89	0	0	6.51	0.81	5.70	0
50 - 55	63.67	0	0	6.51	1.08	5.43	0
55 - 60	69.46	2	32	6.51	1.41	5.10	163
60 - 65	75.25	26	416	6.51	1.79	4.72	1,966
65 - 70	81.04	18	288	6.51	2.23	4.28	1,232
70 - 75	86.83	10	160	6.51	2.75	3.76	602
75 - 80	92.62	13	208	6.51	3.33	3.18	661
80 - 85	98.41	3	48	6.51	4.00	2.51	121
85 - 90	104.19	6	96	6.51	4.75	1.76	169
90 - 95	109.98	8	128	6.51	5.58	0.93	119
95 - 100	115.77	15	240	6.51	6.51	0.00	0

Total Cooling Period kWh Savings: 5,034

Heating Period Electric Savings

Percent Design Load:	Capacity (Btu/Hr):	Run Hours (%):	Run Hours:	Exist. Fan kW:	New Fan kW:	kW Savings:	kWh Savings:
0 - 5	-65,602	12	199	6.51	0.59	5.92	1,177
5 - 10	-131,204	7	116	6.51	0.59	5.92	687
10 - 15	-196,806	7	116	6.51	0.59	5.92	687
15 - 20	-262,408	15	249	6.51	0.59	5.92	1,472
20 - 25	-328,010	11	182	6.51	0.59	5.92	1,079
25 - 30	-393,612	10	166	6.51	0.59	5.92	981
30 - 35	-459,214	8	133	6.51	0.59	5.92	785
35 - 40	-524,817	5	83	6.51	0.59	5.92	491
40 - 45	-590,419	3	50	6.51	0.59	5.92	294
45 - 50	-656,021	2	33	6.51	0.81	5.70	189
50 - 55	-721,623	3	50	6.51	1.08	5.43	270
55 - 60	-787,225	0	0	6.51	1.41	5.10	0
60 - 65	-852,827	0	0	6.51	1.79	4.72	0
65 - 70	-918,429	0	0	6.51	2.23	4.28	0
70 - 75	-984,031	0	0	6.51	2.75	3.76	0
75 - 80	-1,049,633	1	17	6.51	3.33	3.18	53
80 - 85	-1,115,235	2	33	6.51	4.00	2.51	83
85 - 90	-1,180,837	0	0	6.51	4.75	1.76	0
90 - 95	-1,246,439	1	17	6.51	5.58	0.93	15
95 - 100	-1,312,041	12	199	6.51	6.51	0.00	0

Total Heating Period kWh Savings: 8,262

TOTAL KWH SAVINGS: 13,296

Install VFD on AH-4 Return/Exhaust Fan Savings Calculation

Total Run Hours (6am to 6:30pm, M-F): 3,259
 % Total Cooling Run Hours: 0.49
 % Total Heating Run Hours: 0.51

Cooling Period Electric Savings

Percent Design Load:	Capacity (Tons):	Run Hours (%):	Run Hours:	Exist. Fan kW:	New Fan kW:	kW Savings:	kWh Savings:
0 - 5	4.86	0	0	6.51	0.59	5.92	0
5 - 10	9.72	0	0	6.51	0.59	5.92	0
10 - 15	14.57	0	0	6.51	0.59	5.92	0
15 - 20	19.43	0	0	6.51	0.59	5.92	0
20 - 25	24.29	0	0	6.51	0.59	5.92	0
25 - 30	29.15	0	0	6.51	0.59	5.92	0
30 - 35	34.01	0	0	6.51	0.59	5.92	0
35 - 40	38.87	0	0	6.51	0.59	5.92	0
40 - 45	43.72	0	0	6.51	0.59	5.92	0
45 - 50	48.58	0	0	6.51	0.81	5.70	0
50 - 55	53.44	0	0	6.51	1.08	5.43	0
55 - 60	58.3	1	16	6.51	1.41	5.10	82
60 - 65	63.16	23	371	6.51	1.79	4.72	1,750
65 - 70	68.02	12	193	6.51	2.23	4.28	827
70 - 75	72.87	13	209	6.51	2.75	3.76	788
75 - 80	77.73	7	113	6.51	3.33	3.18	358
80 - 85	82.59	9	145	6.51	4.00	2.51	364
85 - 90	87.45	3	48	6.51	4.75	1.76	85
90 - 95	92.31	9	145	6.51	5.58	0.93	134
95 - 100	97.16	23	371	6.51	6.51	0.00	0

Total Cooling Period kWh Savings: 4,389

Heating Period Electric Savings

Percent Design Load:	Capacity (Btu/Hr):	Run Hours (%):	Run Hours:	Exist. Fan kW:	New Fan kW:	kW Savings:	kWh Savings:
0 - 5	-54,819	5	82	6.51	0.59	5.92	487
5 - 10	-109,639	7	115	6.51	0.59	5.92	682
10 - 15	-164,458	11	181	6.51	0.59	5.92	1,072
15 - 20	-219,277	15	247	6.51	0.59	5.92	1,462
20 - 25	-274,096	18	297	6.51	0.59	5.92	1,755
25 - 30	-328,916	12	198	6.51	0.59	5.92	1,170
30 - 35	-383,735	6	99	6.51	0.59	5.92	585
35 - 40	-438,554	3	49	6.51	0.59	5.92	292
40 - 45	-493,374	1	16	6.51	0.59	5.92	97
45 - 50	-548,193	3	49	6.51	0.81	5.70	282
50 - 55	-603,012	0	0	6.51	1.08	5.43	0
55 - 60	-657,831	1	16	6.51	1.41	5.10	84
60 - 65	-712,651	0	0	6.51	1.79	4.72	0
65 - 70	-767,470	2	33	6.51	2.23	4.28	141
70 - 75	-822,289	1	16	6.51	2.75	3.76	62
75 - 80	-877,109	1	16	6.51	3.33	3.18	52
80 - 85	-931,928	0	0	6.51	4.00	2.51	0
85 - 90	-986,747	0	0	6.51	4.75	1.76	0
90 - 95	-1,041,566	0	0	6.51	5.58	0.93	0
95 - 100	-1,096,386	14	231	6.51	6.51	0.00	0

Total Heating Period kWh Savings: 8,226

TOTAL KWH SAVINGS: 12,615


Trane Trace Load Profiles Used to Calculate Return/Exhaust Fan VFD Savings at Admin I

AH-3 Htg. & Clg. Load Profile

Percent	---- Cooling Load ----	----- Heating Load -----	----- Cooling Airflow -----	----- Heating Design -----	Cap.
0 - 5	5.8	0	14	0	0
5 - 10	11.6	-131,204.1	9	0	0
10 - 15	17.4	-196,806.2	7	0	0
15 - 20	23.2	-262,408.3	14	0	0
20 - 25	28.9	-328,010.3	10	0	0
25 - 30	34.7	-393,612.4	9	0	0
30 - 35	40.5	-459,214.4	3	0	0
35 - 40	46.3	-524,816.5	8	0	0
40 - 45	52.1	-590,418.6	0	0	0
45 - 50	57.9	-656,020.6	2	0	0
50 - 55	63.7	-721,622.7	0	0	0
55 - 60	69.5	-787,224.8	0	0	0
60 - 65	75.3	-852,826.8	1	0	0
65 - 70	81.0	-918,428.9	1	0	0
70 - 75	86.8	-984,030.9	0	0	0
75 - 80	92.6	-1,049,633.0	2	2,948	0
80 - 85	98.4	-1,115,235.1	1	30	0
85 - 90	104.2	-1,180,837.1	1	15	0
90 - 95	110.0	-1,246,439.3	0	19	0
95 - 100	115.8	-1,312,041.3	16	277	0
Hours Off	0.0	0.0	6,885	5,471	8,760

AH-4 Htg. & Clg. Load Profile

Percent	---- Cooling Load ----	----- Heating Load -----	----- Cooling Airflow -----	----- Heating Design -----	Cap.
0 - 5	4.9	-54,819.3	7	0	0
5 - 10	9.7	-109,638.6	5	0	0
10 - 15	14.6	-164,457.8	11	0	0
15 - 20	19.4	-219,277.1	14	0	0
20 - 25	24.3	-274,096.4	16	0	0
25 - 30	29.2	-328,915.7	12	0	0
30 - 35	34.0	-383,735.0	5	0	0
35 - 40	38.9	-438,554.3	3	0	0
40 - 45	43.7	-493,373.5	1	0	0
45 - 50	48.6	-548,192.8	1	0	0
50 - 55	53.4	-603,012.1	0	0	0
55 - 60	58.3	-657,831.4	2	0	0
60 - 65	63.2	-712,650.7	1	0	0
65 - 70	68.0	-767,469.9	1	0	0
70 - 75	72.9	-822,289.3	0	0	0
75 - 80	77.7	-877,108.5	0	0	0
80 - 85	82.6	-931,927.8	1	2,889	0
85 - 90	87.5	-986,747.1	0	56	0
90 - 95	92.3	-1,041,566.4	1	30	0
95 - 100	97.2	-1,096,385.6	17	314	0
Hours Off	0.0	0.0	7,098	5,471	-760



ECM 8 – Install a VFD on Existing Vane Axial Fan

Please refer to the Energy Conservation Measure (ECM) section of this report for additional information.

Existing Condition to Warrant an ECM Opportunity:

The two main air handling systems (AHU-1 and AHU-2) at building 35-ACJC Courthouse are variable air volume (VAV) reheat systems. The supply and return fans on each unit are vane axial fans that modulate the airflow in accordance to the building's heating/cooling load. These two air handling systems are also equipped with evaporative heat recovery systems. The coils and evaporative cooling pads in the heat recovery system have "scaled up" so bad that the fans have to operate at nearly 100% of their capacity at all times in order to provide enough air pressure to deliver the appropriate amount of air. The maintenance staff has recently cleaned up the heat recovery system so that the fans don't have to operate at 100% capacity at all times anymore. This ECM concerns recognizing the energy savings that have resulted from the cleaning of the coils and pads. Also, a VFD shall be installed on each fan motor and the existing vanes shall be locked in the 100% open position.

Savings Calculation Methodology:

The implementation of this ECM shall result in electrical savings. The first step in the savings calculation was to determine what the heating and cooling loads are for each air handling unit. These loads were calculated utilizing a Trane Trace building simulation model. Once the loads were calculated then the new supply and return fan energy (with the VFD installed) required at each load condition was calculated. The new fan energy consumption was then subtracted from the existing fan energy consumption.

Install VFD on AHU-1 Supply/Return Fan Savings Calculation

Total Run Hours (5am to 9:30pm, M-F, 8am-5pm): 4,849
 % Total Cooling Run Hours: 0.34
 % Total Heating Run Hours: 0.66

Supply Fan Cooling Period Electric Savings

Percent Design Load:	Capacity (Tons):	Run Hours (%)	Run Hours	Exist. SF Max kW:	Exist. SF kW:	New SF kW:	SF kW Savings:	Supply Fan kWh Savings:	Exist. RF kW:	Exist. RF kW:	RF kW Savings:	Return Fan kWh Savings:
0-5	4.67	0	0	61.48	39.35	5.60	33.75	0	18.86	13.62	1.72	11.91
5-10	9.34	0	0	61.48	39.35	5.60	33.75	0	18.86	13.62	1.72	11.91
10-15	14	0	0	61.48	39.35	5.60	33.75	0	18.86	13.62	1.72	11.91
15-20	18.67	0	0	61.48	39.35	5.60	33.75	0	18.86	13.62	1.72	11.91
20-25	23.34	0	0	61.48	39.35	5.60	33.75	0	18.86	13.62	1.72	11.91
25-30	28.01	0	0	61.48	39.35	5.60	33.75	0	18.86	13.62	1.72	11.91
30-35	32.68	0	0	61.48	39.35	5.60	33.75	0	18.86	13.62	1.72	11.91
35-40	37.34	0	0	61.48	39.35	5.60	33.75	0	18.86	13.62	1.72	11.91
40-45	42.01	0	0	61.48	39.35	5.60	33.75	0	18.86	13.62	1.72	11.91
45-50	46.68	0	0	61.48	39.35	7.69	31.66	0	18.86	13.62	2.35	11.27
50-55	51.35	0	0	61.48	39.35	10.23	29.12	0	18.86	13.62	3.14	10.49
55-60	56.01	1	16	61.48	39.35	13.28	26.07	425	18.86	13.62	4.07	9.55
60-65	60.68	5	81	61.48	39.35	16.88	22.47	1,829	18.86	13.62	5.18	8.45
65-70	65.35	11	179	61.48	39.35	21.09	18.26	3,271	18.86	13.62	6.47	7.16
70-75	70.02	46	749	61.48	39.35	25.94	13.41	10,046	18.86	13.62	7.96	5.67
75-80	74.69	16	261	61.48	39.35	31.48	7.87	2,050	18.86	13.62	9.66	3.97
80-85	79.35	6	130	61.48	44.41	37.75	6.66	868	18.86	13.62	11.58	2.04
85-90	84.02	3	49	61.48	49.79	44.81	4.98	243	18.86	15.28	13.75	1.53
90-95	88.69	3	49	61.48	55.48	52.71	2.78	136	18.86	17.02	16.17	0.65
95-100	93.36	7	114	61.48	61.48	61.48	0.00	0	18.86	18.86	18.86	0.00
Total Cooling Period kWh Savings:								18,868	7,786			

Heating Period Electric Savings

Percent Design Load:	Capacity (Btu/HR):	Run Hours (%)	Run Hours	Exist. SF Max kW:	Exist. SF kW:	New Fan kW:	kW Savings:	Supply Fan kWh Savings:	Exist. RF kW:	Exist. RF kW:	RF kW Savings:	Return Fan kWh Savings:
0-5	-68,871	9	290	61.48	39.35	5.60	33.74	9,782	18.86	13.63	1.72	11.91
5-10	-137,743	9	290	61.48	39.35	5.60	33.74	9,782	18.86	13.63	1.72	11.91
10-15	-206,614	10	322	61.48	39.35	5.60	33.74	10,866	18.86	13.63	1.72	11.91
15-20	-275,486	11	354	61.48	39.35	5.60	33.74	11,956	18.86	13.63	1.72	11.91
20-25	-344,357	14	451	61.48	39.35	5.60	33.74	15,217	18.86	13.63	1.72	11.91
25-30	-413,229	9	290	61.48	39.35	5.60	33.74	9,782	18.86	13.63	1.72	11.91
30-35	-482,100	4	129	61.48	39.35	5.60	33.74	4,349	18.86	13.63	1.72	11.91
35-40	-550,971	7	225	61.48	39.35	5.60	33.74	7,603	18.86	13.63	1.72	11.91
40-45	-619,843	5	161	61.48	39.35	5.60	33.74	5,435	18.86	13.63	1.72	11.91
45-50	-688,714	5	161	61.48	39.35	7.69	31.66	5,099	18.86	13.63	2.36	11.27
50-55	-757,586	1	32	61.48	39.35	10.23	29.12	938	18.86	13.63	3.14	10.49
55-60	-826,457	1	32	61.48	39.35	13.28	26.07	840	18.86	13.63	4.07	9.55
60-65	-895,328	2	64	61.48	39.35	16.88	22.46	1,447	18.86	13.63	5.18	8.45
65-70	-964,200	1	32	61.48	39.35	21.09	18.26	568	18.86	13.63	6.47	7.16
70-75	-1,033,071	0	0	61.48	39.35	25.94	13.41	0	18.86	13.63	7.96	5.67
75-80	-1,101,943	1	32	61.48	39.35	31.48	7.87	253	18.86	13.63	9.66	3.97
80-85	-1,170,814	1	32	61.48	44.42	37.76	6.66	215	18.86	13.63	11.58	2.04
85-90	-1,239,686	0	0	61.48	49.80	44.82	4.98	0	18.86	15.28	13.75	1.53
90-95	-1,308,557	10	322	61.48	55.49	52.71	2.77	894	18.86	17.02	16.17	0.85
95-100	-1,377,428	0	0	61.48	61.48	61.48	0.00	0	18.86	18.86	18.86	0.00
Total Heating Period kWh Savings:								95,054	33,620			

TOTAL KWH SAVINGS FOR AHU-1: 155,328

Install VFD on AHU-2 Supply/Return Fan Savings Calculation

Total Run Hours (5am to 9:30pm, M-F, 8am-5pm): 4,849
 % Total Cooling Run Hours: 0.33
 % Total Heating Run Hours: 0.67

Cooling Period Electric Savings

Percent Design Load:	Capacity (Tons):	Run Hours (%)	Run Hours	Exist. SF Max kW:	Exist. SF kW:	New SF kW:	kW Savings:	Supply Fan kWh Savings:	Exist. RF Max kW:	Exist. RF kW:	RF kW Savings:	Return Fan kWh Savings:
0 - 5	4.94	0	0	61.48	44.41	5.60	38.81	0	18.86	13.62	1.72	11.91
5 - 10	9.88	0	0	61.48	44.41	5.60	38.81	0	18.86	13.62	1.72	11.91
10 - 15	14.82	0	0	61.48	44.41	5.60	38.81	0	18.86	13.62	1.72	11.91
15 - 20	19.75	0	0	61.48	44.41	5.60	38.81	0	18.86	13.62	1.72	11.91
20 - 25	24.69	0	0	61.48	44.41	5.60	38.81	0	18.86	13.62	1.72	11.91
25 - 30	29.63	0	0	61.48	44.41	5.60	38.81	0	18.86	13.62	1.72	11.91
30 - 35	34.57	0	0	61.48	44.41	5.60	38.81	0	18.86	13.62	1.72	11.91
35 - 40	39.51	0	0	61.48	44.41	5.60	38.81	0	18.86	13.62	1.72	11.91
40 - 45	44.45	0	0	61.48	44.41	5.60	38.81	0	18.86	13.62	1.72	11.91
45 - 50	49.39	0	0	61.48	44.41	5.60	38.81	0	18.86	13.62	1.72	11.91
50 - 55	54.32	0	0	61.48	44.41	5.60	38.81	0	18.86	13.62	1.72	11.91
55 - 60	59.26	0	0	61.48	44.41	5.60	38.81	0	18.86	13.62	1.72	11.91
60 - 65	64.2	2	32	61.48	44.41	16.88	27.53	883	18.86	13.62	5.18	8.45
65 - 70	69.14	2	32	61.48	44.41	21.09	23.33	748	18.86	13.62	6.47	7.16
70 - 75	74.08	7	112	61.48	44.41	25.94	18.48	2,075	18.86	13.62	7.96	5.67
75 - 80	79.02	19	305	61.48	44.41	31.48	12.93	3,942	18.86	13.62	9.66	3.97
80 - 85	83.95	34	545	61.48	44.41	37.75	6.66	3,635	18.86	13.62	11.58	2.04
85 - 90	88.89	16	257	61.48	49.80	44.81	4.98	1,276	18.86	15.28	13.75	1.53
90 - 95	93.83	7	112	61.48	55.48	52.71	2.78	312	18.86	17.02	16.17	0.85
95 - 100	98.77	12	192	61.48	61.48	61.48	0.00	0	18.86	18.86	18.86	0.00
Total Cooling Period kWh Savings:								12,873	3,949			

Heating Period Electric Savings


Percent Design Load:	Capacity (Tons):	Run Hours (%)	Run Hours	Exist. SF Max kW:	Exist. SF kW:	New SF kW:	kW Savings:	Supply Fan kWh Savings:	Exist. RF Max kW:	Exist. RF kW:	RF kW Savings:	Return Fan kWh Savings:
0 - 5	54.819	5	162	61.48	44.42	5.60	38.82	6,298	18.86	13.63	1.72	11.91
5 - 10	109.639	7	227	61.48	44.42	5.60	38.82	8,818	18.86	13.63	1.72	11.91
10 - 15	164.458	11	357	61.48	44.42	5.60	38.82	13,056	18.86	13.63	1.72	11.91
15 - 20	219.277	15	487	61.48	44.42	5.60	38.82	18,995	18.86	13.63	1.72	11.91
20 - 25	274.096	18	584	61.48	44.42	5.60	38.82	22,674	18.86	13.63	1.72	11.91
25 - 30	328.916	12	369	61.48	44.42	5.60	38.82	15,116	18.86	13.63	1.72	11.91
30 - 35	383.735	6	185	61.48	44.42	5.60	38.82	7,558	18.86	13.63	1.72	11.91
35 - 40	438.554	3	97	61.48	44.42	5.60	38.82	3,779	18.86	13.63	1.72	11.91
40 - 45	493.374	1	32	61.48	44.42	5.60	38.82	1,260	18.86	13.63	1.72	11.91
45 - 50	548.193	3	97	61.48	44.42	7.69	36.73	3,576	18.86	13.63	2.36	11.27
50 - 55	603.012	0	0	61.48	44.42	10.23	34.19	0	18.86	13.63	3.14	10.49
55 - 60	657.831	1	32	61.48	44.42	13.28	31.14	1,011	18.86	13.63	4.07	9.55
60 - 65	712.651	0	0	61.48	44.42	16.88	27.54	0	18.86	13.63	5.18	8.45
65 - 70	767.470	2	65	61.48	44.42	21.09	23.33	1,514	18.86	13.63	6.47	7.16
70 - 75	822.289	1	32	61.48	44.42	25.94	18.48	600	18.86	13.63	7.96	5.67
75 - 80	877.109	1	32	61.48	44.42	31.48	12.94	420	18.86	13.63	9.66	3.97
80 - 85	931.928	0	0	61.48	44.42	37.76	6.66	0	18.86	13.63	11.58	2.04
85 - 90	986.747	0	0	61.48	49.80	44.82	4.98	0	18.86	15.28	13.75	1.53
90 - 95	1,041.566	0	0	61.48	55.49	52.71	2.77	0	18.86	17.02	16.17	0.85
95 - 100	1,096.386	13	422	61.48	61.48	61.48	0.00	0	18.86	18.86	18.86	0.00
Total Heating Period kWh Savings:								105,374	32,325			

TOTAL KWH SAVINGS FOR AHU-2: 154,521

Trane Trace Load Profiles for AHU-1 & AHU-2 at the ACJC Courthouse

AHU-1 Htg. & Clg. Load Profile

Percent Design Load	---- Cooling Load ----			---- Heating Load ----			---- Cooling Airflow ---			---- Heating Airflow----		
	Cap. (Tons)	Hours (%)	Hours	Cap. (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	4.67	0	0	-68871.42	9	320	4632.72	0	0	1309.43	8	293
5 - 10	9.34	0	0	-137742.84	9	339	9265.45	0	0	2618.87	9	327
10 - 15	14	0	0	-206614.27	10	354	13898.17	0	0	3928.3	10	352
15 - 20	18.67	0	0	-275485.69	11	393	18530.89	0	0	5237.74	7	270
20 - 25	23.34	0	0	-344357.09	14	505	23163.62	0	0	6547.17	12	457
25 - 30	28.01	0	0	-413228.53	9	342	27796.34	0	0	7856.61	11	393
30 - 35	32.68	0	0	-482099.94	4	151	32429.06	0	0	9166.04	8	288
35 - 40	37.34	0	0	-550971.38	7	251	37061.79	0	0	10475.48	5	166
40 - 45	42.01	0	0	-619842.75	5	164	41694.51	0	0	11784.91	6	208
45 - 50	46.68	0	0	-688714.19	5	184	46327.23	0	0	13094.35	5	170
50 - 55	51.35	0	0	-757585.62	1	44	50959.96	0	0	14403.78	3	127
55 - 60	56.01	1	22	-826457.06	1	32	55592.68	0	0	15713.22	1	31
60 - 65	60.68	5	87	-895328.44	2	60	60225.41	0	0	17022.65	1	32
65 - 70	65.35	11	193	-964199.88	1	31	64858.13	0	0	18332.09	2	60
70 - 75	70.02	46	851	-1033071.31	0	12	69490.85	0	0	19641.52	1	31
75 - 80	74.69	16	294	-1101942.75	1	38	74123.58	0	0	20950.96	0	12
80 - 85	79.35	8	154	-1170814.12	1	19	78756.3	93	4483	22260.39	1	38
85 - 90	84.02	3	56	-1239685.5	0	18	83389.02	2	80	23569.83	1	19
90 - 95	88.69	3	49	-1308557	10	365	88021.75	2	81	24879.26	0	8
95 - 100	93.36	7	125	-1377428.37	0	0	92654.47	3	159	26188.7	10	375
Hours Off	0	0	6929	0	0	5138	0	0	3957	0	0	5103
			1,831			3,622						
						5,453						



ECM 10-- Install an A/C Unit to Serve Computer Equipment Room

Please refer to the Energy Conservation Measure (ECM) section of this report for additional information.

Existing Condition to Warrant an ECM Opportunity:

Currently, there are multiple computer equipment rooms located throughout building 37-ACJC Administrative II that require cooling 24 hours a day, seven days a week. So, two of the building's main air handling units (AHU-3 and AHU-5) have to operate at all times in order to provide cooling to these rooms. The installation of individual A/C units to serve each room will eliminate the need to operate the two main air handling systems 24 hours a day, seven days a week.

Savings Calculation Methodology:

The implementation of this ECM shall result in both electrical and natural gas savings. Two different Trane Trace building energy simulation models were developed to calculate the energy savings for this ECM. The first model was developed to reflect the existing energy used by AHU-3 and AHU-5 to provide cooling to the computer equipment rooms at all times. The second model was created to reflect the energy used by individual A/C units (air-cooled, split systems) to provide cooling to the computer equipment rooms. The annual energy consumption calculated from each model was subtracted from one another to produce the annual energy savings.

Figure 1

Arapahoe County - ACJC Admin II Building
Computer Model Calibration for Electric Energy Use

ELECTRIC ENERGY USAGE (kWh)		
Month	BASELINE	MODEL
Jan	149,668	117,519 21%
Feb	123,955	106,449 14%
Mar	137,823	125,967 9%
Apr	166,962	120,398 28%
May	183,024	150,964 18%
Jun	185,588	161,275 13%
Jul	204,313	170,641 16%
Aug	202,649	178,772 12%
Sep	187,481	141,905 24%
Oct	170,057	141,498 17%
Nov	153,399	115,011 25%
Dec	152,731	111,523 27%
	2,017,650	1,641,920 19%





Figure 2

Arapahoe County - ACJC Admin II Building
Computer Model Calibration for Natural Gas

NATURAL GAS USAGE (Therms)		
Month	BASELINE	MODEL
Jan	3,292	2,762 16%
Feb	2,623	2,527 4%
Mar	2,661	2,629 1%
Apr	1,611	1,677 -4%
May	1,342	1,242 7%
Jun	773	1,001 -30%
Jul	650	672 -3%
Aug	841	999 -19%
Sep	897	1,175 -31%
Oct	977	1,842 -89%
Nov	2,320	2,343 -1%
Dec	3,238	2,547 21%
	21,225	21,417 -1%



MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 ACJC Admin II - Match Run

Utility Jan Feb Mar Apr May June July Aug Sept Oct Nov Dec Total

Electric

On-Pk Cons. (kWh) 117,519 106,449 125,967 120,398 150,964 161,275 170,641 178,772 141,905 141,498 115,011 111,523 1,641,920
On-Pk Demand (kW) 370 371 363 420 455 470 530 508 478 446 349 349 530

Gas

On-Pk Cons. (therms) 2,762 2,527 2,629 1,677 1,242 1,001 672 999 1,175 1,842 2,343 2,547 21,417
On-Pk Demand (therms/hr) 12 12 11 10 9 9 7 9 9 10 10 12 12

Building Energy Consumption =
Source Energy Consumption =
Floor Area =

95,541 Btu/(ft2-year)
235,198 Btu/(ft2-year)
81,071 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 ACJC Admin II - Lighting Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	103,095	93,293	110,380	103,857	132,054	140,854	152,364	156,782	124,987	123,969	100,353	97,688	1,439,677
On-Pk Demand (kW)	330	331	330	369	404	418	477	455	427	391	309	323	477
Gas													
On-Pk Cons. (therms)	2.888	2.646	2.781	1.803	1.335	1.077	724	1,079	1,261	1,963	2,476	2,675	22,709
On-Pk Demand (therms/hr)	13	13	12	10	10	9	9	9	9	10	11	12	13
Building Energy Consumption =			88,621	Btu/(ft2-year)									
Source Energy Consumption =			211,331	Btu/(ft2-year)									
Floor Area =			81,071	ft2									

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 ACJC Admin II - EMCS Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	101,636	91,993	108,591	102,210	128,575	137,751	150,090	154,105	121,916	122,297	98,669	96,267	1,414,100
On-Pk Demand (kW)	330	331	330	370	404	426	476	458	427	396	309	323	476
Gas													
On-Pk Cons. (therms)	2,685	2,462	2,516	1,558	1,087	852	580	841	1,041	1,696	2,227	2,465	20,011
On-Pk Demand (therms/hr)	12	13	12	10	7	6	5	6	8	10	11	12	13
Building Energy Consumption =													
Source Energy Consumption =													
Floor Area =													

84,215 Btu/(ft2-year)
204,596 Btu/(ft2-year)
81,071 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 ACJC Admin II - New Boiler Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	102,620	92,871	109,497	102,881	129,228	138,360	150,581	154,695	122,547	123,036	99,480	97,162	1,422,959
On-Pk Demand (kW)	333	333	332	373	406	428	476	458	430	399	311	325	476
Gas													
On-Pk Cons. (therms)	2,353	2,157	2,206	1,368	957	752	514	743	916	1,489	1,953	2,160	17,568
On-Pk Demand (therms/hr)	11	11	10	9	6	5	4	5	7	8	9	11	11
Building Energy Consumption =													
Source Energy Consumption =													
Floor Area =													
			81,575	81,575	81,575	81,575	81,575	81,575	81,575	81,575	81,575	81,575	81,575
			202,544	202,544	202,544	202,544	202,544	202,544	202,544	202,544	202,544	202,544	202,544
			81,071	81,071	81,071	81,071	81,071	81,071	81,071	81,071	81,071	81,071	81,071

MONTHLY ENERGY CONSUMPTION

By Release 2.007

Alternative: 1 ACJC Admin II - New A/C Unit Run

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	101,970	92,318	109,079	100,610	122,947	131,522	137,542	145,021	114,520	120,309	99,115	96,496	1,371,450
On-Pk Demand (kW)	338	338	337	368	407	441	488	465	425	385	317	330	488
Gas													
On-Pk Cons. (therms)	2,154	1,978	1,989	1,075	590	406	202	389	593	1,188	1,782	1,995	14,341
On-Pk Demand (therms/hr)	10	11	10	9	6	5	3	4	6	8	9	10	11
Building Energy Consumption =													
Source Energy Consumption =	75,427 Btu/(ft2-year)												
Floor Area =	191,848 Btu/(ft2-year)												
	81,071 ft2												

MODELING NOTES

ARAPAHOE COUNTY - ACJC ADMIN II BUILDING

ECM Run: Upgrade Existing EMCS

Fan System	Item Changed	Previous Run Input	Current Run Input
AHU-1	Fan Schedule	M-F: 7am-10:30pm; Sat-Sun: OFF	M-F: 7am-8:30pm; Sat-Sun: OFF
AHU-2	Fan Schedule	M-F: 5:30am-10:30pm; Sat-Sun: OFF	M-F: 5:30am-8:30pm; Sat-Sun: OFF
AHU-4	Fan Schedule	M-F: 7am-10:45pm; Sat-Sun: OFF	M-F: 7am-8:30pm; Sat-Sun: OFF
AHU-6	Fan Schedule	M-F: 7am-11pm; Sat-Sun: 8am-5pm	M-F: 7am-8:30pm; Sat-Sun: 8am-5pm

Previous Run (New Lighting Run):

Annual kWh Usage: 1,439,677
Annual kW Usage: 4,563
Annual Therms Usage: 22,709

Current Run (Upgrade Existing EMCS Run):

Annual kWh Usage: 1,414,100
Annual kW Usage: 4,581
Annual Therms Usage: 20,011

Savings (Upgrade Existing EMCS Savings):

Annual kWh Savings: 25,577
Annual kW Savings: -18
Annual Therms Savings: 2,699

Notes:

1. The negative kW savings is the result of the chiller have to work harder in the mornings due to the schedule change. These negative savings shall not be accounted for since the upgraded EMCS shall cool each space down gradually without having to "overload" the chillers in the morning.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

MODELING NOTES

ARAPAHOE COUNTY - ACJC ADMIN II BUILDING

ECM Run: Replace the Existing Boilers

Cooling Equipment Tag	Item Changed	Previous Run Input	Current Run Input
HW Boilers	Equipment Type	Atmospheric Boiler (69% Efficient Energy Rate)	Gas Fired Hot Water Boiler (79% Efficient Energy Rate)

Previous Run (Upgrade Existing EMCS Run):

Annual kWh Usage: 1,414,100
Annual kW Usage: 4,581
Annual Therms Usage: 20,011

Current Run (Replace the Existing Boilers Run):

Annual kWh Usage: 1,422,959
Annual kW Usage: 4,605
Annual Therms Usage: 17,568

Savings (Replace the Existing Boilers Savings):

Annual kWh Savings: -8,859
Annual kW Savings: -24
Annual Therms Savings: 2,443

Notes:

1. The negative kW and kWh savings is the energy used by the forced draft burner on the new boiler.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

MODELING NOTES

ARAPAHOE COUNTY - ACJC ADMIN II BUILDING

ECM Run: Install an A/C Unit to Serve the Computer Equipment Room

Fan System/Clg. Equip.	Item Changed	Previous Run Input	Current Run Input
Rm 6 - AHU-3	Cooling Driftpoint	72	90
Rm 8 - AHU-5	Cooling Driftpoint	72	90
Create A New Fan System	System Type Fan Cycling Schedule Fan Schedule	None None None	Computer Room Unit Cycle With Cooling Loads Only Available (100%)
ASSIGN ROOMS 2 & 3 TO THE NEW COMPUTER ROOM UNIT FAN SYSTEM			
AHU-3	Fan Schedule	24 Hours/Day, 7 Days/Week	M-F: 5am-8:30pm; Sat-Sun: OFF
AHU-5	Fan Schedule	24 Hours/Day, 7 Days/Week	M-F: 5am-8:30pm; Sat-Sun: OFF
Create A New Clg. Plant	Equip. Type/Category Energy Rate	None None	Air-Cooled Unitary 1.237 kW/Ton
ASSIGN THE CLG COIL FOR THE NEW COMPUTER ROOM UNIT TO THIS CLG PLANT			

Previous Run (Replace the Existing Boilers Run):

Annual kWh Usage:	1,422,959
Annual kW Usage:	4,605
Annual Therms Usage:	17,568

Current Run (Install New A/C Units Run):

Annual kWh Usage:	1,371,450
Annual kW Usage:	4,638
Annual Therms Usage:	14,341

Savings (Install New A/C Units Savings):


Annual kWh Savings:	51,509
Annual kW Savings:	-34
Annual Therms Savings:	3,227

Notes:

1. The negative kW savings is the energy used by the new A/C units.

Electric Savings Safety Factor: 0.73

Natural Gas Savings Safety Factor: 0.73



ECM 12 – Install Water Softener

Buildings Included –

- ✓ ACJC Administration II
- ✓ ACJC Detention Center
- ✓ ACJC Courthouse

Spreadsheet savings used (see attached).

For the Justice Center (ACJC Courthouse) the building water usage was modeled. The modeling notes can be seen in the ECM 2 section.

The two penthouse air handlers utilize indirect and direct evaporative heat recovery system as well as a direct evaporative cooling section. Cooling is supplemented with a chilled water cooling system that utilizes a cooling tower. The heat recovery system has never worked correctly in either air handler. The hard water has clogged the direct side media with so much mineral the pads have virtually turned to stone. On the indirect side the nozzles have corroded and leaked over the years making this system use an abundance of water. This recovery coils have so much mineral in them it has restricted air flow through them. The maintenance staff has been forced to open the service doors to allow air pressure to be relieved. The heat recovery system has been disabled as of last fall and water usage has plummeted.

The cooling tower has been operating on a 1.7 cycle or virtually a once through water vessel (as confirmed through the service representative). The bleed line was measured at a rate of 4 gallons per minute to confirm. With the implementation of the water softener the cooling tower will be able to operate in excess of 5 cycles thus saving an immense amount of water.

As both of these cases are relatively difficult to calculate savings a baseline comparison method was used. The baseline water usage (Section 2) for this facility was compared to modeled usage. A .7 safety factor was applied to these savings to be conservative.

For the Detention Center a spreadsheet calculation was also used. There are currently sixteen rooftop units that use direct/indirect evaporative cooling. As the case at the Courthouse the nozzles on the indirect side are constantly calcifying and leaking. The direct side media is also filling with mineral at an alarming rate. The staff has cut the overflow pans to constantly allow water to drain in each air handler. This is a tremendous waste of water. It was estimated that approximately 1 gpm of water was being wasted per unit. With the installation of water softeners for the evaporative cooling units the pans will be fixed and blow down controls will be installed on each unit.

Arapahoe County
Dentention Center
Water Softenner Savings

	BILLING DATA Average last year Gallons	Days per month	GPM per Unit	Number of Untis	Total Water Saved kGals
Jan	2,756,486				
Feb	4,021,000				
Mar	4,314,714				
Apr	4,984,286				
May	3,368,529	31	1.0	16	714
June	4,151,471	30	1.0	16	691
Jul	4,564,677	31	1.0	16	714
Aug	4,210,161	31	1.0	16	714
Sep	5,095,161	30	1.0	16	691
Oct	4,572,727	31	1.0	16	714
Nov	3,977,273				
Dec	3,475,000				
	49,491,485				

4,239


- 1) Drian pan of each unit was cut to allow water to "bleed" off.
- 2) Several units were observed to be flowing in excess of 1 gpm.
- 3) With new water softener the pans will be replaced and water will be able to be re-used.
- 4) Above does not include water savings for increaded efficiency of evaporative cooling.


ArapahoeCounty Justice Center

	BILLING DATA Average last year	Work days per month	Sanitary Water Use Model	Kitchen	Non Weather related total	Baseline	Balance	Gallons Saved
Jan	425,622	22	119,038	9,125	128,163	572,173	306,584	45,312
Feb	514,533	20	107,518	9,125	116,643	572,173	407,015	40,927
Mar	565,324	22	119,038	9,125	128,163	572,173	446,286	45,312
Apr	563,143	21	115,198	9,125	124,323	572,173	447,945	43,850
May	383,824	22	119,038	9,125	128,163	572,173	264,786	45,312
June	486,176	21	115,198	9,125	124,323	572,173	370,978	43,850
Jul	667,161	22	119,038	9,125	128,163	572,173	548,123	45,312
Aug	773,075	22	119,038	9,125	128,163	572,173	654,037	45,312
Sep	758,773	21	115,198	9,125	124,323	572,173	643,575	43,850
Oct	689,563	22	119,038	9,125	128,163	572,173	570,525	45,312
Nov	617,494	21	115,198	9,125	124,323	572,173	502,296	43,850
Dec	783,212	22	119,038	9,125	128,163	572,173	664,174	45,312
	7,227,900	261	1,401,571	73,000	1,013,781	6,866,073	5,826,329	533,511

	Non Sanitary Use	Non Sanitary Use Kgal	Ice machine	Evaporative coolers	Laundry	Total	Model Total	Balance (gal)	Model total to billing	Savings From Original Baseline
Jan	306,584	307	0	0	0	0	128,163	297,459	30%	297,459
Feb	407,015	407	0	0	0	0	116,643	397,890	23%	397,890
Mar	446,286	446	0	0	0	0	128,163	437,161	23%	437,161
Apr	447,945	448	0	4,572	0	4,572	128,895	434,248	23%	434,248
May	264,786	265	0	52,579	0	52,579	180,742	203,082	47%	203,082
June	370,978	371	0	308,617	0	308,617	432,940	53,236	89%	53,236
Jul	548,123	548	0	596,659	0	596,659	724,822	-57,661	109%	-57,661
Aug	654,037	654	0	496,073	0	496,073	624,236	148,839	81%	148,839
Sep	643,575	644	0	130,305	0	130,305	254,628	504,145	34%	504,145
Oct	570,525	571	0	0	0	0	128,163	561,400	19%	561,400
Nov	502,296	502	0	0	0	0	124,323	493,171	20%	493,171
Dec	664,174	664	0	0	0	0	128,163	655,049	16%	655,049
	5,826,329	5,826	0	1,588,806	0	1,594,632	3,099,877	4,128,023	43%	4,128,023

1588.805762





ECM 13 – Install Waterside Economizer

Buildings Included –

- ✓ Administration I

Spreadsheet savings used coupled with Bin Data (see attached). The spreadsheets were broken into three parts:

- January through April
- May through October
- November through December

These were broken into three sections as operating variables can change per season in some buildings such as schedule or lock-out temperatures. The intent was to capture all these variables in the most conservative fashion. All variables were received from operations personnel.

Demand savings was only taken in the winter months when little cooling is needed.

Savings was calculated for reduced run times on the chillers. Currently the staff operates the chillers on the following schedule:

Monday through Friday	5:00 AM to 11:00 PM
Saturday and Sunday	8:00 AM to 4:00 PM

This spreadsheet takes into account the benefit of utilizing the plate & frame heat exchanger during low wet bulb conditions or approximately up to 43°WB under certain conditions.

3.0 kW-months
0.0 kW-months (June-Sept)
0.0 Peak kW (July - Sept)

**Arapahoe County
Administration I Building
H2O Economizer**

Assumptions:

- 1) CH-1 and CH-2 operation from 5:00 AM to 7:00 PM and greater than 50 degrees F OA.
- 2) Uses Trace 700 unloading curve.
- 3) Assumes load varies directly with OA temperature.
- 4) Setup load simulated by reduction of OA temp equal to setup differential:
Setup cfm = $\text{MIN}[(\text{OAT} - (\text{Setup T} - \text{Space T}) - \text{Cooling zero load T}), 0] / (\text{Cooling full load T} - \text{Cooling zero load T})$

Basis:

Total Chiller Tonnage: 260
Existing Chiller KW/Ton 0.55
Max WB for Economizer 43

Trace 700 Coefficients:
Coefficient A: 0.0005
Coefficient B: 0.5614
Coefficient C: -1.1412
Coefficient D: 2.2214
Coefficient E: -0.6455

Occupied Load profile characteristics:

Cooling lockout temperature: 50°
Min load: 50%
Cooling full load at: 90°
Cooling min. load at: 60°
Delta: 30°
Weather data: Denver Temperature Bins

First month of cooling season: 1 January
Last month of cooling season: 4 April
Cooling temp. setup ends: 6
Cooling temp. setup begins: 19

Load Adjustments:

Occupied space temperature: 74°
Cooling setup temperature: 85°

Bin Average (°F)	Occupied Cooling Jan-Apr: 6:00-19:00			Unoccupied Cooling Hours (Nov thru Feb)			Savings	
	Cooling (hrs)	AVG WB	Load Profile	CH-1 kW	Cooling (hrs)	AVG WB	Load Profile	CH-1 kW
107.5°	0.0		100%	0.0		0.0	100%	0.0
102.5°	0.0		100%	0.0		0.0	100%	0.0
97.5°	0.0		100%	0.0		0.0	88%	0.0
92.5°	0.0		100%	0.0		0.0	72%	0.0
87.5°	0.0		92%	0.0		0.0	55%	0.0
82.5°	0.0		75%	0.0		0.0	50%	0.0
77.5°	0.0		58%	0.0	0.0	0.0	50%	0.0
72.5°	0.0		50%	0.0	1.0	0.0	50%	0.0
67.5°	0.0		50%	0.0	5.0	0.0	50%	0.0
62.5°	40.6	42.1	50%	71.5	20.0	44.1	50%	71.5
57.5°	64.9	40.0	50%	71.5	4638.6	47.0	50%	71.5
52.5°	147.0	39.1	50%	71.5	10510.5	84.0	50%	71.5
47.5°	173.9	36.7	50%	0.0	146.0	37.5	50%	0.0
42.5°	201.3	34.0	50%	0.0		0.0	50%	0.0
37.5°	195.1	30.8	50%	0.0		0.0	50%	0.0
32.5°	198.9	27.7	50%	0.0		0.0	50%	0.0
27.5°	145.0	23.8	50%	0.0		0.0	50%	0.0
22.5°	95.9	19.5	50%	0.0		0.0	50%	0.0
17.5°	53.5	15.0	50%	0.0		0.0	50%	0.0
1316				303				29,208

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Max DB Bin:	62.5	62.5	62.5										
kW Savings:	71.5	71.5	71.5										214.5

0.0 kW-months (June-Sept)
0.0 Peak kW (July - Sept)

**Arapahoe County
Administration Building
H2O Economizer**

Assumptions:

- 1) CH-1 & CH-2 operation from 5:00 AM to 7:00 PM and greater than 50 degrees F OA.
- 2) Uses Trace 700 unloading curve.
- 3) Assumes load varies directly with OA temperature.
- 4) Setup load simulated by reduction of OA temp equal to setup differential:
Setup cfm = $\text{MIN}[(\text{OAT} - (\text{Setup T} - \text{Space T}) - \text{Cooling zero load T}), 0] / (\text{Cooling full load T} - \text{Cooling zero load T})$

Basis:

Total Chiller Tonnage: 260
Existing Chiller KW/Ton 0.55
Max WB for Economizer 43

Trace 700 Coefficients:
Coefficient A: 0.0005
Coefficient B: 0.5614
Coefficient C: -1.1412
Coefficient D: 2.2214
Coefficient E: -0.6455

Occupied Load profile characteristics:

Cooling lockout temperature: 50°
Min load: 50°
Cooling full load at: 90°
Cooling min. load at: 60°
Delta: 30°

First month of cooling season: 5 May
Last month of cooling season: 10 October
Cooling temp. setup ends: 5
Cooling temp. setup begins: 19
Weather data: Denver Temperature Bins


Load Adjustments:

Occupied space temperature: 74°
Cooling setup temperature: 85°

Bin	Occupied Cooling			May-Oct: 5:00-19:00			Unoccupied Cooling Hours (Nov thru Feb)			Savings		
Average (°F)	Cooling (hrs)	AVG WB	Load Profile	CH-1 kW	kWh	Cooling (hrs)	AVG WB	Load Profile	CH-1 kW	kWh	kWh	kWh
107.5°	0.0		100%	0.0				100%	0.0		0.0	0.0
102.5°	0.0		100%	0.0				100%	0.0		0.0	0.0
97.5°	0.0		100%	0.0				88%	0.0		0.0	0.0
92.5°	0.0		100%	0.0				72%	0.0		0.0	0.0
87.5°	0.0		92%	0.0				55%	0.0		0.0	0.0
82.5°	0.0		75%	0.0				50%	0.0		0.0	0.0
77.5°	0.0		58%	0.0		0.0	0.0	50%	0.0		0.0	0.0
72.5°	0.0		50%	0.0		1.0	0.0	50%	71.5	357.5	357.5	0.0
67.5°	0.0		50%	0.0	0.0	5.0	0.0	50%	71.5	1430.0	1430.0	0.0
62.5°	0.0		50%	0.0	0.0	20.0	44.1	50%	71.5	3360.5	3360.5	0.0
57.5°	0.0		50%	0.0	0.0	47.0	42.0	50%	71.5	6006.0	6006.0	0.0
52.5°	56.5	41.0	50%	71.5	4048.7	84.0	39.8	50%	71.5	10054.7	10054.7	0.0
47.5°	139.0	40.7	50%	0.0	0.0	146.0	37.5	50%	0.0	0.0	0.0	0.0
42.5°	101.6	37.4	50%	0.0	0.0		0.0	50%	0.0	0.0	0.0	0.0
37.5°	57.4	33.2	50%	0.0	0.0		0.0	50%	0.0	0.0	0.0	0.0
32.5°	38.5	29.6	50%	0.0	0.0		0.0	50%	0.0	0.0	0.0	0.0
27.5°	10.3	25.0	50%	0.0	0.0		0.0	50%	0.0	0.0	0.0	0.0
22.5°	3.3	20.5	50%	0.0	0.0		0.0	50%	0.0	0.0	0.0	0.0
17.5°	1.8	16.5	50%	0.0	0.0		0.0	50%	0.0	0.0	0.0	0.0
	408					303					15,203	

Max DB Bin: kW Savings:	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
													0.0

0.0 kW-months
0.0 kW-months (June-Sept)
0.0 Peak kW (July - Sept)



63

ECM 16 – Irrigation Control System Upgrade

Administration Building 1:

The water economy at the Administration Building 1 is divided between sanitation services, cooling tower make up water, ice machine, irrigation and boiler water make up.

Sanitary water use is calculated based on survey observations of fixture type capacity and condition, population levels integrated with schedules.

Because of seasonal variability in water use rates due to cooling tower and irrigation demand, the year round monthly use rate of sanitary water use is assumed to be at the winter month levels when the only other water use is boiler water makeup (which is normally very low) and the ice machine.

The warm weather increase in water use rates is due to the cooling tower and irrigation usage. The seasonal water use by the cooling tower and irrigation is easily discerned from the water use curve. The cooling tower usage was determined by hand calculations using Denver dry bulb and wet bulb historical data and using a psychrometric chart to estimate the evaporative losses. These results were compared to water tower water consumption results in the Trane Trace computer model.

The irrigation use was assumed to be the balance of the water consumption:

$\text{Irrigation Use} = \text{Total Usage} - \text{Sanitary} - \text{HVAC} - \text{Ice Machine.}$
--

Administration Building 1 has 3.1 acres of irrigated landscape. The irrigated areas include lawn and landscaped area near and between the buildings and area bordering the parking lots and entry roadways.

Two Rainmaster Sentar™ RME timers, control the system. The maintenance staff has set up the system so that each zone is set to ensure the lawn area it serves remains green during the summer months. This is a proven method of maintaining turf, but often leads to over watering.

The water use requirements for turf maintenance vary over the summer. For the purposes of this study, precipitation requirements were calculated from the evapotranspiration rates typical to Denver, actual rain data for 2004 with the assumption that turf applied to the lawn is comprised of cool season grasses.

The gallons per day required was calculated by the following formula:

$$\text{Irrigation required (in)} = (\text{ET}_o \times K_c) - \text{Precipitation (in)}$$


ET_o – reference evapotranspiration rate from weather data

K_c – Crop coefficient. A constant applied to correct for the transpiration losses for a particular planting or crop. In this case the “crop” is cool season turf, i.e. eastern bluegrass.

Precipitation – Denver average precipitation

Water savings for this measure is 75% of the difference between the modeled water use and the calculated water requirements of the landscape.

The following chart illustrates the results of the various components of the water model as a stacked area plot; each calculation result is shown as a solid area on the chart and scaled on the left side. The billing data is represented by the solid line and is scaled on the right side. The chart demonstrates that the sum of the models is a well within the billed usage. The ice machine usage was calculated to less than 800 gallons per month and does not show on this chart.



Arapahoe County Domestic Water
Administration Building

Units
S/Facre 43,850
L/Facre side 209
Gall/CF 7,481
Lawn Area 135,191 SF
2000/2010 Acres

Northern Front Range % of July

April	May	June	July	August	September	October
0.90	1.10	1.40	1.40	1.20	0.90	0.60
60%	75%	93%	100%	80%	60%	40%

Colorado Springs % of July

April	May	June	July	August	September	October
0.50	0.75	1.25	1.50	1.39	0.83	0.33
33%	50%	83%	100%	82%	55%	22%

April	May	June	July	August	September	October
3.88	4.93	6.04	6.52	5.47	4.01	7.76
Per month	0.13	0.16	0.2	0.21	0.18	0.13
Per day						

Predicted Irr use 0 gallons
Estimated Irr billing use 0
0

Increase by 30%

Month	Days	ET Required/ week (inches)	ET Required/ month (inches)	Precip (inches)	Kc	Gallons Irrigation
Jan						
Feb						
Mar						
April	30	0.90	2.85	1.70	0.80	145,444
May	31	1.40	4.37	2.40	0.85	177,049
June	30	1.40	4.20	1.90	0.85	177,049
July	31	1.50	4.64	1.90	0.85	300,891
August	31	1.20	3.84	1.90	0.85	339,770
September	30	0.90	2.85	1.50	0.85	273,248
October	31	0.80	2.66	1.20	0.85	189,353
November						118,715
December						154,329
						1545460
						2009098

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual
0.5	0.6	1.3	1.7	2.4	1.8	1.9	1.5	1.2	1.0	0.8	1.4	15.4
6	6	9	9	11	9	9	9	6	5	6	5	89
81	7.5	12.5	8.9	1.6	0	<0.05	<0.05	1.6	3.7	3.1	7.3	60.3

Denver Precipitation
(inches)
Days with Precipitation 0.01 inch or More
Monthly Snowfall (inches)


Precip Days Monthly Snowfall (inches)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual
0.3	6	8	1									
0.6	9	12	5									
1.1	12	17	9	13	9	13	9	13	9	13	9	13
1.7	9	13	9	13	9	13	9	13	9	13	9	13
2.4	11	16										
1.8	9	0										
1.9	9	<0.05										
1.5	9	<0.05										
1.2	6	16										
1.0	5	37										
0.9	6	9	1									
0.6	5	7	3									
15.4	89	60	3									

Denver Precipitation

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual
0.3	6	8	1									
0.6	9	12	5									
1.1	12	17	9	13	9	13	9	13	9	13	9	13
1.7	9	13	9	13	9	13	9	13	9	13	9	13
2.4	11	16										
1.8	9	0										
1.9	9	<0.05										
1.5	9	<0.05										
1.2	6	16										
1.0	5	37										
0.9	6	9	1									
0.6	5	7	3									
15.4	89	60	3									

Admin 1 Irrigation



Arapahoe County Domestic Water
Administration Building

Rainmaster "iCentral" Setup:

All prices off web published pricelist RETAIL pricing.

Labor Rate @ \$50.00

1 man Day

Rep said installation ~ 15 minutes

Trade-in on old panels and discount because we are going to use the old cases not included

Controller

Zones:	36	24	24
Eagle EG	\$0.00	\$1,619.00	\$1,619.00
iCentral	\$0.00	\$795.00	\$795.00
Service Plan	\$0.00	\$275.00	\$275.00
First Year cost	\$0.00	\$2,689.00	\$2,689.00
Grand total	\$5,378.00		
Labor	\$400.00		
Total	\$5,778.00		

Total Estimated Usage (Gals)	2,009,098
Total Required (Gals)	1,545,460
Gallons of over use	463,638
Assume 75% over use can be save by tighter control savings:	347,729
% savings gallons	17%

Rainmaster Rep expects 30% to 40% savings

Gallons of over use	347,729
Rate	\$5.57
Model Overuse:	\$1,937
Assume 50% over use can be save by tighter control	\$968
Annual Service Cost:	\$550

ROI

13.81


years

ECM 16 - Irrigation

Justice Center Irrigation:

I. General:

- A. There are four meters serving the irrigation system at the Justice Center complex. The irrigation system is one network that can be served by any number of four meters feeding the system. As the demand increases, the maintenance staff turns on valves associated with additional meters. All irrigations services share four meters. The meters are read monthly.
- B. Justice Center Building has on a 1,944,000 sqft. (45 acre) parcel. The total area not occupied by buildings or covered with pavement is 25 acres. The building maintenance measured the irrigation area to be 176,000 square feet. The irrigated areas include lawn and landscaped area near and between the buildings and area bordering the parking lots and entry roadways. Areas west of the detention center, north of the north parking lot, and certain areas east of the northeast parking lot and north east of the Administration 1 building are not irrigated.
- C. Three Rainmaster Sentar TM RME timers, 2 with 36 zones and one with 24 zones, control the system. The maintenance staff has set up the system so that each zone is set to ensure the lawn area it serves remains green during the summer months. This is a proven method of maintaining turf, but often leads to over watering.
- D. The water use requirements for turf maintenance vary over the summer. For the purposes of this study, precipitation were requirements calculated from the evapotranspiration rates typical to Denver, actual rain data for 2004 and assuming turf applied to the lawn is comprised of cool season grasses. The following graph shows the moisture requirements relative to the irrigation applied according to the irrigation billing data.



The Gallons per day required was calculated by the following formula:

$$\text{Irrigation required (in)} = (\text{ETo} \times \text{Kc}) - \text{Precipitation (in)}$$

ETo -- reference evapotranspiration rate from weather data

Kc - Crop coefficient. A constant applied to correct for the transpiration losses for a particular planting or crop. In this case the "crop" is cool season turf, i.e. eastern bluegrass.

The second y-axis illustrated rainfall is 2004. There is an indication from the data that some control is being applied to the system in that a drop in the water use rate accompanies the spike in August rainfall. In general, however, there appears to be room for improvement and optimization on the system. The water use rates greatly exceed requirements for most of the season.


- E. There is a 3600 square foot area nearby the day program entry way irrigated using water from the detention center meter with its own timer and controls.

ACJC Complex

Irrigation

Service Charge Calculated\$/gal	26.44 per acct per Kgal	3.305	Less than 25 25 - 200 Greater than 200	2.32
------------------------------------	----------------------------	-------	--	------

Date	1	2	3	4	Total	Kgal/day	
1 1/31/2004 12/25/2003	Kgal \$ 18.56	\$ 26.44	\$ 26.44	\$ 26.44	\$ 97.88	-	\$ (7.88)
2 2/25/2004 1/31/2004	\$ 18.56	\$ 26.44	\$ 26.44	\$ 26.44	\$ 97.88	-	\$ (7.88)
3 3/26/2004 2/25/2004	\$ 18.56	20 \$ 61.44	\$ 26.44	\$ 26.44	\$ 132.88	0.67	\$ 27.12
4 4/30/2004 3/26/2004	\$ 18.56	159 \$ 582.16	16 \$ 49.44	\$ 26.44	\$ 656.60	5.00	\$ 550.84
5 5/26/2004 4/30/2004	\$ 18.56	89 \$ 308.06	95 \$ 329.84	110 \$ 384.29	\$ 1,040.75	11.31	\$ 934.99
6 6/30/2004 5/26/2004	\$ 18.56	293 \$ 1,115.54	244 \$ 902.39	283 \$ 1,072.04	\$ 3,108.53	23.43	\$ 3,002.77
7 7/30/2004 6/30/2004	\$ 18.56	256 \$ 954.59	282 \$ 1,067.69	307 \$ 1,176.44	\$ 3,217.28	28.17	\$ 3,111.52
8 8/30/2004 7/30/2004	\$ 18.56	186 \$ 660.17	207 \$ 741.44	227 \$ 828.44	\$ 2,248.61	20.00	\$ 2,142.85
9 9/30/2004 8/30/2004	\$ 18.56	228 \$ 832.79	245 \$ 906.74	279 \$ 1,054.64	\$ 2,812.73	24.26	\$ 2,706.97
10 10/28/2004 9/30/2004	\$ 18.56	54 \$ 181.01	63 \$ 228.20	67 \$ 228.20	\$ 655.97	6.57	\$ 550.21
11 11/30/2004 10/28/2004	\$ 18.56	\$ 26.44	26 \$ 79.37	\$ 26.44	\$ 150.81	0.79	\$ 45.05
12 12/31/2004 11/30/2004	\$ 18.56	\$ 26.44	16 \$ 49.64	\$ 26.44	\$ 121.08	0.52	\$ 15.32
				\$ 5,019.35	\$ 14,341.00		\$ 3.39
							\$ 6.78



ACIC Complex Irrigation

Units:
SF/acre 43,650
LF/acre side 209
Gal/CF 7.48

Lawn Area 176,200 SF
4.04 Acres

Northern Front Range % of July

April	May	June	July	August	September	October
0.90	1.10	1.40	1.50	1.20	0.90	0.60
60%	73%	93%	100%	80%	60%	40%

Colorado Springs % of July


April	May	June	July	August	September	October
0.50	0.75	1.25	1.50	1.38	0.83	0.33
33%	50%	83%	100%	92%	55%	22%

Per month	April	May	June	July	August	September	October
Per day	3.88	4.93	5.04	5.47	6.52	4.01	2.76
	0.13	0.16	0.2	0.21	0.18	0.13	0.09

Area 2

Month	Days	E.T. Required/ week	E.T. Required/ month	Kc	Historical Precipitation	Precipitation 2004	Required Irrigation Levels	Billing	differential
January	31								
February	30								
March	31			0.8				20,000	0
April	30	0.90	3.88	0.80	1.7	1.76	189,538	175,000	-14,538
May	31	1.10	4.87	0.85	2.4	1.3	230,724	254,000	23,276
June	30	1.40	6.00	0.85	1.8	2.33	392,098	820,000	427,902
July	31	1.50	6.64	0.85	1.9	2.52	442,777	845,000	402,223
August	31	1.20	5.31	0.85	1.5	2.84	356,089	620,000	263,911
September	30	0.90	3.86	0.85	1.2	1.99	248,082	752,000	503,938
October	31	0.60	2.66	0.85	1	0.85	154,705	134,000	-20,705
November	30							26,000	0
December	31							16,000	0
							14	2,013,993	3,690,000
									1,676,007

Crop - cool sear - warm season is Reduced Kc with careful management



ACJC Complex Irrigation

<http://www.crh.noaa.gov/cgi-bin-den/showProduct.pl?title=Denver's+2004+Climatological+Summary&product=annsum04.htm&backto=2>

MAX

	AVG	AVG I	Mon F	Mon t	HIGH	LOW	PRECIF	Snow	HDD	CCD
JAN	45.5	18.2	31.9	29.2	63	-11	0.23	4.6	1022	0
FEB	41.9	19.8	30.9	33.2	67	-9	0.21	8.9	984	0
MAR	62	30.7	46.4	39.6	79	18	0.14	1.8	569	0
APR	59.6	35.4	47.5	47.6	81	23	1.76	15.3	519	0
MAY	73.9	44.7	59.3	57.2	88	28	1.3	0	192	23
JUN	76.9	50.5	63.7	67.6	98	41	2.33	0	99	67
JUL	85	56.7	70.9	73.4	99	49	2.52	0	17	201
AUG	82.4	54	68.2	71.7	96	42	2.84	0	31	137
SEP	77.6	47.7	62.7	62.4	90	37	1.99	0	131	67
OCT	65.6	36.1	50.9	51	79	24	0.86	1.4	431	0
NOV	49	25.2	37.1	37.5	72	-1	0.45	10	831	0
DEC	48.3	21.4	34.9	30.3	67	-9	0.04	2.6	926	0
ANNUAL	64	36.7	50.3	50.1	99	-11	14.67	44.6	5752	495
SEASON								14	2367	

Denver Precipitation

Precipitation (Inches)

Days with Precipitation 0.01 inch or More

Monthly Snowfall (inches)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual
Precipitation (Inches)	0.5	0.6	1.3	1.7	2.4	1.8	1.9	1.5	1.2	1	0.9	0.6	15.4
Days with Precipitation 0.01 inch or More	6	6	9	9	11	9	9	9	6	5	6	5	89
Monthly Snowfall (inches)	8.1	7.5	12.5	8.9	1.6	0	<0.05	<0.05	1.6	3.7	9.1	7.3	60.3

<http://www.climate-zone.com/climate/united-states/colorado/denver/>

Copied and Transposed from above

Denver Precipitation

Precip Days Monthly Snowfall (inches)

	Precip Days	Monthly Snowfall (inches)
Jan	0.5	8.1
Feb	0.6	7.5
Mar	1.3	12.5
Apr	1.7	8.9
May	2.4	1.6
Jun	1.8	0
Jul	1.9	<0.05
Aug	1.5	<0.05
Sep	1.2	1.6
Oct	1	3.7
Nov	0.9	9.1
Dec	0.6	7.3
Annual	15.4	60.3

ACJC Complex
Irrigation

Rainmaster "iCentral" Setup:

All prices off web published pricelist RETAIL pricing.
<http://www.rainmaster.com/PDF/2004TURF-AGPRICELIST.pdf>

Labor Rate @ \$50.00

1 man Day

Rep said installation ~ 15 minutes

Trade-in on old panels and discount because we are going to use the old cases not included


Controller

Zones:	36	36	24
Eagle SCSB	\$2,660.00	\$2,660.00	\$2,265.00
iCentral	\$795.00	\$795.00	\$795.00
Service Plan	\$275.00	\$275.00	\$275.00
First Year cost	\$3,766.00	\$3,766.00	\$3,359.00
Grand total	\$10,891.00		
Labor	\$400.00		
Total	\$11,291.00		

Total Billed Usage (Gals)	3,690,000
Total Required (Gals)	2,013,993
Gallons of over use	1,676,007
Assume 50% over use can be save by tighter control savings:	
% savings gallons	838,004
	23%

Rainmaster Rep expects 30% to 40% savings

Gallons of over use	838,004
Rate	\$6.96
Model Overuse:	\$5,833
Assume 50% over use can be save by tighter control	\$2,916
Annual Service Cost:	\$275



ECM 17 – Programmable Flush Valve Controls

General:

Domestic Water usage for the Detention Center was modeled using population figures, staff, inmates, and visitors, occupancy schedules, fixture usage rates as determined in the survey and average estimates of fixture usage. The model is then compared to the metered usage and reasonable adjustments to the model are made to reflect the metered usage. In general, the fixture rates were adjusted to bring the model rates safely below the metered rates. After matching the water model to the building use, various water conservation scenarios were applied to the model to analyze potential savings.

The water usage is determined by:

$$(\text{Number of People}) \times (\text{Fixture Rate}) \times (\text{Uses per Day}) \times (\text{Days Occupied per Year})$$

Visitor populations were also included. Visitation period was assumed to be for 2 hours for the detention center, and then the population was normalized to an 8 hr day and added to the given population figure using the following formula:

$$(\text{Number of Hours Visitation}) \div (8 \text{ hours}) \times (\text{Visitors/Day}) = \text{Normalized Visitor Population}$$

Fixture use rates:

There were some adjustments made to the fixture rates to bring the modeled usage in line with the metered data. Some of the adjustments were downward (lower GPF). Some were adjusted upward; this is justified as long as all water is accounted for. Maladjusted flush valves and leaking tank valves can account for significant losses. Also, where there was a mix of fixtures, a weighted average was applied to the model, which also lowered the modeled fixture rate.

The following table illustrates the uses per day per person used in the models.

Uses per day	Inmates		Staff		Visitors		Units
	Male	Female	Male	Female	Male	Female	
Toilet	12	12	1	5	1	5	Flushes
Urinal	0	0	4	0	4	0	Flushes
Lav Faucet	1	1	2	2	2	2	Minutes
Shower (M F)		10	0	0	0	0	Minutes

*Based on: "A Water Conservation Guide for Commercial Institutional and Industrial Users", Water Use and Conservation Bureau, New Mexico Office of the State Engineer.

Schedules are considered only to the extent that the days that the buildings are open and the building are populated.

Schedules:

	Office (staff and visitors)	Detention Center
Work days	250	365
Holidays	-10	-10
Vacation	-14	-14
Total	226	341

Population assumptions are listed below:

	Population (1)	Visitors / day (2)	Quantity of toilets
P.J. Sullivan Detention Center	195	163	71
P.J. Sullivan Detention Center (Comby)	1215	0	413
Total			484

(1) Population figures are as given by the Maintenance Staff.

(2) Visitor figures as per Arapahoe County Staff.

The ECM recommended placing programmable flush controls on the existing combination penal units. Savings were calculated by adjusting the 'Uses per day' from 12 per inmate to 8.

Savings =

4,952,530 gallons x .73 (Safety Factor) = 3,615,347 gallons per year

**Arapahoe County Domestic Water
ACJC Detention Center**

292.955

General	037,353
Directly	

Immenses	Population	815	Post ratio
Immenses	163	0.2	
Immenses: Women	62	0.8	
Immenses: Men	101		
Immenses: Total	163		
Immenses: Ratio	0.38		
Start	155	Post ratio	
Population:	117	0.6	
Staff: Women	78	0.4	
Staff: Men	39		
Staff: Total	117		
Staff: Ratio	0.67		
Length of stay: 2008 to 2009: day	156	1.26	

	8/94	3/95	Visitors
Immature	905	355	10
Schedule			14
Total (all days)	25		
Visitors Men conv to prison days	5		
Visitors Women conv to prison days	20		
Visitors Total per day	183		

[illegible]

Future Diversity			Weighted Average
	GFF	Quantity	
Total	1.6	0	1.90
Total	3.5	71	
Comby	3.5	50	1.96
Comby	4	386	
Unval	1	0	2.00
Unval	2	22	

Population:	Pop. nro.
Initiated: Yes	80
Initiated: No	320
Initiated: Total	400
Absent	0.00%

Staff	Population:	1955-01 Pro. ratio
Staff: Women	117	0.6
Staff: Men	78	0.4
Staff: Total	195	
Absent		0.00%
Waiters:		
Length of stay Staff 8 hour day	15%	1.20

	8/94	3/95	Visitors
Immature	905	355	10
Schedule			14
Total (all days)	25		
Visitors Men conv to prison days	5		
Visitors Women conv to prison days	20		
Visitors Total per day	183		

[illegible][illegible]

	Benchmarks	Admin :	Typical Range
	Total Usable / SF	170	25-36
	Usable/SF less Immission		


Sanitary Water Use Summary	Gallons	Gals / person/yr	Gals / SPY	Gals / person / day
Unads Used Pre	24,131,896	17,626.8	117	488
Unads Used Post	1,234,567	900.4	5	19
Unads Used Pre	3,333,333	2,407.4	15	51
Unads Used Post	333,333	240.7	1	5
Soft Usage Pre	65,541	47.5	3	1
Soft Usage Post	65,541	47.5	2	3
Water Usage Pre	190,097	97.5	6	21
Water Usage Post	9,853	4.8	1	1
Gravel Usage Pre	35,653,442	25,653.4	152	522
Gravel Usage Post	29,170	21.2	1	1
Gravel Usage Pre	6,564,472	4,726.8	100	343
Gravel Usage Post	656,447	472.7	4	34
Water Usage Pre	5,112,075	3,672.9	227.2	787
Water Usage Post	5,423,632	3,916.6	238.15	822
Water Usage Pre	5,423,632	3,916.6	238.15	822
Water Usage Post	5,423,632	3,916.6	238.15	822
Gravel Usage Pre	89,243	64.1	459	1,583
Gravel Usage Post	1,614	1.2	1	1

	(Mmbtu)	ThermB	kWh
Energy Pro (Mmbtu)	5,196		1,522,308
Energy Prod (Mmbtu)	5,077		1,487,561
Energy Savings	119		34,727
% Savings (Prod Water)	2.3%		

Arapahoe County Domestic Water
ACJC Detention Center

BILLING DATA	Average last year Gallons	Staff days per month	Visitors days per month	Population days	Sanitary Water Use Model	Water		Sewer		Water		Sewer		Differential
						Balance	Gallons Saved	Water Dollars Saved	Sewer Dollars Saved	Total Dollars Saved	Differential	Differential	Differential	
							< 25,000 gal	\$0.00290	\$0.00232					
							25,001-200,000	\$0.00363	\$0.00290					
							>200,000	\$0.00435	\$0.00346					
Jan	2,756,486	31	31	6,820	3,028,525	-272,039	557,531	\$2,425	\$1,940	\$4,365	-9%			
Feb	4,021,000	28	28	6,160	2,735,442	1,285,558	503,576	\$2,191	\$1,752	\$3,943	47%			
Mar	4,314,714	31	31	6,820	3,028,525	1,286,189	557,531	\$2,425	\$1,940	\$4,365	42%			
Apr	4,984,286	30	30	6,600	2,930,831	2,053,455	539,546	\$2,347	\$1,878	\$4,225	70%			
May	3,368,529	31	31	6,820	3,028,525	340,004	557,531	\$2,425	\$1,940	\$4,365	11%			
June	4,151,471	30	30	6,600	2,930,831	1,220,640	539,546	\$2,347	\$1,878	\$4,225	42%			
Jul	4,564,877	31	31	6,820	3,028,525	1,536,152	557,531	\$2,425	\$1,940	\$4,365	51%			
Aug	4,210,161	31	31	6,820	3,028,525	1,181,636	557,531	\$2,425	\$1,940	\$4,365	39%			
Sep	5,095,161	30	30	6,600	2,930,831	2,164,330	539,546	\$2,347	\$1,878	\$4,225	74%			
Oct	4,572,727	31	31	6,820	3,028,525	1,544,202	557,531	\$2,425	\$1,940	\$4,365	51%			
Nov	3,977,273	30	30	6,600	2,930,831	1,046,442	539,546	\$2,347	\$1,878	\$4,225	36%			
Dec	3,475,000	31	31	6,820	3,028,525	446,475	557,531	\$2,425	\$1,940	\$4,365	15%			
	49,491,485	365		80,300	35,658,442	13,833,043	6,564,473	28,555	\$22,844	\$51,400	13%			

Non Sanitary Use	kgals	Ice machine	Evaporative coolers	Laundry	Kitchen	Impaction	Total		Total Modeled usage	Modeled to Billing ratio
							Balance	Total		
Jan	-272,039	2,920	0	197,731	120,861	0	321,513	-593,552	3,350,038	-22%
Feb	1,285,558	1,286	0	197,731	120,861	0	321,513	964,045	3,056,955	24%
Mar	1,286,189	1,286	0	197,731	120,861	0	321,513	964,676	3,350,038	22%
Apr	2,053,455	2,053	5,494	197,731	120,861	4,707	327,066	1,726,449	3,257,837	35%
May	340,004	340	63,178	197,731	120,861	8,015	384,690	-44,696	3,413,215	-1%
June	1,220,640	1,221	2,920	370,826	197,731	8,237	692,338	528,302	3,623,169	13%
Jul	1,536,152	1,536	2,920	716,330	197,731	9,253	1,038,443	497,709	4,086,968	11%
Aug	1,181,636	1,182	2,920	596,088	197,731	5,553	917,581	264,055	3,946,106	5%
Sep	2,164,330	2,164	2,920	156,571	197,731	4,190	478,083	1,686,247	3,408,914	33%
Oct	1,544,202	1,544	0	197,731	120,861	4,033	321,513	1,222,669	3,350,038	27%
Nov	1,046,442	1,046	0	197,731	120,861	0	321,513	724,930	3,252,343	18%
Dec	446,475	446	0	197,731	120,861	0	321,513	124,962	3,350,038	4%
	13,833,043	13,833	35,045	1,909,067	1,581,852	39,282	4,506,862	8,065,826	41,425,659	16%




Arapahoe County Domestic Water
ACJC Detention Center

Assumptions		
Staff Population	195	
Pop Ratio Female	60.00%	
Visitor Population		
Pop Ratio Female		
Inmate Population		
Pop Ratio Female		
Population Inmate		
Staff Absentee rate	0.00%	
Visitors/day	163	
Visitor ratio Female	0.8	
Length of stay(hours)	1.2	
Days/year	365	
Site Type (Res Comm)	res	
Common Laundry?	no	
Quantity of Machines	6	
Quantity of Apt Units	88	
Laundry Population	0	
non resident factor	0.01	
Water Temperature		
Street	54	
DHW supply	130	
DHW Efficiency	0.7	
Laundry		
Cycle/person/day	0	
Gallons/load Pre	37.5	
Gallons/load Post	25	
Ice Machine Calc.		
Lbs/ Day	300	
lbs/year	109500	
Gallons / year	13145.3	
Gallons of water/100 lbs of ice procees waste	4	
Process waste	4380	
Storage waste / day	24	
Est. Storage Waste	8760	
Number of Ice Machines	2	
Total Storage Waste	17520	
Total Ice Machine Usage (Gallons)	35045	

Energy Inputs		Billing units	\$/unit
DHW heating source	NG	kWh	\$0.5300
Fuel conversion source	GG	Therm	\$0.6500
Nat. Gas System Efficiency			82.00%

0.020831	29.997
----------	--------



ECM 18 – Water Reclaim

There are three primary uses of water at the Peoria Shops: sanitary, road maintenance and vehicle washing. After estimating the sanitary usage in a manner identical to the methods used to analyze the sanitary water usage at the other buildings, the billing records indicate that the sanitary usage is a minor component of the total usage. The road maintenance water use was estimated and the balance of the water use is assumed to be the vehicle-washing load.

Water usage is determined by:

Sanitary Usage + Road Maintenance Usage + Vehicle Washing Usage

The road maintenance usage was estimated using the following assumptions based on interviews with the road construction staff.

Street Sweepers	
Capacity (gallons)	250
Quantity	4
Frequency (days each unit filled per year)	237
Total Usage (product of above) (gallons)	59,365
Patch Trucks	
Capacity (gallons)	50
Quantity	3
Frequency (days each unit filled per year)	150
Total Usage (product of above) (gallons)	22,500
Tankers	
Capacity (gallons)	3000
Quantity	2
Frequency (days each unit filled per year)	0
Total Usage (product of above) (gallons)	0
Grand Total (Gallons)	81,865

Street sweeper trucks go out every working day when it is above 20 °F. The number of days used accounts for the cold days. The patch trucks work during the summer construction season and fill or top off their tanks once a day.

There are large 3000 + gallon tank trucks used on road repair and road building projects for dust control. These trucks are filled at a remote standpipe and Shop water is not used for this function.

The vehicle-washing component includes washing passenger vehicles and trucks to maintain a presentable appearance and “mucking” out dump truck and cleaning mud and grime from the undercarriage. For the purposes of the estimating savings, it was assumed that the total vehicle wash water usage is divided equally between the vehicle washing and mucking operations and that 100 % of the mucking wash water would be recycled.

Water Savings:

$$\text{Total Usage} - \text{Sanitary Usage} - \text{Road Work Usage} = \text{Total Vehicle Washing Usage}$$

$$\text{Washing Recycle Savings} = \text{Total Vehicle Washing Usage} / 2$$

The electrical usage for the new system is summarized below:

Electric Calc: Washer pump	Washer Pump	Sump Pump
HP	10	1
kW/HP	0.746	0.746
Load Factor	0.70	0.70
Efficiency	0.80	0.70
kW (HP x .746 hp/kW x load factor / efficiency)	6.53	0.75
GPM	25	25
Gallons used for washing	640,000	640,000
Run Time	427	427
Total kWh	2,785	318
	Total kWh	3,103


Arapahoe County Domestic Water
Peoria Shops
 Road Maintenance

Street sweepers are deployed when Temps are above 20 °F

Street Sweepers	250	actions
Capacity	4	
Quantity	237	
Frequency	59,365	
Total Usage		
Patch Trucks	50	
Capacity	3	
Quantity	150	
Frequency	22,500	
Total Usage		
Tankers	0	
Capacity	2	
Quantity	150	
Frequency	0	
Total Usage		
Grand Total	81,865	

Recycle factor 0.5
 Total recycle savings 640000
 Estimated cost savings 9600

Total Hours		20
average	Denver	
97	4	0
92	42	0
87	168	0
82	280	0
77	397	0
72	498	0
67	634	0
62	798	0
57	799	0
52	769	0
47	737	0
42	710	0
37	672	0
32	678	0
27	582	0
22	436	0
17	242	242
12	137	137
7	80	80
2	46	46
-3	20	20
-8	11	11
-13	3	3
-18	2	2
		541
		23



ECM 19 – Laundry Conservation

The savings from the use of an ozone sanitizer comes from water savings produced by reducing the number of fills in a wash cycle and energy savings produced by the reduction of wash and rinse water temperatures. The reductions are based on the track record of ozone units installed at other facilities per manufacturer data and on data gathered from the facility including the quantity and size of loads and the degree of soiling. The reduction in water volume use and the reduction in water temperature are the manufactures estimates.

The following assumptions were used in calculating the savings:

Wash Load	LBS/day
Total Pounds/day	2,289
% Light Soil	90%
% Heavy Soil	10%

Wash Duty	Pre Measure Gallons/ Pound	Ozone Gallons per Pound	Percent Savings
Light Soil	2.8	2.1	26%
Heavy Soil	3.2	2.6	19%

Water Temperature °F	
Street	55.0
DHW supply	170.0


Laundry	Hot Water Fraction	
	Pre measure condition	Ozone Condition
Light Wash	65%	5%
Heavy Wash	73%	14%

Model pre measure	Light Soil			Heavy Soil		
	Cold	Hot	Total	Cold	Hot	Total
Gal/lb	0.98	1.82	2.80	0.86	2.34	3.20
lb/day	2,060	2,060	4,120	229	229	458
Gal/day	2,019	3,749	5,768	198	535	732
total gals/year	736,898	1,368,524	2,105,422	72,186	195,169	267,355
Model Ozone	Cold	Hot	Total	Cold	Hot	Total
Gal/lb	1.96	0.10	2.07	2.27	0.31	2.58
lb/day	2,060	2,060	4,120	229	229	458
Gal/day	4,046	213	4,259	521	71	591
total gals/year	1,476,728	77,676	1,554,404	190,006	25,841	215,846

Total Gallons Saved = (2,105,422-1,554,404) + (267,355-215,846) = 602,527

Hot Water Gallons Saved = (1,368,524 – 77,676) + (195,169 – 25,841) = 1,460,176

Therms Saved = (1460*(8.33*(170-55))/1000/0.8) = 1,748



ECM 20 – Replace DHW HX with a New DHW Heater

Please refer to the Energy Conservation Measure (ECM) section of this report for additional information.

Existing Condition to Warrant an ECM Opportunity:

Currently, the domestic hot water (DHW) for building 01-Administration Building is produced by a heat exchanger (HX) that is served by the building's heating hot water loop. So, the two big natural gas-fired boilers that provide heating hot water must operate throughout the entire year in order to serve the building's DHW system. The replacement of the DHW HX with a stand-alone DHW heater will eliminate the need to operate the two boilers throughout the entire year, and DHW with a higher efficient heating source.

Savings Calculation Methodology:

The implementation of this ECM shall result in natural gas savings. The first step in the savings calculation was to determine what the building's DHW load is. Once the actual DHW load was calculated then the amount of natural gas that is currently being consumed by the existing DHW system was calculated utilizing a 70% heating efficiency. Also, the amount of natural gas that will be consumed by the new DHW heater to meet the building's DHW load was calculated using an 85% heating efficiency. These two values were then subtracted from each other to produce a natural gas savings that is the result of a higher efficient heating source. Additional savings were calculated by subtracting the new DHW heater's summer usage from the billed summer usage which reflects the natural gas saved by not having to operate the boilers in the summer months.

Existing DHW Heater		Staff		Visitor	
		Faucet Usage women	Faucet Usage men	Faucet Usage women	Faucet Usage men
Days/year		237	237	251	251
Population:		231	154	41	41
Minutes		1	1	1	1
Use per day					
Uses or minutes		54,747	36,498	10,291	10,291
Diversity (account for absentee)		0.95	0.95	0.95	0.95
GPU present					
GPM present (PRE)		2.5	2.5	2.5	2.5
GPM Proposed					
GPM Proposed (POST)		1.5	1.5	1.5	1.5
Total Usage Pre (Gals)		130,024	86,683	24,441	24,441
Total Usage Post (Gals)		78,014	52,010	14,665	14,665
Savings		52,010	34,673	9,776	9,776

	100% Efficiency	70% Efficiency (Existing)
Total (Gals/yr.)	265,589	379,413
Yearly Usage/Annual Therms	1,681	2,402
% HW	0.67	
Total HW (Gals/yr.) PRE	178,237	254,624
Yearly Usage/Annual Therms HW	1,128	1,612


Monthly Therms / DHW		Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec
Days		31	28	31	30	31	30	31	31	30	31	30	31
Monthly Usage/Therms (100%)		143	129	143	138	143	138	143	143	138	143	138	143
Monthly Usage/Therms (100%) HW		96	87	96	93	96	93	96	96	93	96	93	96
Existing DHW Heater		Total Therms in Summer HW 284											
Monthly Usage/Therms (70%)		204	184	204	197	204	197	204	204	197	204	197	204
Monthly Usage/Therms (70%) HW		137	124	137	132	137	132	137	137	132	137	132	137
New DHW Heater		Total Therms in Summer HW 406											
Monthly Usage/Therms (85%)		168	152	168	162	168	162	168	168	162	168	162	168
Monthly Usage/Therms (85%) HW		113	102	113	109	113	109	113	113	109	113	109	113
85% Efficiency		Total Therms in Summer HW 334											
Total (Gals/yr.)		312,458											
Yearly Usage/Annual Therms		1,978											
% HW		0.67											
Total HW (Gals/yr.) PRE		209,690											
Yearly Usage/Annual Therms HW		1,328											

Savings		Savings (therms)	
Savings by Efficiency (12 mo.)	70% Efficiency	85% Efficiency	
Yearly Usage	2,402	1,978	424
Savings by Summer (boilers off)			
Summer Usage	3,030	498	
Total Savings			2,956
Yearly Usage (therms)			

Admin I - DHW Pump EMCS Savings

Pump ID:	HP:	LF:	Efficiency:	kW:	Existing Run Hrs:	New Run Hrs:	kWh Savings:
DHWP-1	0.17	0.75	0.7	0.13	8,760	3,259	733
HX Pump	0.25	0.75	0.7	0.20	8,760	3,259	1,099
Total kWh Savings:							1,832

Note: The existing run hours are 24 h/d, 7 d/w. The new run hours are 12.5 h/d, 5 d/w. These savings shall be added to the EMCS savings that were calculated in the Trane Trace building simulation model.



ECM 21 - Change Natural Gas Utility Provider

Savings Calculation Description:

The savings for this ECM result from using a cheaper gas rate. The current natural gas utility provider, Xcel Energy, at Building 13-Arapahoe Human Services charges \$0.74946/therm. The new natural gas utility provider, Seminole Energy Services, shall charge \$0.63481/therm.

The dollar savings for this ECM were calculated by taking the difference in the two utility rates (\$0.11465/therm) and multiplying it the target natural gas usage of the facility. The target natural gas usage was calculated with the following equation:

Target Natural Gas Usage = Baseline Natural Gas Usage - Total Natural Gas Saved

where,

Total Natural Gas Saved = Total Natural Gas Saved at Building 12-Arapahoe Plaza Building + Total Natural Gas Saved at Building 13-Arapahoe Human Services + Total Natural Gas Saved at Building 14-Arapahoe Plaza West Building

Note: The natural gas-fired boilers at Building 13-Arapahoe Human Services provide heating to Buildings 12 and 14, that is why these two buildings are included in the calculation above.

Project: Arapahoe County
Building: 13-Arapahoe Human Services

Natural Gas Usage Baseline

Baseline Units: therms

Account #(s): 53-3441672-9


Meter #(s): 1015025

Total Monthly Natural Gas Usage (therms)					CEA Baseline	Average All Data	Average Last 2 Years	Most Recent 12 Months
Month	2002	2003	2004	2005				
Jan			7,719	6,316	6,316	7,018	7,018	6,316
Feb			6,785	5,567	5,567	6,176	6,176	5,567
Mar			4,638	5,364	5,364	5,001	5,001	5,364
Apr	2,333		3,074		3,074	2,704	3,074	3,074
May	1,388		2,324		2,324	1,856	2,324	2,324
Jun	587		1,054		1,054	821	1,054	1,054
Jul			605		605	605	605	605
Aug		524	873		873	699	699	873
Sep		1,193	1,523		1,523	1,358	1,358	1,523
Oct	3,702	3,570	4,029		4,029	3,767	3,800	4,029
Nov	5,787	5,918	6,131		6,131	5,945	6,025	6,131
Dec		7,347	6,336		6,336	6,842	6,842	6,336
Totals	13,797	18,552	45,091	17,247	43,196	42,792	43,976	43,196

The CEA Baseline is the Most Recent Twelve Months Data Collected.

The Initial Monitoring Baseline will be reviewed and determined before the start of monitoring.

Performance Contract Savings:	16280
New Baseline:	26,916
0.11465 \$	3,086




ECM 23 – Energy Resource Conservation Manager

Savings will be achieved through behavioral modifications of occupants (convincing them to turn their lights off, don't mess with thermostats, etc.). See ECM write-up #23 in Section 4 of this Report for more information. The savings for this ECM are stipulated.

Arapahoe County's utility budget over the past twelve months was \$2,274,106 including water, electrical, and natural gas usage. Table 2-4 in Volume I of this report illustrates this.

- The current recommended program estimates that \$431,264 in energy savings thus reducing the energy budget to \$1,842,842.
- A conservative estimate of savings for this program is 1% of budget or \$18,428.
- \$15,000 is used in the program.



ECM 24 – Replace Cooling Tower

Figure 1

Arapahoe County - ACJC Courthouse
Computer Model Calibration for Electric Energy Use

Month	ELECTRIC ENERGY USAGE (kWh)	
	BASELINE	MODEL
Jan	202,551	197,435 3%
Feb	172,659	178,589 -3%
Mar	234,751	203,151 13%
Apr	234,674	190,309 19%
May	248,888	221,458 11%
Jun	247,557	224,685 9%
Jul	293,663	238,057 19%
Aug	276,365	238,231 14%
Sep	228,143	211,261 7%
Oct	214,985	213,383 1%
Nov	201,979	192,946 4%
Dec	199,199	194,492 2%
	2,755,414	2,503,997 9%





Figure 1

Arapahoe County - ACJC Courthouse
Computer Model Calibration for NG usage

Month	NG USAGE (Therms)	
	BASELINE	MODEL
Jan	9,680	8,570 11%
Feb	8,870	7,938 11%
Mar	7,540	7,540 0%
Apr	6,710	5,356 20%
May	4,560	3,860 15%
Jun	4,020	2,835 29%
Jul	2,730	1,484 46%
Aug	3,710	2,446 34%
Sep	3,870	3,639 6%
Oct	6,020	5,366 11%
Nov	6,770	7,029 -4%
Dec	8,320	8,374 -1%
	72,800	64,437 11%



MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 ACJC Courthouse

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kW/h)	197,435	178,589	203,151	190,309	221,453	224,865	238,057	238,231	211,281	213,383	192,946	194,492	2,503,985
On-Pk Demand (kW)	409	409	409	430	486	583	581	574	516	490	409	409	581
Gas													
On-Pk Cons. (therms)	8,570	7,938	7,540	5,356	3,860	2,835	1,484	2,446	3,639	5,368	7,029	8,374	64,439
On-Pk Demand (therms/hr)	45	44	44	44	44	44	44	44	44	44	44	44	45
Water													
Cons. (1000gal)	0	0	0	0	82	109	155	132	81	56	0	0	615
Building Energy Consumption = 142,485 Btu/(ft2-year)													
Source Energy Consumption = 308,201 Btu/(ft2-year)													
Floor Area = 105,204 ft2													

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 ACJC Courthouse

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric	On-Pk Cons. (kWh)	172,576	155,952	166,190	194,011	196,562	208,985	208,391	185,310	186,583	168,343	189,960	2,189,927
	On-Pk Demand (kW)	346	346	350	415	488	501	491	443	417	348	346	501
Gas	On-Pk Cons. (therms)	8,695	8,063	7,673	3,915	2,859	1,436	2,445	3,694	5,460	7,149	8,475	66,319
	On-Pk Demand (therms/hr)	42	42	42	42	42	42	42	42	42	42	42	42
Water	Cons. (1000gal)	0	0	0	67	90	129	108	66	46	0	0	506
Building Energy Consumption = 133,133 Btu/(ft2-year)													
Source Energy Consumption = 278,513 Btu/(ft2-year)													
Floor Area = 105,204 ft2													

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 ACJC Courthouse

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	164,194	148,381	158,067	158,423	184,563	168,552	203,494	197,971	175,808	178,072	160,172	162,178	2,087,862
On-Pk Demand (kW)	346	346	346	350	415	488	501	491	443	417	346	346	501
Gas													
On-Pk Cons. (therms)	8,519	7,900	7,409	4,930	3,084	1,916	800	1,394	2,877	4,630	6,839	8,278	58,575
On-Pk Demand (therms/hr)	42	42	42	42	33	13	7	10	31	42	42	42	42
Water													
Cons. (1000gal)	0	0	0	0	65	85	133	104	62	46	0	0	496
Building Energy Consumption =													
Source Energy Consumption =													
Floor Area =													
			123,411	Btu/(ft2-year)									
		261,828	Btu/(ft2-year)										
		105,204	ft2										

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 ACJC Courthouse

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	165,187	148,258	169,078	159,381	185,535	187,457	204,084	198,853	176,722	179,073	161,138	163,158	2,098,842
On-Pk Demand (kW)	349	349	349	353	417	488	501	481	446	420	348	348	501
Gas													
On-Pk Cons. (therms)	7,042	6,530	6,129	4,089	2,570	1,608	527	1,180	2,389	4,007	5,659	6,844	48,583
On-Pk Demand (therms/hr)	35	34	34	34	27	10	6	8	28	34	34	34	35
Water													
Cons. (1000gal)	0	0	0	0	65	85	133	104	82	46	0	0	498
Building Energy Consumption = 114,269 Btu/(ft2-year) Source Energy Consumption = 252,800 Btu/(ft2-year) Floor Area = 105,204 ft2													

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 ACJC Courthouse

Utility Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	165,187	149,258	169,076	159,381	184,637	186,273	202,080	197,420	175,861	178,439	161,738	163,159	2,091,908
On-Pk Demand (kW)	349	349	348	353	414	483	494	485	442	476	349	349	494
Gas													
On-Pk Cons. (therms)	7,042	5,530	6,129	4,089	2,570	1,608	527	1,180	2,399	4,007	5,659	6,844	40,583
On-Pk Demand (therms/hr)	35	34	34	34	27	10	6	8	26	34	34	34	35
Water													
Cons. (1000gal)	0	0	0	0	64	84	132	103	62	45	0	0	490

Building Energy Consumption = 114,045 Btu/(ft2-year)
Source Energy Consumption = 252,226 Btu/(ft2-year)
Floor Area = 105,204 ft2

MODELING NOTES

ARAPAHOE COUNTY - ACJC COURTHOUSE

ECM Run: Upgrade Existing EMCS

Fan System	Item Changed	Previous Run Input	Current Run Input
AH-1	Fan Schedule Changed	M-F - 4am-11pm, Sat-Sun: 8am-17pm	M-F: 5:30am-9:30pm; Sat-Sun: 8am-17pm
AHU-1	Fan Schedule Changed	M-F - 4am-11pm, Sat-Sun: 8am-17pm	M-F: 5:30am-9:30pm; Sat-Sun: 8am-17pm
AHIU-2	Fan Schedule Changed	M-F - 4am-11pm, Sat-Sun: 8am-17pm	M-F: 5:30am-9:30pm; Sat-Sun: 8am-17pm

Previous Run (New Lighting Run):

Annual kWh Usage: 2,189,928
Annual kW Usage: 4,835
Annual Therm Usage: 65,319

Current Run (Upgrade Existing EMCS Run):

Annual kWh Usage: 2,087,853
Annual kW Usage: 4,835
Annual Therm Usage: 58,576

Savings (Upgrade Existing EMCS Savings):

Annual kWh Savings: 102,075
Annual kW Savings: 0
Annual Therm Savings: 6,743

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

MODELING NOTES

ARAPAHOE COUNTY - ACJC COURTHOUSE

ECM Run: Replace the Existing Boilers

Cooling Equipment Tag	Item Changed	Previous Run Input	Current Run Input
NG Fired HW Boilers	Efficiency	Atmospheric Boiler (65% Efficient Energy Rate)	Gas Fired Hot Water Boiler (79% Efficient Energy Rate)

Previous Run (Upgrade Existing EMCS Run):

Annual kWh Usage: 2,087,853
Annual kW Usage: 4,835
Annual Therm Usage: 58,576

Current Run (Replace the Existing Boilers Run):

Annual kWh Usage: 2,098,843
Annual kW Usage: 4,861
Annual Therm Usage: 48,584

Savings (Replace the Existing Boilers Savings):

Annual kWh Savings: -10,990
Annual kW Savings: -26
Annual Therm Savings: 9,992

Notes:

1. The negative kW and kWh savings is the energy used by the forced draft burner on the new boiler.

Electric Savings Safety Factor: 0.73

Natural Gas Savings Safety Factor: 0.73

MODELING NOTES

ARAPAHOE COUNTY - ACJC COURTHOUSE

ECM Run: Replace Cooling Tower

Cooling Equipment Tag	Item Changed	Previous Run Input	Current Run Input
Water Cooled Chiller	Energy Rate	0.8536 kW/ton	0.776 kW/ton

Previous Run (Upgrade Existing EMCS Run):

Annual kWh Usage: 2,098,843
Annual kW Usage: 4,861
Annual Therm Usage: 48,584


Current Run (Replace the Cooling Tower Run):

Annual kWh Usage: 2,091,909
Annual kW Usage: 4,832
Annual Therm Usage: 48,584

Savings (Replace Cooling Tower Savings):

Annual kWh Savings: 6,934
Annual kW Savings: 29
Annual Therm Savings: 0

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73



ECM 25 – Retro-commissioning

Details of Retro-commissioning services can be found in ECM write-up #25, located in Volume 1 of 2 of this Comprehensive Energy Analysis.

Existing Condition to Warrant an ECM Opportunity:

The Sheriff's Coroners and Centrepont Facilities are two recently built buildings that currently have an energy management control system (EMCS). In both cases, the equipment in these facilities operates during periods of the little or no occupancy. So, some of the existing operating schedules programmed into the EMCS can be modified to better match the actual occupancy schedules. Also much of the HVAC equipment has fallen out of calibration and is not operating very efficiently.

Savings Calculation Methodology:

The savings for this ECM were calculated utilizing two Trane Trace building energy simulation models. The first model included the existing operating schedules for each piece of equipment. The second model was modified to include the new operating schedules to set back areas within the facilities during unoccupied periods. As each facility utilizes electric reheat the models were also programmed to allow the natural gas preheat to operate in lieu of the electric reheat during morning warm-up as this is a more efficient way to operate the equipment. This made gas usage increase but saved considerable amount of electric energy. The annual energy consumption calculated from each model was subtracted from one another to produce the annual energy savings.

Spreadsheet calculations were performed on the buildings that were not modeled. The spreadsheet calculations used the same methodology described above.

Figure 1

Arapahoe County - Centrepont Plaza
Computer Model Calibration for Electric Energy Use

Month	ELECTRIC ENERGY USAGE (kWh)	
	BASELINE	MODEL
Jan	260,048	165,144 36%
Feb	230,963	151,316 34%
Mar	252,724	169,175 33%
Apr	215,531	151,954 29%
May	211,119	199,585 5%
Jun	213,078	216,752 -2%
Jul	224,479	245,758 -9%
Aug	222,248	240,887 -8%
Sep	210,752	190,230 10%
Oct	215,706	171,451 21%
Nov	230,257	153,726 33%
Dec	256,230	156,570 39%
	2,743,135	2,212,548 19%





Figure 1

Arapahoe County - Centrepont Plaza
Computer Model Calibration for NG usage

Month	NG USAGE (Therms)	
	BASELINE	MODEL
Jan	340	186 45%
Feb	290	168 42%
Mar	290	186 36%
Apr	150	180 -20%
May	160	186 -16%
Jun	120	180 -50%
Jul	130	186 -43%
Aug	140	186 -33%
Sep	140	180 -29%
Oct	150	186 -24%
Nov	160	180 -13%
Dec	170	186 -9%
	2,240	2,190 2%



MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 Centrepont Plaza

Utility Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	165,144	151,316	169,175	151,964	159,565	216,752	245,758	240,887	190,230	171,451	153,728	156,570	2,212,549
On-Pk Demand (kW)	560	509	548	509	606	657	797	715	647	560	514	589	797

Gas													
On-Pk Cons. (therms)	186	188	186	180	166	180	186	186	180	186	180	186	2,190
On-Pk Demand (therms/hr)	0	0	0	0	0	0	0	0	0	0	0	0	0

Building Energy Consumption = 57,380 Btu/(ft2-year)
 Source Energy Consumption = 169,007 Btu/(ft2-year)
 Floor Area = 135,421 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 Centrepont Plaza

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	161,443	147,980	155,165	147,758	194,701	211,758	240,844	235,560	185,659	186,738	149,436	152,822	2,159,865
On-Pk Demand (kW)	547	557	539	494	590	841	774	698	690	545	506	557	774
Gas													
On-Pk Cons. (therms)	186	188	186	180	186	180	186	186	180	186	180	186	2,190
On-Pk Demand (therms/hr)	0	0	0	0	0	0	0	0	0	0	0	0	0
Building Energy Consumption =													
Source Energy Consumption =													
Floor Area =													
			58,052	Btu/(ft2-year)									
			165,023	Btu/(ft2-year)									
			135,421	ft2									

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 Centrepoint Plaza

		Monthly Energy Consumption												
Utility		Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric	On-Pk Cons. (kWh)	144,780	132,997	149,824	134,020	180,345	156,001	221,271	217,840	171,107	152,455	136,386	137,896	1,973,523
	On-Pk Demand (kW)	547	557	553	494	591	642	786	701	635	545	509	557	788
Gas	On-Pk Cons. (therms)	188	188	188	180	186	180	186	186	180	186	180	186	2,190
	On-Pk Demand (therms/hr)	0	0	0	0	0	0	0	0	0	0	0	0	0
Building Energy Consumption =		51,353 Btu/(ft2-year)												
Source Energy Consumption =		150,955 Btu/(ft2-year)												
Floor Area =		135,421 ft2												

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 Centrepoin Plaza

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	111,981	88,612	125,980	131,508	180,345	196,001	221,271	217,840	171,107	150,770	120,902	108,691	1,834,807
On-Pk Demand (kW)	448	447	458	494	591	642	786	701	635	545	457	446	788
Gas													
On-Pk Cons. (therms)	1,655	1,708	1,248	294	186	180	186	186	180	261	827	1,500	8,408
On-Pk Demand (therms/hr)	11	11	11	9	0	0	0	0	0	3	11	11	11
Building Energy Consumption =													
Source Energy Consumption =													
Floor Area =													
			52,451										
			145,277										
			135,421										
			ft2										

MODELING NOTES

ARAPAHOE COUNTY - CENTREPOINT PLAZA

ECM Run: Upgrade Existing EMCS

Fan System	Item Changed	Previous Run Input	Current Run Input
Rm-1	Fan Schedule Changed	M-F - 5am-11pm, Sat-Sun: 8am-5pm	M-F: 6am-10pm; Sat-Sun: 8am-5pm
Rm-2	Fan Schedule Changed	M-F - 5am-11pm, Sat-Sun: 8am-5pm	M-F: 6:30am-9pm; Sat-Sun: 8am-5pm
Rm-3	Fan Schedule Changed	M-F - 5am-11pm, Sat-Sun: 8am-5pm	M-F: 7am-7pm

Previous Run (New Lighting Run):

Annual kWh Usage: 2,159,864
Annual kW Usage: 7,078
Annual Therm Usage: 2,190

Current Run (Upgrade Existing EMCS Run):

Annual kWh Usage: 1,973,822
Annual kW Usage: 7,119
Annual Therm Usage: 2,190

Savings (Upgrade Existing EMCS Savings):

Annual kWh Savings: 186,042
Annual kW Savings: -41
Annual Therm Savings: 0

Notes:

1. The negative kW savings is the result of the electric reheat coils all coming 100% on in the morning to bring the space temperature up from 55F in the morning. These negative savings shall not be accounted for since the EMCS shall warm each space up gradually without having to energize each reheat coil to 100% of its capacity.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

MODELING NOTES

ARAPAHOE COUNTY - CENTREPOINT PLAZA

ECM Run: Utilize Natural Gas Preheat

Cooling Equipment Tag	Item Changed	Previous Run Input	Current Run Input
Heating System 01	Preheat Coil Plant Type	No Preheat Coil	NG Preheat Coil
Heating System 02	Preheat Coil Plant Type	No Preheat Coil	NG Preheat Coil
Heating System 03	Preheat Coil Plant Type	No Preheat Coil	NG Preheat Coil

Previous Run (Upgrade Existing EMCS Run):

Annual kWh Usage: 1,973,822
Annual kW Usage: 7,119
Annual Therm Usage: 2,190

Current Run (Utilize Natural Gas Preheat Run):

Annual kWh Usage: 1,834,806
Annual kW Usage: 6,652
Annual Therm Usage: 8,409

Savings (Utilize Natural Gas Preheat Savings):

Annual kWh Savings: 139,016
Annual kW Savings: 467
Annual Therm Savings: -6,219

Notes:

1. The air handling units are equipped with natural gas burners that can be utilized to preheat the mixed air stream before it enters the electric reheat VAV boxes. Currently they are not being utilized to do this, the electric reheat coils are handling the entire heating load. So this ECM, which is included with the Upgrade Existing EMCS ECM, includes utilizing the existing natural gas fired burners to preheat the mixed air stream.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

Figure 1

Arapahoe County - Sheriff/Coroner Facility
Computer Model Calibration for Electric Energy Use

ELECTRIC ENERGY USAGE (kWh)		
Month	BASELINE	MODEL
Jan	233,435	165,528
Feb	205,024	154,600
Mar	222,636	161,209
Apr	199,959	138,039
May	202,483	177,411
Jun	194,728	193,133
Jul	204,941	222,406
Aug	203,837	218,283
Sep	191,029	170,089
Oct	190,813	159,069
Nov	185,731	140,385
Dec	238,052	154,695
	2,472,668	2,054,847
		17%





Figure 1

Arapahoe County - Sheriff/Coroner Facility
Computer Model Calibration for NG usage

NG USAGE (Therms)		
Month	BASELINE	MODEL
Jan	1,970	1,262
Feb	1,760	1,187
Mar	1,410	1,122
Apr	1,050	796
May	770	205
Jun	630	150
Jul	760	149
Aug	580	149
Sep	670	207
Oct	930	764
Nov	1,640	978
Dec	2,780	1,191
	14,950	8,160
		45%



MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 Sheffs Corners

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	165,528	154,600	161,209	138,039	177,411	198,133	222,406	218,283	170,089	159,069	140,385	154,895	2,054,848
On-Pk Demand (kW)	541	550	550	485	567	603	681	643	593	528	472	550	681

Gas

On-Pk Cons. (therms)	1,262	1,187	1,122	796	205	150	149	149	207	764	978	1,191	8,160
On-Pk Demand (therms/hr)	3	3	3	3	2	1	0	0	2	3	3	3	3

Building Energy Consumption =

Source Energy Consumption =

Floor Area =

67,883 Btu/(ft2-year)
189,887 Btu/(ft2-year)
115,335 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 Sheriffs Coroners

		Monthly Energy Consumption												Total
Utility		Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	
Electric	On-Pk Cons. (kWh)	163,364	152,857	158,758	135,413	174,026	189,585	218,813	214,423	168,914	155,869	138,032	152,880	2,020,714
	On-Pk Demand (kW)	530	538	538	471	552	588	665	627	577	514	463	538	665

Gas

On-Pk Cons. (therms)	1,285	1,189	1,125	797	206	151	149	149	208	208	765	980	1,194	8,178
On-Pk Demand (therms/hr)	3	3	3	3	2	1	0	0	0	2	3	3	3	3

Building Energy Consumption =
Source Energy Consumption =
Floor Area =

66,888 Btu/(ft2-year)
186,873 Btu/(ft2-year)
115,335 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 Sheriffs Couriers

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	151,251	142,104	147,554	125,359	137,510	182,224	210,780	205,749	180,183	149,444	128,938	142,603	1,917,713
On-Pk Demand (kW)	530	538	538	470	552	589	666	628	578	514	463	538	686
Gas													
On-Pk Cons. (therms)	1,265	1,189	1,125	797	206	151	149	149	208	765	980	1,194	8,178
On-Pk Demand (therms/hr)	3	3	3	3	2	1	0	0	2	3	3	3	3

Building Energy Consumption = 63,840 Btu/(ft2-year)
 Source Energy Consumption = 177,728 Btu/(ft2-year)
 Floor Area = 115,335 ft2

MONTHLY ENERGY CONSUMPTION

By Release 2.006

Alternative: 1 Sheriffs Coroners

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	105,678	96,450	112,233	120,952	167,510	182,224	210,760	205,749	190,183	142,626	104,390	102,092	1,706,948
On-Pk Demand (kW)	427	427	426	470	552	589	666	628	578	514	427	427	666
Gas													
On-Pk Cons. (therms)	3,288	3,257	2,892	1,212	206	151	149	149	208	1,070	2,071	2,994	17,446
On-Pk Demand (therms/hr)	12	12	12	9	2	1	0	0	2	7	12	12	12

Building Energy Consumption = 65,698 Btu/(ft2-year)
Source Energy Consumption = 167,652 Btu/(ft2-year)
Floor Area = 115,335 ft2

MODELING NOTES

ARAPAHOE COUNTY - SHERIFF/CORONER FACILITY

ECM Run: Upgrade Existing EMCS

Fan System	Item Changed	Previous Run Input	Current Run Input
Rm-4	Fan Schedule Changed	M-F - 4am-1am, Sat-Sun: 8am-5pm	M-F: 5am-10pm; Sat-Sun: 8am-5pm
Rm-5	Fan Schedule Changed	M-F - 4am-1am, Sat-Sun: 8am-5pm	M-F: 6am-10pm; Sat-Sun: 8am-5pm

Previous Run (New Lighting Run):

Annual kWh Usage: 2,020,714
Annual kW Usage: 6,601
Annual Therm Usage: 8,178

Current Run (Upgrade Existing EMCS Run):

Annual kWh Usage: 1,917,714
Annual kW Usage: 6,604
Annual Therm Usage: 8,178

Savings (Upgrade Existing EMCS Savings):

Annual kWh Savings: 103,000
Annual kW Savings: -3
Annual Therm Savings: 0

Notes:

1. The negative kW savings is the result of the electric reheat coils all coming 100% on in the morning to bring the space temperature up from 55F in the morning. These negative savings shall not be accounted for since the EMCS shall warm each space up gradually without having to energize each reheat coil to 100% of its capacity.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73

MODELING NOTES

ARAPAHOE COUNTY - SHERIFF/CORONER FACILITY

ECM Run: Utilize Natural Gas Preheat

Cooling Equipment Tag	Item Changed	Previous Run Input	Current Run Input
Heating System 01	Preheat Coil Plant Type	No Preheat Coil	NG Preheat Coil
Heating System 02	Preheat Coil Plant Type	No Preheat Coil	NG Preheat Coil
Heating System 03	Preheat Coil Plant Type	No Preheat Coil	NG Preheat Coil

Previous Run (Upgrade Existing EMCS Run):

Annual kWh Usage: 1,917,714
Annual kW Usage: 6,604
Annual Therm Usage: 8,178

Current Run (Utilize Natural Gas Preheat Run):

Annual kWh Usage: 1,708,947
Annual kW Usage: 6,131
Annual Therm Usage: 17,447


Savings (Utilize Natural Gas Preheat Savings):

Annual kWh Savings: 208,767
Annual kW Savings: 473
Annual Therm Savings: -9,269

Notes:

1. The air handling units are equipped with natural gas burners that can be utilized to preheat the mixed air stream before it enters the electric reheat VAV boxes. Currently they are not being utilized to do this, the electric reheat coils are handling the entire heating load. So this ECM, which is included with the Upgrade Existing EMCS ECM, includes utilizing the existing natural gas fired burners to preheat the mixed air stream.

Electric Savings Safety Factor: 0.73
Natural Gas Savings Safety Factor: 0.73



ECM 26 – Replace Modulines, Install VAV Boxes, Diffusers, and Add Controls

There are no savings associated with the ECM.